

Order Plans @ www.LDinline.com

ELECTRICAL LEGEND	
LIGHTING FIXTURES - SEE LIGHTING FIXTURE SCHEDULE	
	RECESSED GRID LED
	EMERGENCY EGRESS LED
	SURFACE MOUNTED LED
	BRACKET MOUNTED LED
	EXIT LIGHT - WALL, CEILING
	SURFACE MOUNTED DOWNLIGHT
	RECESSED MOUNTED DOWNLIGHT
	WALL BRACKET
CONVENIENCE OUTLETS	
	SIMPLEX
	DUPLEX - WALL (W-WEATHERPROOF, GFI-GROUND FAULT PROTECTED), DOUBLE DUPLEX
	FLOOR MOUNTED DUPLEX
	DUPLEX ABOVE COUNTER
	DUPLEX - ISOLATED GROUND, DOUBLE DUPLEX ISOLATED GROUND
	DUPLEX - ISOLATED GROUND
	DUPLEX - MOUNTED AT 90°
	DUPLEXES - MOUNTED ABOVE AND BELOW, ONE AT 90° AND 90°
	DUPLEXES - MOUNTED ABOVE AND BELOW, ONE AT 90° AND 90° ABOVE COUNTER
	DUPLEX - ISOLATED GROUND, NON-INDUCTIVE COILS
	DUPLEX - ISOLATED GROUND, NON-INDUCTIVE COILS ABOVE COUNTER
	DUPLEX PURPOSE (COMPUTER)
	FLOOR MOUNTED SPECIFIC PURPOSE
	COMPUTER - WALL, FLOOR INDICATES MULTIPLE DROPS
	JUNCTION - WALL, CEILING
	TELEVISION
	TELEPHONE - WALL, FLOOR
	EXISTING MANHOLE POINT
	AUTO VIDEO IMPEDANCE AUTO VIDEO CONTROLLER
SWITCHES	
	SINGLE POLE (W-WEATHERPROOF)
	SINGLE POLE, MOTOR RATED
	SINGLE POLE, KEY OPERATED
	THREE WAY, KEY OPERATED
	0-10V LED DIMMER
	SINGLE POLE, PILOT LIGHT
	OCCUPANCY SENSOR
	THREE WAY
	FOUR WAY
PANELS	
	120/208V, 3PH, 4W OR 2WDY, 1PH, 3W
	480/277V, 3PH, 4W
	PLYWOOD BACKBOARD
	SWITCHBOARD OR MOTOR CONTROL CENTER
	TCS-TRANSIENT CONTROLLER, LSP-SURGE ARRESTER, ATS-AUTO TRANSFER SWITCH
CIRCUITS	
	RACEWAY IN CEILING OR WALL
	ONE CROSSMARK PER WIRE, 2 WIRES UNLESS SHOWN
	GENERAL - ONE ARROW PER CIRCUIT
	RACEWAY UNDER FLOOR OR SLAB
	FA-FIRE ALARM, IC-INTERCOM, TV-TELEVISION, C-COMPUTER
	EXPOSED RACEWAY
	FLEXIBLE RACEWAY
	CONDUIT - 1/2", 3/4", 1", 1 1/2", 2"
	SURFACE RACEWAY
	LOW VOLTAGE LIGHTING CONTROL CABLE
GENERAL EQUIPMENT	
	DISCONNECT SWITCH (FUSED, NON-FUSED)
	MOTOR CONTROLLER
	ENCLOSED CIRCUIT BREAKER
	COMBINATION STARTER/DISCONNECT
	CONTACTOR
	PHOTO-CELL
	AUXILIARY RELAY
	ROOM LIGHTING CONTROLLER
	PUSHBUTTON
	MOTOR - FRACTIONAL H.P.
	MOTOR - HORSEPOWER NOTED
	TRANSFORMER (CRY-TYPE)
	THERMOSTAT
	PULL BOX
	OCCUPANCY SENSOR
COMMUNICATION AND PROTECTION	
	FIRE VOICE EVACUATION AND POWER SUPPLY PANEL (FAP-ANNUNCIATOR PANEL, FAP-SATT-SUB PANEL)
	FIRE ALARM PULL STATION
	FIRE ALARM HORN - STROBE
	VOICE EVACUATION SPEAKER STROBE
	SMOKE DETECTOR - WALL, CEILING
	HEAT DETECTOR
	SPEAKER - CEILING PENDENT (W-WEATHERPROOF)
	DUCT MOUNTED SMOKE DETECTOR
	INDICATING STROBE
	MICROPHONE OUTLET - WALL, CEILING
	GLASS BREAK DETECTOR
	DOOR HOLDER
	INTERCOM CALL STATION - WALL, FLOOR (ADMINISTRATION PHONE, S-STATION)
	MASTER CLOCK - WALL, CEILING (D-DOUBLE FACE)
	HIGH POWER SPEAKER
	SECURITY SYSTEM ZONE STATUS INDICATOR
	MICROPHONE OUTLET - WALL, CEILING
	SECURITY SYSTEM KEYPAD
	CLOSED CIRCUIT TV CAMERA
	TWIN CLOSED CIRCUIT TV CAMERAS MOUNTED 180° OPPOSED
	CONDUIT SEALING FITTING
	CARD READER
	REQUEST TO EXIT DETECTOR
	ELECTRIC STRIKE
	DOOR STATUS MONITOR

REVISIONS/ISSUANCES		
NO.	DATE	DESCRIPTION
KEYPLAN		
N		
AH&P CONSULTING ENGINEERS		
ANDREWS, HAMMOCK & POWELL, INC. 250 Chester Lane Suite 100 Macon, Georgia 31210 Macon (478) 485-8321 FAX (478) 485-8210 WWW.AHPENR.COM		
Manley Spangler Smith Architects A Professional Corporation		
825 East Taylor St. P.O. Box 880 Griffin, Georgia 30204 Office: 770.227.5473 Fax: 770.226.3442		
PROJECT: RENOVATIONS, MODIFICATIONS, & ADDITIONS TO HENRY COUNTY SCHOOLS - GROUP 10 WOODLAND MIDDLE SCHOOL (ITEM B)		
CLIENT: HENRY COUNTY BOARD OF EDUCATION		
SHEET TITLE: ELECTRICAL LEGEND		
LL: 57 F.T.E.: 000 FACILITY CODE: 075-0308 © 2018 Manley Spangler Smith Architects, PC PROJECT NUMBER: 2017519 DATE: 06.07.18 SCALE: NONE DRAWN BY: CTS CHECKED BY: NDC		
SHEET NO.: E801		