ROOFTOP AIR CONDITIONING UNITS

TAG	TRANE MODEL NUMBER	TOTAL COOLING MBH	SENSIBLE COOLING MBH	TOTAL SUPPLY CFM	OA CFM	HEATING INPUT MBH	HEATING OUTPUT MBH	APPROX. SUPPLY ESP IN. WG	SUPPLY MOTOR HP	MIN. STAGES COOL	MIN. STAGES HEAT	ENTERING AIR °F DB	ENTERING AIR °F WB	MINIMUM AMBIENT COOLING °F	NOTES:
RTAC-1	YHC-036	38.9	28.7	1055	0	60	45	0.8	1	1	1	75	63.3	40	1,2,3,4,5,6,7,8,11,12,13,14,16,18
RTAC-2	YHC-048	47.2	35.8	1600	300	80	64	0.6	1	1	1	78.8	65.8	40	1,2,3,4,5,6,7,8,9,11,12,13,14,16,18
RTAC-3	XVCC-4824	24.5	18.4	500	80	60	48	0.8	1/3	1	1	80.0	67.0	55	1,2,3,4,5,9,13,14
RTAC-4	YHC-060	58.6	47.0	1995	0	80	61	0.5	1	1	1	70.0	63.0	40	1,2,3,4,5,6,7,8,11,12,13,14,16,18
RTAC-5	YHC-036	35.7	25.8	1150	200	60	45	0.4	1	1	1	75.8	65.8	40	1,2,3,4,5,6,7,8,9,11,12,13,14,15,16
RTAC-7	YHC-060	58.6	47.0	1995	0	80	61	0.5	1	1	1	70.0	63.0	40	1,2,3,4,5,6,7,8,11,12,13,14,16,18
RTAC-8	YHC-072	68.9	50.6	2560	200	120	96	0.6	1	1	1	75.8	65.8	40	1,2,3,4,5,6,7,8,9,10,11,12,13,16,18
RTAC-10	YHC-048	47.2	35.8	1625	0	80	64	0.8	1	1	1	75.0	63.0	40	1,2,3,4,5,6,7,8,11,12,13,14,16,18

1. COOLING CAPACITIES BASED ON AIR ENTERING EVAPORATOR AT SCHEDULED CONDITION AND 100°F AMBIENT AIR TEMPERATURE AND 1000 FT. ELEVATION. UNIT SHALL PROVIDE MECHANICAL COOLING DOWN TO SCHEDULED TEMPERATURE. UNIT SHALL UTILIZE R-410a REFRIGERANT.
2. HEATING CAPACITIES BASED ON 60°F AIR ENTERING HEAT EXCHANGER AND FIRING NATURAL GAS. PROVIDE ALUMINIZED STEEL HEAT EXCHANGER.
3. PROVIDE TRAPPED CONDENSATE DRAIN. SEE CONDENSATE DRAIN TRAP DETAIL.
4. UNIT SHALL HAVE BOTTOM DISCHARGE AND RETURN MOUNTED ATOP FULL PERIMETER 18" TALL (MINIMUM) ROOF CURB. SEE ROOF CURB DETAIL.
5. STATIC PRESSURE SCHEDULED DOES NOT INCLUDE WET COOLING COIL, FILTER, HEATING PLANT OR SYSTEM EFFECT LOSSES.
6. PROVIDE FACTORY INSTALLED NON-FUSED DISCONNECT SWITCH.
7. PROVIDE FACTORY INSTALLED 'INSIDE THE CURB' UTILITY PROVISIONS (POWER CIRCUIT AND CONTROLS CIRCUIT) SO THAT NO ELECTRICAL UTILITIES ARE OUTSIDE UNIT CASING. GAS CONNECTION SHALL BE OUTSIDE CASING. POWER CIRCUIT AND CONTROL CIRCUIT SHALL ALL BE ROUTED UP INSIDE THE CURB. CONTRACTOR SHALL ROUTE UTILITIES IN FACTORY DESIGNATED LOCATION. UNDER NO CIRCUMSTANCES SHALL CONTRACTOR CUT OPENINGS IN BOTTOM OF RTAC UNIT. FIELD CUTTING OF RTAC UNIT SHALL RESULT IN REJECTION OF RTAC UNIT AND NEW UNIT SHALL BE PROVIDED AT NO ADDITIONAL COST TO THE OWNER.
8. PROVIDE FACTORY INSTALLED POWERED G.F.I. CONVENIENCE OUTLET.
9. PROVIDE OUTDOOR AIR INTAKE HOOD WITH 25% MAXIMUM MANUAL OUTSIDE AIR DAMPER AND BIRDSCREEN.
10. PROVIDE FORWARD CURVED BELT DRIVE INDOOR FAN WITH ADJUSTABLE SHEAVE
11. PROVIDE LOUVERED CONDENSER HAIL GUARDS.
12. PROVIDE HINGED ACCESS DOORS WITH ¼ TURN LATCHES.
13. PROVIDE ELECTROMECHANICAL CONTROLS.
14. PROVIDE MULTISPEED DIRECT DRIVE FAN MOTOR OR BELT DRIVE WITH ADJUSTABLE SHEAVE.
15. PROVIDE INTEGRAL HOT GAS REHEAT DEHUMIDIFICATION COIL CIRCUIT. PROVIDE CRANK CASE HEATER, FROSTAT, THERMAL EXPANSION VALVE, AND ALL OTHER CONTROL AND MATERIAL OPTIONS REQUIRED TO ACCEPT INPUT FROM SPACE HUMIDITY SENSOR. RTAC SHALL PROVIDE MINIMUM TEMPERATURE RISE AS SCHEDULED TO DELIVER NEUTRAL DEHUMIDIFIED AIR DURING CALL FOR DEHUMIDIFICATION.
16. PROVIDE HIGH EFFICIENCY UNIT.
17. PROVIDE HORIZONTAL DISCHARGE AND HORIZONTAL RETURN MOUNTED ATOP FULL PERIMETER 14" TALL (MINIMUM) ACOUSTICAL ROOF CURB. SEE ACOUSTICAL ROOF CURB DETAIL. ACOUSTICAL ROOF CURB SHALL BE PREMANUFACTURED ITEM, NOT CONTRACTOR ASSEMBLED AND NOT STANDARD ROOF CURB PROVIDED BY RTAC MANUFACTURER. ACOUSTIC ROOF CURB PERIMETER DIMENSIONS SHALL BE THE SAME OUTER PERIMETER DIMENSIONS AS A STANDARD ROOF CURB, AND SHALL NOT BE LARGER THAN RTAC BASE RAIL.
18. PROVIDE BLANK-OFF PLATE OVER OUTSIDE AIR OPENING.

FILTERS

FILTER TYPE	CAMFIL FARR FILTER MODEL NUMBER	APPLICATION	MAXIMUM INITIAL PRESSURE DROP @ FACE VELOCITY P.D. IN W.G.	FPM	ASHRAE 52.1-1992 DUST SPOT EFFICIENCY	ASHRAE MERV	FILTER THICKNESS	NOTES:
PLEATED	30-30	ROOFTOP AIR CONDITIONERS	0.36	500	30%	7	2"	1,2,3,4,5

1. UL CLASS 2, MEDIUM EFFICIENCY, COTTON AND SYNTHETIC MEDIA FILTER.
2. PROVIDE RIGID HEAVY DUTY FRAME BONDED TO MEDIA WITH WELDED WIRE PLEATED SUPPORT GRID TO MAINTAIN RADIAL PLEAT.
3. FILTER MINIMUM EFFICIENCY REPORTING VALVE (MERV) RATING BASED ON EVALUATION IN ACCORDANCE WITH ASHRAE STANDARD 52.2-1999.
4. FILTER SIZE AND FILTER QUANTITIES FOR EACH PIECE OF EQUIPMENT SHALL BE DETERMINED BY EQUIPMENT MANUFACTURER.
5. CONTRACTOR SHALL PROVIDE FILTERS DURING CONSTRUCTION AND REPLACE WITH NEW CLEAN FILTERS IMMEDIATELY PRIOR TO OCCUPANCY BY OWNER.

RTAC BI-POLAR IONIZATION UNITS

TAG	ASSOCIATED EQUIPMENT	CFM	GLOBAL PLASMA MODEL #	NOTES:
BPI-1	RTAC-1	N/A	N/A	5
BPI-2	RTAC-2	1600	GPS-PC-3 BAS	1,2,3,4
BPI-3	RTAC-3	N/A	N/A	5
BPI-4	RTAC-4	N/A	N/A	5
BPI-5	RTAC-5	1150	GPS-PC-3 BAS	1,2,3,4
BPI-6	RTAC-6	1150	GPS-PC-3 BAS	1,2,3,4
BPI-7	RTAC-7	1995	(2) GPS-PC-3 BAS	1,2,3,4
BPI-8	RTAC-8	2560	(2) GPS-PC-3 BAS	1,2,3,4
BPI-9	RTAC-9	2560	(2) GPS-PC-3 BAS	1,2,3,4
BPI-10	RTAC-10	N/A	N/A	5

1. NEEDLE POINT TYPE IONIZER WITH ABS PLASTIC OR PONDER COATED STEEL HOUSING AND CARRIER FOR STAINLESS STEEL IONIZATION NEEDLES. SEE BIPOLAR IONIZATION CONTROL DETAIL.
2. PROVIDE (1) IONIZER PER UNIT.
3. PROVIDE FACTORY FURNISHED 24VAC INPUT TERMINALS FOR POWERING BIPOLAR UNIT FROM ASSOCIATED EQUIPMENTS 24V FAN TERMINAL.
4. UNIT SHALL BE FACTORY MOUNTED AND WIRED INSIDE AIR CONDITIONING EQUIPMENT.
5. NO IONIZER IS REQUIRED FOR MAINTENANCE/UNITS ONLY. NO BIPOLAR IONIZATION IS REQUIRED FOR THIS RTAC.
6. PROVIDE MULTIPLE BIPOLAR UNITS AS QUANTITIES INDICATED.

GRILLES

TAG	PRICE MODEL NUMBER	SIZE OR LENGTH	FINISH	THROW	NOTES:
A	SCD	6"Ø	WHITE	4-WAY	1,5,7,8
B	SCD	9"Ø	WHITE	4-WAY	1,5,7,8
C	SCD	10"Ø	WHITE	4-WAY	1,5,7,8
D	SDD	8 X 8	WHITE	----	3,6,7
F	ADD	14 X 14	WHITE	----	3,6,7
G	SMD	8 X 8	WHITE	1-WAY	2,6,7,8
H	STG1	12 X 12	WHITE	----	16
I	SDRD	24 X 8	WHITE	SIDEWALL	4,6,7,8
J	SDSD	14 X 14	WHITE	SIDEWALL	4,6,7,8
K	HCD	24 X 12	WHITE	SIDEWALL	6,7,11
L	90	16 X 16	WHITE	----	6,7,12
O	92 CORE	24 X 24	WHITE	----	3,13
P	TBD-3100	48", 2 SLOT, 4" INLET	WHITE	VERTICAL DOWN	7,14
Q	SMD	12 X 12, 12"Ø	WHITE	4-WAY	2,6,7,8
R	TBD-3100	48", 2 SLOT, 10" INLET	WHITE	VERTICAL DOWN	7,14

1. LOUVERED FACE SQUARE CONE STEEL CEILING SUPPLY DIFFUSER WITH FIXED AIR 360° RADIAL DISCHARGE PATTERN. PROVIDE FULL FACED LOUVERS. PROVIDE FACTORY INSULATED BACKPAN.
2. LOUVERED FACE HIGH CAPACITY STEEL CEILING SUPPLY DIFFUSER WITH FIXED AIR DISCHARGE PATTERN AS SCHEDULED.
3. ALL ALUMINUM 1" X 1" X 1" "EGG CRATE" EXHAUST/RETURN GRILLE.
4. PROVIDE OPPOSED BLADE DAMPER.
5. IN 24 X 24 PANEL FOR LAY-IN CEILING.
6. FLANGED FRAME FOR SURFACE MOUNTING.
7. NC LEVEL NOT TO EXCEED NC 30.
8. SEE CEILING SUPPLY DUCT CONNECTION DETAIL.
9. DOUBLE DEFLECTION STEEL SIDEWALL GRILLE WITH FRONT BARS HORIZONTAL (PARALLEL TO LONG DIMENSION). PROVIDE ½" BLADE SPACING. PROVIDE FRONT & REAR BLADE SETTINGS AS REQUIRED TO ACHIEVE PROPER AIR DISTRIBUTION.
10. STEEL SIGHT PROOF HORIZONTAL BLADE DOOR GRILLE WITH AUXILIARY FRAME ASSEMBLY (BOTH SIDES).
11. INDUSTRIAL DUTY EXTRUDED ALUMINUM SIDEWALL DRUM LOUVER WITH ADJUSTABLE DRUM AND BLADES. PROVIDE ADJUSTABLE AIRFOIL BLADES AND MIN. ¾" THICK FRAME.
12. HEAVY DUTY STEEL SIDEWALL GRILLE WITH HORIZONTAL BLADES AT 0° DEFLECTION. PROVIDE ½" BLADE SPACING AND WELDED CONSTRUCTION.
13. CORE ONLY PANEL IN AREAS WHERE CONDUIT, PIPING, DUCT, STRUCTURE, ETC. IS VISIBLE FROM 6' ABOVE FLOOR LEVEL. PROVIDE FLAT BLACK 26 GAUGE VISION SHIELD. SEE ELECTRICAL RETURN GRILLE VISION SHIELD DETAIL.
14. LINEAR SLOT DIFFUSER WITH 1" SLOT WIDTH AND EXTRUDED ALUMINUM EGGCRATE PATTERN CONTROLLER TO PROVIDE 180° CONTROL OF AIR PATTERN. SEE LAY-IN LINEAR DIFFUSER CEILING DETAIL. PROVIDE FACTORY FABRICATED DIFFUSER PLENUM WITH INTERNAL INSULATION. PROVIDE OPTIONAL CENTER NOTCH AT 1/2 LENGTH TO ALLOW 48" UNIT TO BE INSTALLED INTO TWO 24" CEILING MODULES. DIFFUSER IS DESIGNED FOR INSTALLATION IN T BAR LAY-IN CEILING.

ELECTRIC UNIT HEATERS

TAG	Q-MARK MODEL NUMBER	KW			MOTOR HP	THROW FEET	MOUNTING HEIGHT B.E. A.F.F.	NOTES:
EQH-1	MQH05		17,065		1/100	22	9'-0"	1,2,3,4,5

1. ELECTRIC PROPELLER TYPE UNIT HEATER WITH HORIZONTAL DISCHARGE.
2. PROVIDE ADJUSTABLE DISCHARGE LOUVERS.
3. OPERATE FROM 24V THERMOSTAT AS SHOWN ON DRAWINGS. PROVIDE LOCKING THERMOSTAT COVER.
4. PROVIDE MOUNTING BRACKETS AND ADJUSTABLE SWING BASE.
5. PROVIDE CONTROL POINT, DISCONNECT SWITCH, AUTOMATIC RESET THERMAL CUT-OUT AND FAN DELAY SWITCH.

FANS

TAG	GREENHECK MODEL NO.	CFM	FAN STATIC PRESSURE IN W.G.	FAN RPM	MOTOR HP	MAX SONES	NOTES:
E	G-180-E	1400	0.33	968	1/4	5.8	1,3,4,5
F	G-165-D	600	0.25	1316	1/6	6.5	1,3,4,5
G	BG-100-B	850	0.25	1520	1/6	4.7	2,3,4,5

1. CENTRIFUGAL CURB MOUNTED EXHAUST FAN. PROVIDE BIRDSCREEN, GRAVITY BACKDRAFT DAMPER, AND 14" TALL MINIMUM ROOF CURB. SEE CENTRIFUGAL ROOF EXHAUST FAN DETAIL.
2. CENTRIFUGAL IN-LINE FAN WITH DISCHARGE MOUNTED BACKDRAFT DAMPER. PROVIDE MOUNTING BRACKETS AND SUPPORT FROM VERTICAL DROP RODS (WITH VIBRATION ISOLATORS. SEE CENTRIFUGAL DIRECT DRIVE IN-LINE FAN DETAIL.
3. DIRECT DRIVE
4. PROVIDE FACTORY MOUNTED DISCONNECT SWITCH.
5. PROVIDE SPEED CONTROLLER.

LEGEND

A 500	GRILLE, REGISTER, DIFFUSER DESIGNATION ABOVE WITH CFM SHOWN BELOW FOR TAG AGENT TO BALANCE DEVICE AT
18 X 12	DUCT SIZE: FIRST DIMENSION IS SIDE SHOWN
	RIGID ROUND DUCTWORK OR FLUE PIPING
	FLEXIBLE ROUND DUCTWORK
	RECTANGULAR - TO - ROUND DUCT TRANSITION
	FLEXIBLE CONNECTION
	ACOUSTICAL/THERMAL DUCT LINER - 1" THICK OR 1" THICK, RESPECTIVELY
	SQUARE ELBOW WITH TURNING VANES
	45° BRANCH ENTRY FITTING
SD	SMOKE DAMPER, SEE SMOKE DAMPER DETAIL.
MVD MVD	MANUAL VOLUME DAMPER (OPPOSED BLADE)
AP	ACCESS PANEL IN SIDE OF DUCT
	DOOR GRILLE
	BELLMOUTH TAKE-OFF COLLAR AT RUN-OUT W/BALANCING DAMPER. SEE BELLMOUTH AND 45° FITTING TAKE-OFF DETAIL.
	45° FITTING TAKEOFF WITH BALANCING DAMPER. SEE BELLMOUTH AND 45° FITTING TAKEOFF DETAIL.
	SUPPLY DUCT TO OR FROM ABOVE
	RETURN OR EXHAUST DUCT TO OR FROM ABOVE
	INDICATES EQUIPMENT ON ROOF
	DUCT OR PIPE OFFSET. ARROW HEAD INDICATES DIRECTION OF FLOW
	RETURN OR EXHAUST AIR FLOW
SD 109	DUCTWORK SMOKE DAMPER. SEE SMOKE DAMPER DETAIL.
A	CONVENTIONAL SPACE THERMOSTAT (MOUNT AT 48")
T	WALL MOUNTED DIGITAL TEMPERATURE SENSOR
H	DDC HUMIDITY SENSOR
F	WALL MOUNTED FAN SWITCH (VARIABLE ELECTRONIC SPEED OR TYPE)
C	POWER CONTACTOR PROVIDED BY MECHANICAL
D	DUCT MOUNTED SMOKE DETECTOR (PROVIDED AND WIRED BY ELEC. AND INSTALLED BY MECH.)
	CONDENSATE DRAIN PIPING
DB	DRY BULB, WET BULB
	STAINLESS STEEL
	PER MINUTE
CFM	CUBIC FEET PER MINUTE
OA	OUTDOOR AIR
MBH	BTU/HR x 1000
APPROX.	APPROXIMATELY
ESP IN WG	EXTERNAL STATIC PRESSURE INCHES WATER GUAGE
HP	HORSEPOWER
RPM	REVOLUTIONS PER MINUTE
UNO	UNLESS NOTED OTHERWISE
AFF	ABOVE FINISHED FLOOR
UC	UNDERCUT DOOR ½"
KW	KILOWATTS
Δt	TEMPERATURE DIFFERENCE
B.E. T.E.	BOTTOM ELEVATION, TOP ELEVATION
LB/HR	POUNDS PER HOUR
	LIMIT OF SCOPE OF WORK
2 M1	SECTION OR DETAIL IDENTIFICATION NUMBER
	SHEET NUMBER ON WHICH SECTION OR DETAIL IS DRAWN

GENERAL NOTES

1. SEE ARCHITECTURAL AND STRUCTURAL DRAWINGS FOR EXACT BUILDING ARRANGEMENT, DIMENSIONS AND DETAILS. THESE DRAWINGS ARE DIAGRAMMATIC AND ARE NOT TO BE SCALED.
2. COORDINATE DUCT AND PIPE ROUTING AND EQUIPMENT LOCATION WITH PLUMBING AND ELECTRICAL INSTALLATIONS AND WITH BUILDING STRUCTURAL MEMBERS. OFF-SET DUCTS/PIPING AND SHIFT EQUIPMENT AS REQUIRED TO AVOID CONFLICTS WITH OTHER INSTALLATIONS.
3. COORDINATE LOCATION OF CEILING REGISTERS WITH LIGHTING LAYOUT, SPRINKLER HEADS AND CEILING GRID SYSTEMS AND APPURTENANCES. REFER TO ARCHITECTURAL REFLECTED CEILING PLANS FOR EXACT LOCATION.
4. DUCT SIZES INDICATED ON THE PLANS ARE CLEAR INSIDE DIMENSIONS REQUIRED. WHERE LINER IS INDICATED, INCREASE DUCT SIZE.
5. REFER TO THE ELECTRICAL DRAWINGS FOR VOLTAGE, PHASE, MAXIMUM ALLOWABLE CURRENT DRAW, AMPERAGE, AND CONNECTION ARRANGEMENT (SINGLE OR MULTI-POINT CONNECTION, ETC.) OF ALL MECHANICAL EQUIPMENT PRIOR TO ORDERING/INSTALLING EQUIPMENT.
6. SUPPORT ALL DUCTS, PIPING AND EQUIPMENT FROM PRIMARY BUILDING STRUCTURAL MEMBERS AND PROVIDE SUPPLEMENTAL STRUCTURAL FRAMING AS REQUIRED BETWEEN PRIMARY BUILDING STRUCTURAL MEMBERS TO SUPPORT ALL SYSTEMS INSIDE THE BUILDING.
7. MOST AREAS ABOVE CEILINGS ARE USED AS RETURN AIR PLENUMS. ALL MATERIAL IN PLENUM SPACE SHALL HAVE MAXIMUM FLAME SPREAD OF 25 AND MAXIMUM SMOKE DEVELOPMENT OF 50 BASED ON ASTM E84 TEST. RETURN AIR FROM SOME CONDITIONED SPACES IS TRANSFERRED TO ABOVE CEILINGS THRU SUPPLEMENTARY TRANSFER GRILLES WHERE INDICATED. AIR IS THEN TRANSFERRED THROUGH TRANSFER DUCTS, SMOKE DAMPERS, ETC.
8. PROVIDE STRUCTURAL FRAMING AROUND FULL PERIMETER OF ALL ROOF OPENINGS/EQUIPMENT. PROVIDE STRUCTURAL LINTELS ABOVE ALL WALL OPENINGS. SEE STRUCTURAL FOR LINTEL DETAILS OR REINFORCEMENT DETAILS.
9. INSTALL DUCT PENETRATIONS THROUGH NON-RATED WALLS AS SHOWN IN "DUCT PENETRATION THRU WALL DETAIL".

DUCTLESS CONDENSING UNITS

TAG	MITSUBISHI MODEL NUMBER	COOLING CAPACITY MBH RATED	COOLING CAPACITY MBH MIN.	HEATING CAPACITY MBH RATED	HEATING CAPACITY MBH MIN.	MINIMUM AMBIENT OPERATING TEMP °F	NOTES:
DCU-1	PUY-A12NHA3	12.0	6.5	---	---	23	1,2,3,4,5

1. COOLING CAPACITY BASED ON 95°F AMBIENT AIR TEMPERATURE AND MATCHED WITH INDICATED DUCTLESS FAN COIL UNIT.
2. PROVIDE REFRIGERANT PIPING SIZED AND DESIGNED IN ACCORDANCE WITH MANUFACTURERS INSTRUCTION.
3. SCHEDULED CAPACITIES ARE OVERALL CAPACITIES REQUIRED FOR MATCHED CONDENSING UNIT AND EVAPORATOR COIL 2 PIPE LOSS.
4. PROVIDE INTEGRAL CONTROLS INCLUDING CONTACTORS, CONTROL TRANSFORMER.
5. UNIT SHALL UTILIZE R-410A REFRIGERANT. PROVIDE DC ROTARY COMPRESSOR WITH VARIABLE SPEED INVERTER TECHNOLOGY TO MODULATE COOLING CAPACITY TO MATCH LOAD

DUCTLESS FAN COIL UNITS

TAG	MITSUBISHI MODEL NUMBER	TOTAL COOLING MBH RATED	TOTAL COOLING MBH MIN.	HEATING CAPACITY MBH RATED	HEATING CAPACITY MBH MIN.	TOTAL SUPPLY CFM	NOTES:
DFCU-1	PKA-A12NA	12.0	6.0	---	---	385	1,2

1. WALL MOUNTED STYLE DUCTLESS FAN COIL UNIT. PROVIDE ADJUSTABLE VANES, 3 SPEED FAN MOTOR, MICROPROCESSOR CONTROLLER, FILTER AND WALL MOUNTING BRACKET AND 12V DC WIRED REMOTE CONTROLLER.
2. COOLING CAPACITIES BASED ON AIR ENTERING EVAPORATOR AT 80°dB, 67°wb AND MATCHED WITH INDICATED CONDENSING UNIT. AIRFLOW LISTED IS IN COOLING MODE WITH WET COIL

Order Plans @ WWW.LDline.com

REVISIONS/ISSUANCES

NO.	DATE	DESCRIPTION

KEYPLAN



AH&P CONSULTING ENGINEERS
ANDREWS, HAMMOCK & POWELL, INC.
250 Charter Lane
Suite 100
MACON, GEORGIA 31210
MACON (478) 405-8301
FAX (478) 405-8310
WWW.AHPENGR.COM

GEORGIA REGISTERED ENGINEER No. 17016 EXPIRES: 12/31/2019

STATE OF GEORGIA R. VANCE SMITH, JR. REGISTERED ARCHITECT

Manley Spangler Smith Architects
A Professional Corporation
525 East Taylor St.
P.O. Box 880
Griffin, Georgia 30224
Office 770.227.5473
Fax 770.228.3442

PROJECT:
RENOVATIONS, MODIFICATIONS, & ADDITIONS TO HENRY COUNTY SCHOOLS - GROUP 10
WOODLAND HIGH SCHOOL (ITEM C)

CLIENT:
HENRY COUNTY BOARD OF EDUCATION

SHEET TITLE:
MECHANICAL LEGEND, SCHEDULES AND GENERAL NOTES

LU : 68
F.T.E. : 1,687
FACILITY CODE: 875-0456

© 2018 Manley Spangler Smith Architects, PC

PROJECT NUMBER:	20173C
DATE:	06.07.18
SCALE:	NONE
DRAWN BY:	WDC
CHECKED BY:	JDR

SHEET NO.:
M601