

NOTES: (THIS SHEET ONLY)

- ① GENERAL: ALL EMERGENCY ESCAPE LIGHT FIXTURES, ELOU NORMAL POWER SENSING CIRCUIT, AND EXIT SIGNS SHALL BE UNSWITCHED.
- ② GENERAL: CLASSROOM LIGHTS SHALL SWITCH FRONT TWO ROWS OF LIGHTS, CLOSEST TO MARKER BOARD AND INTERACTIVE PROJECTOR. ON ONE SWITCH AND BACK ROW OF LIGHTS ON OTHER FOR CLASSROOM AT INUSE LIGHTING. EXISTING LIGHTING FACTORS ARE AS SHOWN IN CLASSROOMS.
- ③ INTERCEPT EXISTING LIGHTING CIRCUITS IN ABOVE CEILING LIGHTING JUNCTION BOXES TO PROVIDE ROOF SWITCHING AS NOTED. UTILIZE 2P/1, 1P/3, 1P/2 TO EXTEND AND MAKE CONNECTION TO EXISTING 277V LIGHTING CIRCUIT.
- ④ PROVIDE NEW SWITCHES IN EXISTING RECESSED SWITCH LOCATIONS. CUT, PATCH AND PAINT WALLS TO INSTALL NEW MULTI-WAY SWITCH BOX FOR ADDITIONAL SWITCH IN EXISTING WALLS. UTILIZE EXISTING IN-WALL RACEWAY SYSTEM TO ROUTE NEW CONDUCTORS FOR ROW SWITCHING.
- ⑤ PROVIDE NEW LIGHT SWITCH CONDUCTOR IN EXISTING 1/2" RACEWAY FOR ROW SWITCHING AS NOTED. THE NEW CONDUCTOR SHALL BE BUNDLED WITH THE EXISTING CONDUCTORS TO REMAIN IN PLACE. PROTECT EXISTING CONDUCTORS DURING INSTALLATION.
- ⑥ PROVIDE LINE VOLTAGE OCCUPANCY SENSOR AS SHOWN. INTERCEPT EXISTING CIRCUIT UTILIZING #12, #10, 1/2" MAKE ALL CONNECTIONS.

MATCH LINE - SEE SECTOR "E"
MATCHLINE - SEE SECTOR "E"

MATCH LINE - SEE SECTOR "E"
MATCHLINE - SEE SECTOR "E"

NOTICE TO CONTRACTOR CONCERNING PROJECT PHASING:
THE WORK DESCRIBED ON THIS DRAWING AND SPECIFICATIONS ILLUSTRATES THE CONCEPT CONTRACTOR SHALL PROVIDE. THIS PROJECT IS PHASED IN MULTIPLE PHASES. THE AREA OF EACH PHASE IS DESCRIBED IN THE ARCHITECTURAL DOCUMENTS AND THE CONTRACTOR SHALL REVIEW THESE PHASING REQUIREMENTS. CONTRACTOR SHALL INCLUDE IN THE ALL COSTS NECESSARY TO ACCOMPLISH THE CONTRACT IN PHASES. THE CONTRACTOR SHALL NOT DESCRIBE THE PROJECT WORK REQUIRED BY THE CONTRACTOR TO PREPARE FOR PHASING IN PHASES. THE CONTRACTOR SHALL PREPARE PHASING PLAN AND SUBMIT TO ARCHITECT/ENGINEER AND HENRY COUNTY MAINTENANCE DEPARTMENT PRIOR TO BEGINNING WORK.

GENERAL LIGHTING NOTE
UNDER THIS PROJECT OCCUPANCY SENSORS SHALL BE INSTALLED. EXISTING 277V LIGHTING CIRCUITS WITHIN BUILDING SHALL BE UTILIZED TO POWER EXISTING LIGHTING. SOME AREAS REQUIRE REWORK OF LIGHTING CIRCUIT WITHIN SPACES WHILE OTHERS MAY CONNECT DIRECTLY TO EXISTING SWITCHED CIRCUITS. EXISTING CONDUIT AND WIRING MAY BE UTILIZED WHERE IT MEETS THIS SPECIFICATION.

ELECTRICAL NEW WORK LIGHTING PLAN - SECTOR "E"
SCALE: 1/8"=1'-0"

REVISIONS/ISSUANCES		
NO.	DATE	DESCRIPTION

KEYPLAN

AH&P
CONSULTING ENGINEERS
ANDREWS, HARRISON & POWELL, INC.
250 Charter Lane
Suite 150
Macon, Georgia 31210
Macon (478) 405-8301
Fax (478) 405-8210
WWW.AHPENG.COM

STATE OF GEORGIA
REGISTERED ARCHITECT

Manley Spangler Smith Architects
A Professional Corporation

525 East Taylor St.
P.O. Box 650
Gills, Georgia 30224
Office 770.227.6473
Fax 770.226.3442

PROJECT: RENOVATIONS, MODIFICATIONS, & ADDITIONS TO HENRY COUNTY SCHOOLS - GROUP 10 WOODLAND HIGH SCHOOL (ITEM C)

CLIENT: HENRY COUNTY BOARD OF EDUCATION

SHEET TITLE: ELECTRICAL NEW WORK LIGHTING PLAN - SECTOR "E"

LU: 88
P.T.E.: 1,687
FACILITY CODE: 875-0408
© 2018 Manley Spangler Smith Architects, P.C.
PROJECT NUMBER: 201731C
DATE: 08.07.18
SCALE: 1/8"=1'-0"
DRAWN BY: JAB
CHECKED BY: NHO

SHEET NO.: E108