



PART PLAN - BUNKER ATTIC

## **GENERAL NOTES:**

 DO NOT ROUTE WIRING OR CONDUITS IN FRONT OF GRATES/LOUVERS WITHIN REMOTE BUNKER. VERIFY MOUNTING LOCATIONS OF EQUIPMENT BASED ON GRATE/LOUVER LOCATIONS. SEE ARCHITECTURAL PLANS.

## LEGEND NOTES:

LEGEIND NOTES.

1 SOKW 72 HOUR DIESEL GENERATOR. KOHLER MODEL 150REOZJF WITH ASSOCIATED 72H DIESEL TANK, NEMA 3R ENCLOSURE. ENCLOSURE MOUNTED 550 CONTROLLER. 400A ENCLOSURE MOUNTED MAIN BREAKER, AND CRITICAL SILENCER. GENERATOR TO BE ORIENTED AS SHOWN TO MINIMIZE LENGTH OF CONDUIT RUNS TO CONDUIT ENTRANCE SIDE. ENSURE NO OBSTRUCTIONS ARE ABOVE EXHAUST OUTLET SIDE. CONTRACTOR TO VERIFY ALL INSTALLATION REQUIREMENTS WITH MANUFACTURER CONTRACTOR SHALL ALSO SUBMIT ALTERNATE COST FOR DUAL FUEL DIESEL/NATURAL GAS GENERATOR DURING BID. INCLUDE COST O NATURAL GAS PIPING AND REQUILATOR TO THE GENERATOR IN ALTERNATE PRICE COORDINATE PRICING WITH GC AND PLUMBING CONTRACTOR AS NEEDED.



FANNIN COUNTY: 722 Black Dog Trail P.O. Box 639 Blue Ridge, GA 30513 Phone 706.374.4304

COBB COUNTY: 1480 Shiloh Road NW Suite #300 Kennesaw, GA 30144 Phone 770.790.3655 Fax 770.790.3650



FANNIN CO. PUBLIC SAFETY COMPLEX 964 WINDY RIDGE ROAD BLUE RIDGE, GA 30513

PART PLANS - ELECTRICAL

ISSUE: REVISIONS:

SEAL



DRAWN BY/ DATE: CHECKED BY: IJC/SWL 4.19.2017 SHEET NO.: PROJECT NO. 1517 E-2.1

> Copyright © 2016 R Design Works