HVAC ELECTRICAL COORDINATION SCHEDULE

ABBREVIATIONS	
DC	LOCAL DISCONNECT
MC	MOTOR CONTROL (POWER)
SD	DUCT SMOKE DETECTOR
CN	CONTROLS
TS	TOGGLE SWITCH
CB	CIRCUIT BREAKER AT SOURCE PANELBOARD
FUSE	FUSE AT LOCAL DISCONNECT (VERIFY FIELD RATING)
FLA	OPERATING FULL LOAD AMPS
MCA	MINIMUM CIRCUIT AMPACITY
CP	CORD AND PLUG CONNECTION

CONTRACTOR TYPE	
EC	ELECTRICAL CONTRACTOR
EX	EXISTING
FC	FIRE PROTECTION CONTRACTOR
GC	GENERAL CONTRACTOR
HC	HVAC CONTRACTOR
NIC	NOT IN CONTRACT
PC	PLUMBING CONTRACTOR
OR	OWNER OR OTHERS

MOTOR CONTROL TYPE	
CS	COMBINATION STARTER
MSC	MOTOR CONTROL STARTER
MS	MAGNETIC STARTER OR CONTACT
MS	MANUAL STARTER
VFD	VARIABLE FREQUENCY DRIVE
MSR	MANUAL STARTER W/ CONTROL RELAY
OV	OVERCURRENT PROTECTION

CONTROL TYPE	
TC	TIMECLOCK
CPT	CONTROL POWER TRANSFORMER
BAS	BUILDING AUTOMATION SYSTEM
LOW	LOW VOLTAGE CONTROLS
LINE	LINE VOLTAGE CONTROLS
LLC	LOW VOLTAGE ACTING LINE VOLTAGE THERMOSTAT
MAN	MANUAL
FA	FIRE ALARM
CO	CARBON MONOXIDE SENSOR
INT	INTEGRAL TO EQUIPMENT

EQUIPMENT MARK	DESCRIPTION	VOLTS (V)	PHASE	EMERGENCY	BHP (HP)	HP (HP)	HTG (kW)	WATTS	FLA (A)	MCA (A)	OCP (A)	DC TYPE	DC FURN	DC INST	DC WIRE	MC TYPE	MC FURN	MC INST	MC WIRE	CN TYPE	CN FURN	CN INST	CN WIRE	SD TYPE
AC-ECR	DUCTLESS SPLIT HIGH WALL UNIT	208	1										ECC	ECC	EC	NG	MFR	MFR	MFR	LOW	MFR	MFR	MFR	
CU-ECR	DUCTLESS SPLIT OUTDOOR CONDENSING UNIT	208	1							25	40		ECC	ECC	EC	NG	MFR	MFR	MFR	LOW	MFR	MFR	MFR	

Kroger Data Device Seudle		
Family and Type	Type Comments	Keynote
Structured Cabling Kroger: ACLNC-T	2 DATA JACKS	T3
Structured Cabling Kroger: ACRLC-T	2 DATA JACKS	T4
Structured Cabling Kroger: AUAS	3 DATA, 1 VOICE JACK	T5
Structured Cabling Kroger: D23T	1 DATA JACK	T3
Structured Cabling Kroger: E38AS	3 DATA, 1 VOICE JACK	T5
Structured Cabling Kroger: E102	1 DATA JACK	T1
Structured Cabling Kroger: GE2		T3
Structured Cabling Kroger: GE38	3 DATA, 1 VOICE JACK	T3
Structured Cabling Kroger: GE38S	3 DATA, 1 VOICE JACK	T5
Structured Cabling Kroger: GE67		T3
Structured Cabling Kroger: GE107		
Structured Cabling Kroger: GE121		T3
Structured Cabling Kroger: GE156	DATA JACK	T4
Structured Cabling Kroger: M117	1 DATA JACK	T3
Structured Cabling Kroger: S2NT		
Structured Cabling Wall Data		
TV: D29ETV-48		
TV: E22TV-47		

Electric Fixture Schedule1

Fixture ID	Type Comments
A21	120V 1PH 20A, QUAD OUTLET WITH USB PORTS FOR CELL PHONE CHARGING STATION
ACLNC-T	120V, 1PH, 720W DEDICATED CIRCUIT W/ ISOLATED GROUND RECEPTACLE FOR USCAN CHECKOUT LANE. ADDITIONAL QUAD OUTLET (90W TOTAL) ON A SEPARATE CIRCUIT FOR EAS DEACTIVATOR
ACRLC-T	120V, 1PH, 720W DEDICATED CIRCUIT W/ ISOLATED GROUND RECEPTACLE FOR USCAN CHECKOUT LANE. ADDITIONAL QUAD OUTLET (90W TOTAL) ON A SEPARATE CIRCUIT FOR EAS DEACTIVATOR
ALSK	120V, 7.5AMP, 1PH, FOR DUPLEX OUTLET IN SBG LOW BOY KIOSK
ALSS955-FS	500W FOR REGISTER (DEDICATED CIRCUIT) AND 204W FOR BELT ON ENTERPRISE STANDARD CHECKSTAND (95" FM, 65" RM)
AUK	120V, 4.5AMP, 1PH, FOR DUPLEX OUTLET IN SBG SLIMKIOSK
AUAS	120V, 10A MIN. DEDICATED CIRCUIT FOR ENTERPRISE SELF-CHECKOUT ATTENDANT STATION
B55C	120V, 840W, 1PH FOR VARIETY BREAD SLICER
B55SS-2	120V, 720W, 1PH, FOR SELF SERVICE BREAD SLICER
B99CDS	1027W FOR CAKE IMAGING MACHINE
B100	
BQDNC6HI	130W FOR FANS, 180W FOR A.S. HTRS., 43W FOR LIGHTS, 1403W (208V 1PH) FOR ELEC DEF. (TO PANEL FOR DEF WIRING) ON 6' NARROW GLASS DOOR ICE CREAM TEMP GROCERY CASE
BQDNC8HI	195W FOR FANS, 273W FOR A.S. HTRS., 65W FOR LIGHTS, 2103W (208V 1PH) FOR ELEC DEF. (TO PANEL FOR DEF WIRING) ON 8' NARROW GLASS DOOR ICE CREAM TEMP GROCERY CASE
BQDNC12HI	29W FOR FANS, 117W FOR LIGHTS ON 6' MOLP BAKERY CASE
BMDL6HP	72W FOR FANS, 117W FOR LIGHTS ON 6' MOLP BAKERY CASE
BRICS	
C39M-4S	120V, 5.1W, FOR 4 FT COSMETIC LIGHT VALANCE (STARTER)
D12SC2HP-2	120V, 15AMP, 1PH FOR 2 'S INGLE DECK MOBILE DELI CASE (SELF-CONTAINED)
D23T	120V 1PH .75AMPS FOR SERVICE SCALE/UPC PRINTER (TOLEDO), PROVIDE A 3/4" COND. TO ECR ROOM
D29S	300W, 120V, 1PH, FOR DELI AUTOMATIC SLICER STACKER
D35	504W 4'-0" AB FL FOR MANUAL SLICER
D36	120V 1PH 13.0A CKT, 1750W 3'-5" AB FL FOR MICROWAVE OVEN
D40A	
D41	SEE KROGER A&E STANDARDS FOR WHERE PLUGMOLD IS REQUIRED
D4X0E	TWO 208V, 48AMP, 3PH CIRCUITS REQUIRED FOR OPEN DUAL RACK FRYER, MOUNT J.B. 2'-0" AB. FL., TWO SHUNT TRIP CIRCUIT BREAKERS REQUIRED
D7RI	1150W FOR RICE COOKER
D137	PROVIDE POWER FOR TABLE TOP EQUIPMENT AS SHOWN ON LEGEND & 600W. CONVENIENCE OUTLETS, 4'-0" AB FL. AS REQUIRED BY CODE
D174SC8	* 115V 10 AMPS FOR S.C. PIZZA MAKE-UP TABLE. MOUNT RCPT. 2'-0" AB. FL. (REQD. LOCKED ON DEVICE @ PANEL)
D195-2	120V, 13.0AMP, 1PH FOR UNDER COUNTER HOT HOLDING CABINET
D195-3	208V, 13.8AMP, 1PH FOR PASS THRU HOT HOLDING CABINET
D203SC3	120V, 8.4 AMP, 1PH FOR 3 DOOR DELI STORAGE REFRIGERATOR (SELF CONTAINED) EQUIPPED WITH 5-15P PLUG
D204SC3	120V, 15.8 AMP, 1PH FOR 3 DOOR DELI STORAGE FREEZER (SELF CONTAINED) EQUIPPED WITH 5-15P PLUG
D270SC1-2	120V, 240W, 1PH, FOR UNDERCOUNTER REFRIGERATOR
D299TV-48	120V, 180W, 1PH, FOR 48" DIGITAL MONITOR FOR DELI MENU BOARD
D335R-2	350W, 208V, 1PH, FOR PREWIRED ELECTRICAL LOAD PANEL FOR 18 SALAD BAR WI[illegible] (REMOTE)
DGDN4HE	120V, 60W FOR FANS, 35W FOR LIGHTS ON 4'T NARROW GLASS DOOR DE[illegible]SE. MOUNT J.B. 1'-9" AB FL.
DHFMDH	208V, 1740W, 1PH FOR 4' SELF SERVICE MULTI DECK HOT CASE
DMDLR4HC	120V, 19W, FOR FANS, 3 W, FOR LED LIGHTS FOR 4' FRESH SLICED MULTI DECK CASE (REMOTE)
DMDLR6HC	120V, 24W, FOR FANS, 31W, FOR LED LIGHTS FOR 6' FRESH SLICED MULTI DECK CASE (REMOTE)
DMDLR8HC	120V, 32W, FOR FANS, 41W FOR LED LIGHTS FOR 8' FRESH SLICED MULTI DECK CASE (REMOTE)
DMSC4SS	
DMSC6SS	
DR1028C	
E-8	960W FOR MEDIUM VOLUME COPIER SCANNER COMBO FOR INTEGRATED PRINTER HIGH VOLUME
E12C	960W FOR LASER PRINTER (GENERAL USE)
E27TV-47	300W FOR LCD WIDESCREEN TV (47")
E38AG	120V 500W DEDICATED CIRCUIT FOR POS EQUIPMENT FOR SCO ATTENDANT STATION
E38PS	120V, 1PH
E38TP	120V, 1PH, THERMAL PRINTER
E38TS	18W FOR TOUCH SCREEN POS SYSTEM (CM MOUNT)
E39	120V, 100W FOR RECEIPT PRINTER
E40	60W FOR THIN CLIENT MONITOR
ENDN6	75W FOR FANS, 35W FOR LIGHTS ON 6' NARROW FLORAL CASE
ES955	348W FOR CHECK SCANNER/REFRIGERATED SCANNER
G101	150W FOR NCMC VENDING AREA. PROVIDE OUTLET ON SEPARATE CIRCUIT AT BASE OF ADJACENT CASE, FIXTURE, OR COLUMN.
GE1	115V/60HZ 60W 7'-0" AFF FOR RECEPTICAL. MOUNT SWITCH 5'-0" AB FL. MOUNT (BOTTOM OF FLYZAPPER 4'-0" AFF.
GE1H	115V 30W, 1PH, FOR FLY ZAPPER AREA FLY ZAPPER (MOUNT @ 6'-0" AFF TO BOTTOM)
GE2	115V 15A CKT FOR LOTTERY MACHINE
GE7	180W 1'-0" AB FL FOR DESK
GE38	120V 500W FOR REGISTER (DEDICATED CKT)
GE38S	120V, 1PH (DEDICATED CKT) FOR POS TERMINAL. WIRED TO KROGER SUB PANEL (NOT STARBUCKS PANEL)
GE41	SEE KROGER A&E STANDARDS FOR WHERE PLUGMOLD IS REQUIRED
GE67	120V 75W 4'-0" ABOVE FLOOR FOR MONEY ORDER MACHINE
GE102C	120, 12W, FOR CHECK SCANNER, 120V, 83W, FOR MONITOR AND TINY PC, 120V, 168W, FOR PRINTER
GE107	48W 4'-0" AB FL FOR BIOMETRIC READER FOR T&A (REQ'D. LOCKED ON DEVICE @ PANEL)
GE121	120V 5.5A DEDICATED CKT PLUS A PHONE MODEM FOR WESTERN UNION TERM.
GE156	*160W 1'-0" AB FL FOR VENDING MACHINE (REQ'D. LOCKED ON DEVICE @ PANEL)
GE158	120V 250W ELEC FED FROM RACEWAY FOR EFT PIN PAD & CREDIT CARD READER
GE186	120V 1PH 14AMPS FOR MICROWAVE MOUNT RCPT 4'-0" AB FL
GE-R62	120V 800W 2'-0" AB FL FOR REFRIG (REQ'D. LOCKED ON DEVICE @ PANEL)
GDDLT6HI	ELECTRICAL DATA IS PER SIDE. TWO CIRCUITS REQUIRED PER CASE: 195W FOR FANS, 273W FOR A.S. HEATERS, 40W FOR LIGHTS, 1403W (208V 1PH) FOR ELETRIC DEF. (TO PANEL FOR DEF WIRING) ON 6' GLASS DOOR GROCERY CASE
GDDLT8HI	ELECTRICAL DATA IS PER SIDE. TWO CIRCUITS REQUIRED PER CASE: 180W FOR FANS, 415W FOR A.S. HEATERS, 60W FOR LIGHTS, 2103W (208V 1PH) FOR ELETRIC DEF. (TO PANEL FOR DEF WIRING) ON 8' GLASS DOOR GROCERY CASE
GDDLT12HI	ELECTRICAL DATA IS PER SIDE. TWO CIRCUITS REQUIRED PER CASE: 300W FOR FANS, 766W FOR A.S. HEATERS, 100W FOR LIGHTS, 3503W (208V 1PH) FOR ELETRIC DEF. (TO PANEL FOR DEF WIRING) ON 12' GLASS DOOR GROCERY CASE
GDDITT8HI	ELECTRICAL DATA IS PER SIDE. TWO CIRCUITS REQUIRED PER CASE: 195W FOR FANS, 273W FOR A.S. HEATERS, 65W FOR LIGHTS, 2103W (208V 1PH) FOR ELETRIC DEF. (TO PANEL FOR DEF WIRING) ON 8' GLASS DOOR GROCERY CASE
GDDITT12HI	ELECTRICAL DATA IS PER SIDE. TWO CIRCUITS REQUIRED PER CASE: 325W FOR FANS, 455W FOR A.S. HEATERS, 108W FOR LIGHTS, 3503W (208V 1PH) FOR ELETRIC DEF. (TO PANEL FOR DEF WIRING) ON 12' GLASS DOOR GROCERY CASE
GDDNC6PHI	130W FOR FANS, 180W FOR A.S. HTRS., 43W FOR LIGHTS, 1403W (208V 1PH) FOR ELEC DEF. (TO PANEL FOR DEF WIRING) ON 6' NARROW GLASS DOOR ICE CREAM TEMP GROCERY CASE
GDDNC10HI	260W FOR FANS, 364W FOR A.S. HTRS, 86W FOR LIGHTS, 2803W (208V 1PH) FOR ELEC DEF. (TO PANEL FOR DEF WIRING) ON 10' NARROW GLASS DOOR LOW-TEMP GROCERY CASE
GDDNC12HI	325W FOR FANS, 455W FOR A.S. HTRS, 108W FOR LIGHTS, 3503W (208V 1PH) FOR ELEC DEF. (TO PANEL FOR DEF WIRING) ON 12' NARROW GLASS DOOR ICE CREAM TEMP GROCERY CASE
GDDNLT8HI	195W FOR FANS, 273W FOR A.S. HTRS., 65W FOR LIGHTS, 2103W (208V 1PH) FOR ELEC DEF. (TO PANEL FOR DEF WIRING) ON 8' NARROW GLASS DOOR LOW-TEMP GROCERY CASE
GDDNLT12HI	325W FOR FANS, 455W FOR A.S. HTRS, 108W FOR LIGHTS, 3503W (208V 1PH) FOR ELEC DEF. (TO PANEL FOR DEF WIRING) ON 12' NARROW GLASS DOOR LOW-TEMP GROCERY CASE
GM17S-4	120V, 411.5W, FOR 4 FT KPNR LIGHTED SHELVING SECTION
GMSC4K	
MDDFRH-K	100W FOR FANS, 304W FOR LIGHTS ON 8' FIVE DK FRESH MEAT CASE. MOUNT J.B. 1'-0" AB FL
MDDFRNSHK	100W FOR FANS, 304W FOR LIGHTS ON 8' FIVE DK FRESH MEAT CASE. MOUNT J.B. 1'-0" AB FL
MDDFRN12HK	150W FOR FANS, 510W FOR LIGHTS ON 12' FIVE DK FRESH MEAT CASE. MOUNT J.B. 1'-0" AB FL
M10	208V 3PH (HP 5.0AMPS (30AMPS OCP) FOR MEAT SAW (SEE ESD-1/6)
M117	120V 1PH .75AMPS FOR SERVICE SCALE/UPC PRINTER (TOLEDO), MOUNT RCPT 4'-0" AB FL. PROVIDE A 3/4" CONDUIT TO ECR ROOM
M32	120V 1PH 6.5AMP 2'-5" AB FL FOR MANUAL CARRAGE MEAT SLICER
MAPPM	120V, 60W, 1PH, FOR LG MONITOR
MDDH2HE	120V, 132W FOR FANS, 95W FOR LIGHTS ON 12FT GLASS DOOR MEAT CASE. MOUNT J.B. 1'-9" AB FL
MS12HC-2	120V, 4.7W FOR AIRSWEEP FANS, 93W FOR LED LIGHTS, 180W FOR CONVENIENCE OUTLET, FOR 12' SERVICE MEAT CASE
N19P	120V 20A DEDICATED CIRCUIT FOR PEANUT BUTTER GRINDER
P21E	200W (NON-CONTINUOUS) 20A DEDICATED CIRCUIT FOR ENERGY EFFICIENT 3-ROLL WRAPPER (NO WINGS). MOUNT RCPT. 2'-0" AB. FL.
P31T	120V 1PH .75AMPS FOR SERVICE SCALE/UPC PRINTER (TOLEDO), MOUNT RCPT 4'-0" AB FL. PROVIDE A 3/4" CONDUIT TO ECR ROOM
S2NT	120V 1PH .75AMPS FOR SERVICE SCALE/UPC PRINTER (TOLEDO). PROVIDE A 3/4" CONDUIT TO ECR ROOM
SS12HC-DSFM	100W FOR FANS, 304W FOR LIGHTS ON 8' FIVE DECK FRESH SEAFOOD CASE (NO GLASS). MOUNT J.B. 1'-9" AB FL
SS12HE	
SWHL12H	120V, .49AMP 1PH FOR 12' WIDE ISLAND SEAFOOD HALF LIDS WITH LED LIGHTS
T3D	PROVIDE POWER FOR TABLE TOP EQUIPMENT AS SHOWN ON LEGEND & 600W. CONVENIENCE OUTLETS, 4'-0" AB FL. AS REQUIRED BY CODE
T4S	PROVIDE POWER FOR TABLE TOP EQUIPMENT AS SHOWN ON LEGEND & 600W. CONVENIENCE OUTLETS, 4'-0" AB FL. AS REQUIRED BY CODE
T6D	PROVIDE POWER FOR TABLE TOP EQUIPMENT AS SHOWN ON LEGEND & 600W. CONVENIENCE OUTLETS, 4'-0" AB FL. AS REQUIRED BY CODE
T6S	PROVIDE POWER FOR TABLE TOP EQUIPMENT AS SHOWN ON LEGEND & 600W. CONVENIENCE OUTLETS, 4'-0" AB FL. AS REQUIRED BY CODE
T6SC	1200W FOR 6' TABLE W/REF BASE (SELF- CONT.)
T8D	PROVIDE POWER FOR TABLE TOP EQUIPMENT AS SHOWN ON LEGEND & 600W. CONVENIENCE OUTLETS, 4'-0" AB FL. AS REQUIRED BY CODE
T8SC	115V 13AMP FOR 8' SELF-CONTAINED TABLE W/REFRIG. BASE
TMP-215	120V, 180W, 1PH, FOR LED LIGHTS ON MID-HEIGHT ARTISAN BREAD DISPLAY
TMP-217	120V, 180W, 1PH, FOR LED LIGHTS ON MID-HEIGHT BAGUETTE DISPLAY
TMP-218	120V, 180W, 1PH, FOR LED LIGHTS ON MID-HEIGHT BAGEL/PRETZEL DISPLAY
TMP-219	120V, 180W, 1PH, FOR LED LIGHTS ON MID-HEIGHT DONUT DISPLAY

OWNERSHIP OF INSTRUMENTS OF SERVICE
All reports, plans, specifications, computer files, field data, notes and other documents and instruments prepared by the Consultant as instruments of service shall remain the property of the Consultant. The Consultant shall retain all common law, statutory and other reserved rights, including, without limitation, the copyright thereto.

Order Plans @ www.LHline.com

STUDIO A architecture
1975 RAILROAD TOWN PKWY.
LOUISVILLE, KENTUCKY 40214
(502) 384-6169 FAX 384-6180
WWW.STUDIOA.COM

CONSULTANTS

MECHANICAL/ELECTRICAL ENGINEERS
WWW.KLHENGRS.COM
KLH ENGINEERS
LEXINGTON, KENTUCKY
1508 ALEXANDRIA PIKE, SUITE 11
859-254-6169 859-442-8200
COLUMBUS, OHIO
614-754-9278 614-754-9279
NOVI, MICHIGAN

KROGER L758

234 EASTBROOKE PKWY,
MT WASHINGTON, KY

CLIENT

KROGER COMPANY
1600 Ormsby Station Court
Louisville, Kentucky 40223

ELECTRICAL EQUIPMENT SCHEDULES

No.	Description	Date

BID ISSUE

© 2015 STUDIO A ARCHITECTURE
THESE DRAWINGS ARE COPYRIGHTED BY STUDIO A. USE OF THIS WORK IN WHOLE OR IN PART WITHOUT WRITTEN PERMISSION IS PROHIBITED. WRITTEN DIMENSIONS AT VAULT TO BE FOLLOWED.

E6.1

Project number 20168
Date 08/17/2018

5" REFERENCE LINE

JAD JAT