



1 LIGHTING PLAN  
A111 SCALE: 1/4" = 1'-0"

GENERAL NOTES:

- A. REFER TO SHEET G100 FOR RESPONSIBILITIES.
- B. DO NOT SCALE DRAWINGS.
- C. REFER TO ELECTRICAL PLANS FOR ADDITIONAL INFORMATION AND REQUIREMENTS.
- D. LIGHT FIXTURES, AND LAMPS FURNISHED BY TENANT'S VENDOR AND INSTALLED BY G.C.
- E. NO JUNCTION BOXES TO BE INSTALLED BELOW THE CEILING HEIGHT.
- F. THE EMERGENCY LIGHTS WILL PROVIDE AN AVERAGE OF ONE (1) FOOTCANDLE ALONG THE ENTIRE MEANS OF EGRESS PER NFPA 101, 7.9.
- G. REFER TO SHEET A110 FOR REFLECTED CEILING PLAN NOTES AND REFER TO SHEET A112 FOR DETAILS.
- H. DIMENSIONS ARE TO THE CENTERLINE OF OBJECTS, UNLESS NOTED OTHERWISE.
- I. ALL SPRINKLER HEADS IN STOCK ROOM TO BE 18" ABOVE THE HIGHEST STOCK SHELF (MINIMUM).

KEY NOTES:

- 1. CENTER LIGHT FIXTURE WITHIN ROOM.
- 2. CEILING MOUNTED EMERGENCY SIGNAGE CENTER ON EXIT DOOR BEYOND.

These drawings are instruments of the Architect's service and are the property of LGA Partners LP. They shall not be reproduced or used in any way, whatsoever, without the written permission of LGA Partners LP. © 2018

Order Plans

LIGHT FIXTURE SCHEDULE									
SYMBOL	TYPE	MANUFACTURER	PRODUCT NUMBER	FINISH	DESCRIPTION	LAMPING	MTG METHOD	MTG HT	COMMENTS
	A	AMERLUX	C3MR/SR-FRAME-2-LED-120-0-10V C3MR-TRIM-2-21-LED-WT-120-277 -NF-NF-WT-3CLA-SN-0-10V	WHITE	RECESSED ACCENT DISPLAY LIGHT	LED	RECESSED IN CEILING	CEILING HEIGHT	TRIM: 6" x 10-3/4"
	A1	AMERLUX	C3MR/SR-FRAME-2-LED-120-0-10V C3MR-TRIM-2-21-LED-WT-120-277 -NF-NF-WT-3CLA-SN-0-10V-LS-LS	WHITE	RECESSED ACCENT DISPLAY LIGHT WITH LINEAR SPREAD LENS	LED	RECESSED IN CEILING	CEILING HEIGHT	TRIM: 6" x 10-3/4"
	C1	PINNACLE	LF44-A-CL835LO-SF-U-OL2.1-0-W	WHITE	RECESSED ACCENT DISPLAY LIGHT	LED	RECESSED	CEILING HEIGHT	PER MANUFACTURER'S REQUEST. ATTACH (4) 10 GAUGE STEEL BRACING WIRES - (1) AT EACH CORNER OF LIGHT FIXTURE. WIRES SHALL BE ATTACHED TO STRUCTURAL FRAMING ABOVE.
	C2	PINNACLE	LF48A-935LO-FL-U-OL1.1-0-W	WHITE	RECESSED ACCENT DISPLAY LIGHT	LED	RECESSED	CEILING HEIGHT	CUSTOM 4'x8' LIGHT FIXTURE; PER MANUFACTURER'S REQUEST. ATTACH (4) 10 GAUGE STEEL BRACING WIRES - (1) AT EACH CORNER OF LIGHT FIXTURE. WIRES SHALL BE ATTACHED TO STRUCTURAL FRAMING ABOVE.
	J	MERCURY LIGHTING	LR15-22G-2300-35K-UNI	WHITE	RECESSED 2x2 LIGHT	LED	RECESSED IN CEILING	CEILING HEIGHT	
	K	MERCURY LIGHTING	LW3-4-3800-35K-HTA-UNI	WHITE	1x4 STRIP LIGHT	LED	SUSPENDED / SURFACE	10'-0" TO BOTTOM OF FIXTURE / CEILING HGT.	CEILING MOUNTED WHERE CEILING EXISTS
	P	AMERLUX	EDR-1729-MCAV-FRAME-A17-42-120-0-10V EDR-1729-MCAV-A17-WT-WW-3CLA-0-10V	WHITE	RECESSED ADJUSTABLE WALL WASH	LED	RECESSED	CEILING HEIGHT	TRIM: 6" x 10-3/4". G.C. TO ADJUST WALL WASHERS TO AIM LIGHT ABOVE PERIMETER MILLWORK FIXTURES. COORDINATE WITH CONSTRUCTION PROJECT MANAGER ON SITE.
	Y	CONTECH LIGHTING	EL2HALEDEM-P	INCANDESCENT	EMERGENCY LIGHT	LED	WALL MOUNTED, UNO	10'-0" AFF / CEILING HEIGHT	WITH 90 MINUTES EM. BATTERY BACK UP.
	Y1	CONTECH LIGHTING	APL-LC-UI	(2) 25 WATTS SUPERFLUX	RECESSED EMERGENCY LIGHT	LED	RECESSED IN CEILING	ABOVE CEILING	WITH 90 MINUTES EM. BATTERY BACK UP.
	X	CONTECH LIGHTING	REXA-MF-R-EM	LED	EDGE LIT ACRYLIC EXIT SIGN	LED	WALL MOUNTED, UNO	6" CENTERED ABOVE DOOR FRAME	WITH 90 MINUTES EM. BATTERY BACK UP.
	X1	CONTECH LIGHTING	EX2HRLDEM-P	LED	EXIT SIGN/LIGHT COMBO	LED	WALL MOUNTED, UNO	6" CENTERED ABOVE DOOR FRAME, UNO	WITH 90 MINUTES EM. BATTERY BACK UP.

ALL FIXTURES TO BE NEW UNLESS NOTED OTHERWISE. WHERE EXISTING FIXTURES ARE TO REMAIN, REPLACE FIXTURES/BALLASTS AND LAMPS AS NEEDED FOR LIKE NEW APPEARANCE AND OPERATION.