



GENERAL NOTES:
FOR ROOFING DETAILS, ROOF FLASHING AND TERMINATIONS SEE A102 AND A102.1

- KEYNOTES:**
- 1 PRECAST CONC PANEL
 - 2 8" NOMINAL CMU PARTIET WALL
 - 3 1/4" / FT OPEN INSULATION
 - 4 STEEL DECK (SEE STRUCTURAL)
 - 5 BEAM POCKET (SEE STRUCTURAL)
 - 6 STEEL LONG SPAN BEAM (SEE STRUCTURAL)
 - 7 POURED CONC BEAM (SEE STRUCTURAL)
 - 8 POURED CONC COLUMN AT LONG SPAN TRUSSES (SEE STRUCTURAL)
 - 9 8" NOMINAL CMU'S W/ HORIZONTAL JOINT REINFORCING @ 16" O.C. (SEE STRUCTURAL)
 - 10 INTERMEDIATE CONC BEAM (SEE STRUCTURAL)
 - 11 CONTINUOUS POURED U BLOCK W/ (2) #5 REBAR (SEE STRUCTURAL TYPICAL)
 - 12 FACE BRICK TO MATCH ADJACENT BOILER BUILDING
 - 13 BOILER ROOM SLAB, SEE STRUCTURAL FOR THICKNESS AND REINFORCEMENT
 - 14 LOCATION OF HVAC INTAKE DUCT, SEE MECHANICAL FOR EXACT SIZE AND CONFIGURATION
 - 15 PRECAST COPING
 - 16 INTEGRAL PANEL LOUVER SYSTEM - CENTRIA PROFILE SUPERRIB OR EQUAL

FINAL DESIGN
APPROVED FOR CONSTRUCTION

Order Plans @ WWW.LDOnline.com

<p>CONSULTANTS:</p>	<p>ARCHITECT/ENGINEERS:</p> <p>AKEA INC. 3803 NW 95th Street, Suite B Gainesville, FL 32606 Phone: (352) 474-6124 Fax: (352) 553-4437 OJA: FL #26693 AKEA Project No. 083-14</p>	<p>Drawing Title:</p> <p>WALL SECTIONS</p> <p>Approved: Project Director</p>	<p>Project Title:</p> <p>REPLACE BOILERS - FCA D. ENERGY AT THE MALCOM RANDALL VAMC</p> <p>Location:</p> <p>GAINESVILLE, FLORIDA</p> <p>Date: MARCH 9, 2016 Checked: THG Drawn: JG</p>	<p>Project Number:</p> <p>573-14-600</p> <p>Building Number:</p> <p> </p> <p>Drawing Number:</p> <p>A400 34 OF 127</p>	<p>Office of Construction and Facilities Management</p> <p>Department of Veterans Affairs</p>
---------------------	---	---	--	--	---