DocuSign Envelope ID: E7AF9EAA-8D15-4E09-8FF4-B5B6E2B2F1EA
26C2661660C71

SUPPORT AREA:
LIGHT HAZARD SPRINKLERS
0.1 GPM/FT2 OVER ENTIRE
AREA.

OFFICE AREA
LIGHT HAZARD

HIGH BAY AREA
ORDINARY HAZARD GROUP #
2 SPRINKLERS 0.2 GPM/FT2
OVER REMOTE 1500FT2.

FLOW SWITCH AND TAMPER SWITCH

4" Riser
Check Valve
Refer to Detail

4"ø Fire
Protection
Wet
37.0' AFF

To Sprinklers

2" Main
Drain Thru
Wall

4"d Fire
Protection
Wet
1.7' AFF

1"ø Fire
Protection
Wet
37.0' AFF

1"ø Fire
Protection
Wet
1.8' AFF

To Sprinklers

INSPECTOR TEST
CONNECTION,
ANCHOR DROP IN
PLACE'S MINIMUM.

8" ALARM BELL 12'-0" AFF

FDC

4"d Fire
Protection
Wet
37.0' AFF

4"ø Fire
Protection
Wet
2.7' AFF

BOILER ROOM
ORDINARY HAZARD
GROUP 2

6"ø Fire
Protection
Wet
14.5' AFF

SEE SHEET FP201
FOR CONTINUATION.

308

NEW FIRE PROTECTION PLAN
1/4" = 1'-0"

Order Plans @ WWW.LDILine.com

FINAL DESIGN
APPROVED FOR CONSTRUCTION

Revisions:	Date

CONSULTANTS:

AEI Affiliated Engineers
Affiliated Engineers SE, Inc.
Tioga Town Center
12821 SW 1st Road Ste 205
Gainesville, Florida 32608
Tel 352.376.6590 Fax 352.375.8479
CA-5160

I, James J. Williams, State of Florida, Professional Engineer, License No. 51049.
This item has been electronically signed and sealed by James J. Williams, PE. On 3/9/2018 using a digital signature.
Printed copies of this document are not considered signed and sealed and the signature must be verified on any electronic copies.

ARCHITECT/ENGINEERS:

AKEA INC
1803 NW 80th Street, Suite B
Gainesville, FL 32606
Phone: (352) 474-8124
Fax: (352) 563-4437
CA#: FL #26693
AKEA Project No. 083-14

Drawing Title	NEW FIRE PROTECTION PLAN
Approved: Project Director	
Project Title	REPLACE BOILERS - FCA D, ENERGY AT THE MALCOM RANDALL VAMC
Location	GAINESVILLE, FLORIDA
Date	MARCH 9, 2018
Checked	JSN
Drawn	RWD
Project Number	573-14-600
Building Number	
Drawing Number	FP200
	51 OF 127

Office of Construction and Facilities Management
Department of Veterans Affairs

VA FORM 08-6231