

BLOWDOWN/CONTINUOUS BLOWDOWN SYSTEM SCHEMATIC


- DRAWING NOTES:**
- VENT SHALL BE A MINIMUM OF ONE PIPE SIZE LARGER THAN SAFETY VALVE OUTLET. FINAL VALVE SIZE SHALL BE BY THE MANUFACTURER. CONTRACTOR SHALL FLUSH AND INSTALL DRIP PAN ELBOWS.
  - FINAL VENT SIZE SHALL BE DETERMINED BY THE MANUFACTURER.

FINAL DESIGN  
APPROVED FOR CONSTRUCTION

Order Plans @

**CONSULTANTS:**

**AEI** Affiliated Engineers  
Affiliated Engineers SE, Inc.  
Triage Town Centre  
12821 SW 1st Road Ste 205  
Gainesville, Florida 32609  
Tel: 352.376.5500 Fax: 352.375.3479  
CA-6142



**ARCHITECT/ENGINEERS:**

**AKEA** INC  
1903 NW 58th Street, Suite B  
Gainesville, FL 32606  
Phone: (352) 474-8124  
Fax: (352) 503-8437  
OIA: FL #26493  
AKEA Project No. 083-14

**Drawing Title:**  
BLOWDOWN/CONTINUOUS BLOWDOWN SYSTEM SCHEMATIC

**Approved:** Project Director

**Project Title:**  
REPLACE BOILERS - FCA D. ENERGY AT THE MALCOM RANDALL VAMC

**Location:**  
GAINESVILLE, FLORIDA

**Date:** MARCH 9, 2018

**Checked:** JSN

**Drawn:** RWD

**Project Number:**  
573-14-600

**Building Number:**

**Drawing Number:**  
MP704

86 OF 127

Office of Construction and Facilities Management