

**PUBLIX FACILITIES
DESIGN DEPARTMENT**

- DAVID M. REE, PE
ARCHITECT FL REG. 13199
GA REG. 11277
AL REG. 6234
TN REG. 103497
VA REG. 12432
- JOHN W. KITCHENS, PE
CIVIL/STRUCTURAL FL REG. 45277
GA REG. 27740
SC REG. 21754
AL REG. 24905
NC REG. 101862
TN REG. 39873
VA REG. 040205922
- PAUL C. HARMAN, PE
STRUCTURAL FL REG. 13199
GA REG. 27740
SC REG. 21754
AL REG. 24905
NC REG. 101862
TN REG. 39873
VA REG. 040205922
- JOHN J. CASAMALIS, PE
MECHANICAL FL REG. 43889
GA REG. 021248
SC REG. 16521
AL REG. 20581
TN REG. 106507
VA REG. 040205478
- ANTHONY CLEMENTI, PE
MECHANICAL FL REG. 54781
GA REG. 31882
SC REG. 25591
AL REG. 28489
TN REG. 111382
NC REG. 039864
VA REG. 040205937
- RAYMOND J. SIRIANNI, PE
ELECTRICAL FL REG. 54085
GA REG. 020508
SC REG. 19743
AL REG. 23965
TN REG. 108038
NC REG. 039863
VA REG. 040205379

© COPYRIGHT 2018
PUBLIX SUPER MARKETS, INC.

THESE CONSTRUCTION DOCUMENTS ARE THE
PROPERTY OF PUBLIX SUPER MARKETS, INC. AND
ARE NOT TO BE COPIED OR REPRODUCED FOR ANY
SPECIFIC BUILDING WITHOUT WRITTEN PERMISSION.
THESE DRAWINGS SHALL NOT BE DISSEMINATED
WITHOUT PRIOR WRITTEN PERMISSION OF PUBLIX
SUPER MARKETS, INC.

THE DESIGN INDICATED IN THESE CONSTRUCTION
DOCUMENTS IS BASED ON THE BEST OF MY
KNOWLEDGE, INFORMATION, AND BELIEF. I COMPLY
WITH THE APPLICABLE MINIMUM BUILDING CODES.

DRAWING NOTES

- ◇ DRY PENDANT SPRINKLER HEAD IN CEILING (TYPICAL)
- ◇ DRY PENDANT SPRINKLER HEAD IN COOLERS AND FREEZERS (TYPICAL)
- ◇ SEE DRAWING FP-1.1 FOR INFORMATION ON THE UPRIGHT SPRINKLERS IN THE JOIST SPACE.
- ◇ PROVIDE SPRINKLER HEAD PROTECTION BELOW ALL REFRIGERANT PIPE GROUPINGS GREATER THAN 4" IN WIDTH.
- ◇ FREEZER AND COOLER SPRINKLER HEADS SHALL BE POSITIONED TO ADHERE TO OBSTRUCTION CLEARANCE FROM EVAPORATOR COOLING UNITS AND LED LUMINAIRES (TYPICAL).
- ◇ PROVIDE 280°F RATED SPRINKLER (K-8.0) 5TP RESP ABOVE THE OVEN
- ◇ PROVIDE DRAIN VALVES AT TRAPPED SECTIONS OF PIPE
- ◇ WALL EXTENDS TO UNDERSIDE OF ROOF DECK, SEE DRAWING A-4 FOR MORE DETAIL.

PLOT DATE:
August 21 2018

| No. | Description | Date |
|-----|-------------|------|
| | | |
| | | |
| | | |
| | | |

STORE NUMBER
1687
Tattersall Park
US 280 & Highway 19
Hoover
Shelby Co., AL

48.10
V0814.2018
SIENNA LITE

FIRE
PROTECTION
PLAN-LOWER
LEVEL

As indicated

FP1.2

PERMIT SET DATE: 8/29/2018 11:24:54 AM

