



LUMINAIRE SCHEDULE

MARK	LUMINAIRE WATTAGE	MANUF.	CATALOG NUMBER	DESCRIPTION	MOUNTING	BALLAST	LAMP
						QTY. TYPE QTY.	TYPE
77	G	COLLORBA	4PDM-4220-44A12 105-48U-0LH	3x4 LAMP, 50W 50 FULLWAVE RECTIFIED INCANDESCENT DIFFUSER	LAY-ALIGNED	1 SELECTRONIC 4	PC0205850100CC
7	FB	ULS LIGHTING	FWV 540 S 213 X HE W	WALL MTD. LINEAR (1 X 4 FT)	WALL MTD. (9" HP TO BOT)	2	0P13008383ECC
1	RR	COLLORBA	PRV-034-230-84LGRPHN (TYPE PRR)	4 FOOT, 2 LAMP 18, 40W FULLWAVE RECTIFIED SELECT. BALLAST	SURFACE	1 SELECTRONIC 2	PC0205850100CC
10	ETP	727	TRV-020-060-20W12LGRPHN	TRIPLE DISTRIBUTION LED WALLPACK W/ WHITE COOLER	WALL MTD	N/A	27W 4000K LED
22	EM	ELNOLITE	QVSC03P	EMERGENCY LIGHTING WALLPACK W/ WHITE BACKUP	SURFACE	N/A	LAMP INCLDGED
14	X1	PRESCOLITE	PEXAL S-R-820 W/O CR	LED EXIT FIXTURE	SURFACE	N/A	LED DRIVER 1 INCLDGED

* INDICATES UL LISTED FIXTURE SUITABLE FOR METADAMP LOCATION TO COMPLY WITH N.E.C. 410-4.

NOTES ○

- ROUTE HOMERUN VIA LIGHTING CONTACTOR(S).
- EC SHALL ROUTE HOMERUN FOR TENANT LIGHTING CIRCUIT AS SHOWN ON "TENANT LIGHTING CONTROL DIAGRAM".

GENERAL NOTES

- FIXTURE WHIPS SHALL BE ASSEMBLED WITH 1/2" MC CABLE AND SHALL BE OF SUFFICIENT LENGTH TO ALLOW RELOCATION OF ANY TYPE "G" LIGHT FIXTURE A MINIMUM OF ONE TILE IN ANY DIRECTION.
- ALL EXPOSED CONDUIT SHALL BE LOCATED WITHIN JOIST SPACE AREA OR ATTACHED DIRECTLY TO THE JOIST. CONDUIT SHALL NOT BE SUSPENDED FROM STRUCTURE.
- CONTRACTOR SHALL COORDINATE LOCATION AND MOUNTING HEIGHT OF ALL EXTERIOR SOFFIT LIGHTS AND WALLPACKS WITH ARCHITECTURAL DRAWINGS AND DETAIL.
- EXTEND UNCONTROLLED "HOT" CONDUCTOR TO ALL EMERGENCY LIGHTS, EXIT LIGHTS, AND NIGHT LIGHTS.

Order Plans

WWW.DLINE.COM

1925 Prospect Ave
Orlando, FL 32814
P (407) 661-9100
F (407) 661-9101

Colucci & Retta
Architects Engineers

CLIENT NAME
White Development Company
1801 South Keene Rd.
Clearwater, FL 33756

PROJECT NAME
Retail @ Tattersall Park
US Highway 280 & Highway 119
Hoover, AL

SHEET TITLE
Lighting Plan

Rev.	Description	Date
A	100% P/L	06-07-18
B	ISSUED TO BID & PERMITS	7-26-18

PROJECT NO.	DATE	BY	CHECKED
210090	07-27-18	AW	PC