

OG 1289 Site Survey - Commissioning Document.xlsx  
Panel Schedule NCR

PANEL RATING 100 Amps					
Breaker	Rating	Load	Breaker	Rating	Load
1	20		2	20	Recept - Bar and Late Side/MPS Line
3	20	Recepts - Break Area 2	4	20	Pagers/Dessert Cooler/Bar Screen
5	20		6	20	
7	20	Space	8	20	
9	20		10	30	
11	20	Space	12	30	
13	20	Space	14	20	Space
15	20	Space	16	20	Space
17	20	Space	18	20	Space

NOTES Located in Managers Office

OG 1289 Site Survey - Commissioning Document.xlsx  
Panel Schedule KA-1

PANEL RATING 400 Amps					
Breaker	Rating	Load	Breaker	Rating	Load
1	20		2	20	
3	20		4	20	
5	20	Microwave Line Assemble	6	20	Space
7	20	Microwave Line Assemble	8	20	Walk In Freezer
9	20	Walk In Freezer	10	20	Walk In Freezer
11	20	Walk In Freezer	12	20	Walk In Freezer
13	20	Walk In Freezer	14	20	
15	20	Line Freezer/Timer/Fryer	16	20	
17	20	Spare	18	20	
19	20		20	30	Cheese Melter 1
21	20		22	30	Cheese Melter 1
23	30		24	20	Heat Lamps Windows 1 and 2
25	30		26	20	Heat Lamps Windows 1 and 2
27	20	Heat Lamps App Station	28	20	
29	20	Heat Lamps App Station	30	20	Space
31	20	GF+ Beside App Station	32	20	
33	20		34	20	
35	20	Late Side Coffee/Tea	36	20	Line Reach In 1
37	20	Early Side Coffee/Tea	38	20	Space
39	20	Early Side Server Screen	40	30	Cheese Melter 2
41	20	Late Side Server Cooler	42	30	Cheese Melter 2

NOTES

OG 1289 Site Survey - Commissioning Document.xlsx  
Wall Box Dimmer and Switches

Location	From	Control	Load	Qty	Notes
Back Bar		51	Back bar down lgt	7	
Back Bar		52	Back bar wall wash track lgt	4	



OG 1289 Site Survey - Commissioning Document.xlsx  
Panel Schedule KB-1

PANEL RATING 225 Amps					
Breaker	Rating	Load	Breaker	Rating	Load
1	20		2	40	
3	20		4	40	
5	20	Bar Cooler/Refrigerator	6	40	
7	20		8	40	
9	20	Recept - App Station	10	20	Bar Glass Chiller
11	20		12	20	Space
13	20		14	20	Space
15	20		16	20	
17	20	Space	18	20	
19	20	Space	20	20	MPS Server Side
21	20		22	20	
23	20		24	20	Spare
25	20	Recept Late Side to go Area/Bar	26	20	
27	20	Recept Server Area	28	20	
29	20		30	30	Recept Salad Station
31	20		32	30	Recept Salad Station
33	25	Espresso Machine	34	30	
35	25	Espresso Machine	36	20	
37	20	Recept	38	20	
39	20	Recept	40	20	
41	20		42	20	

NOTES

OG 1289 Site Survey - Commissioning Document.xlsx  
Panel Schedule KP2


PANEL RATING 400 Amps					
Breaker	Rating	Load	Breaker	Rating	Load
1	20		2	20	Microwave Mop Station
3	20		4	20	Microwave Mop Station
5	20	Bag Zap/Kin EM/Late Side Srv Area	6	20	
7	20		8	20	Recepts Hostess Area
9	20		10	20	
11	30		12	30	
13	30		14	30	
15	30	Recepts Salad Station	16	30	
17	30	Recepts Salad Station	18	20	
19	30		20	20	
21	20		22	20	
23	20		24	20	
25	20		26	20	
27	20	Tilt Kettle 1	28	20	
29	20		30	30	
31	20		32	20	Back Up Crescor
33	20	Line Reach In 2/Crescor	34	20	Recept Bar
35	20	Line Reach In 2/Crescor	36	20	
37	20	Recept Behind Oven (Unused)	38	20	Oven
39	20	Recept Behind Oven (Unused)	40	20	Oven
41	20		42	20	Line Wall Recepts
43	20		44	20	Line Wall Recepts

NOTES

OG 1289 Site Survey - Commissioning Document.xlsx  
MARLIN DIMMING PANEL 1

Breaker	Amp Break	Module	Area - Fixture Type	Qty	Notes
C					
1	5.4	1	Back bar down lgt	18	
2	5.7	2	Back bar 1 down lgt	4	
3	2.2	3	Section Alley 1 down lgt	4	
4	3.2	4	Hand Room table pendant	5	
5			Cheese Melt wall wash track lgt	5	
6	5.7	7	Sergio's Room down track lgt	8	
7			Vigorelli's Room down track lgt	2	
8			Master Room down track lgt	4	
9			Hand Room down track lgt	2	
10	2.4	5	Cabinet Room down track lgt	2	
11	4.3	8	Vigorelli's Room down track lgt	10	
12	6.6	10	Sergio's Room down track lgt	7	
13			Cabinet Room down track lgt	5	
14			Master Room down track lgt	2	
15			Master Room table pendant lgt	2	
16			Bar canopy down lgt	5	
17	5.8	11	Vigorelli's Room wall wash track lgt	5	

NOTES



Order Plans @