

STANDING SEAM METAL ROOF SPECIFICATIONS

PART 1 GENERAL

1.01 SECTION INCLUDES

A. Preformed, pre-finished roof panels.

1.02 RELATED SECTIONS

Not Used.

1.03 SUBMITTALS

- A. Submit properly identified product data including material specifications and published installation directions.
- B. Submit shop drawlings for review showing structural purlin framing plans, elevations, sections, large scale details of all typical connections, joints and related flashings. Show sizes, panel profiles, thicknesses, joint waterproof treatment, weatherproof closures, corner treatment, accessories, finishes, anchors, clips, fastenings and erection details. Shop drawings shall be signed & sealed by a Registered Professional Structural Engineer of the state in which this product is being installed.

1.04 QUALITY ASSURANCE

 Design metal roof panel system including structural puriln supports and connections to comply with wind loading requirements of the local Building Codes.

1.05 PRODUCT DELIVERY, STORAGE AND HANDLING

- A. Deliver products to job site in their original unopened containers clearly labeled with the manufacturer's name and brand designation referenced specification number, type and class as applicable.
- B. Store products in an accepted dry area; protect from contact with soil and from exposure to the elements Keep products dry at all times.
- C. Handle products in a manner that will prevent breakage of containers and damage to products.

PART 2 PRODUCTS

2.01 PREFORMED PREFINISHED ROOF PANEL SYSTEM

- Provide products shown on drawings by Berridge Manufacturing Co., (800) 231-8127 "CEE-Lock" Standing seam panel (OR APPROVED EQUAL, COORDINATE WITH OWNER.
- B. Prefinished 22 gauge galvanized steel panels, Exposed Flashings And Trim
- C. Panel and Flashing Accessory Finish: Kynar 500 fluoropolymer coating applied to extend sheet metal surfaces of color DARK BRONZE.
- D. Bottom eave drip flashings; hip-ridge flashings, to be flashings formed to fit roof panel cap flashings, gutfers and penetration flashings frommed prefit shed, galvanized sheet rife accessories in accord with manufacturery's details gaiphed or a yoposed surfaces to match of panels.
- E. Roof Panel Closures: Manufacture and address panels
- F. Panel Edge Seals: Paner "May facturer's" and factory apply assoments seal, sealant tape or sealant. Face fasten the inter a face 18 inches are not and proving a continuous cleat on the outer fit that is fastened every 12 inches on center.
- G. Exposed Roof and Flast or Fasteners: #14 x 3 4% ch and #14 x 2 inch colored nylon head zinc plate stainless site and mediscrews with neoprene washers. Screw head color shall match penel a mediscrew solor.
- Top, Bottern ng Internediates short Angles, Support Framing, Cross Bracing, Roof Purlins, Purlin Attachment 2 CC of formed fraging galvanized sheet steel special angles and channels designed by manufacturer to get getign leading and deficition requirements, spanning between primary steel roof beam supports. Measurer size and spacing shall be determined by manufacturer.
- Fasteners for Securing Support Angles and Purlin Attachment Clips to Masonry and Concrete: Minimum 1/4 inch diameter zinc plated steel Tap-Con Fasteners, 1/4 inch diameter zinc plated hex-head machine crows in self-driling concrete anchors, or equivalent powder driven fasteners. Fastener sizes and umbers shall be designed by panel manufacturer to meet design loadings.
- J. Fasteners for Securing Cold Formed Metal Support Framing, Cross Bracing, Clips and Roof Purlins Together. Minimum 1/4 inch diameter zinc plated hex head machine screws with matching washers and nuts. Fastener sizes and numbers shall be designed by panel manufacturer to meet design loadings.
 - K. Underlayment: Grace ice & watershield (40 mil).

- L. Supply and install new 22 gauge, Kynar 500 finish, roof to wall metal flashing at the base of the parapet wall area of the same color as the new metal panels (utilize manufacturer flat stock materials).
- M. Supply and install manufacturer approved penetration flashing as required by manufacturer to obtain specified warranty.
 - Contractor to include material and labor for waterproofing the new rooftop light fixtures replaced by others (if applicable).

PART 3 EXECUTION

3.01 INSPECTION

A. Inspect dimensions, elevations and alignment of structural steel framing for support of purins, roof paralls and accessories. If substrate corrections are necessary, do not proceed until corrections have been accessories.

3.02 ERECTION

A. Erect roof panel purlin supports, roof panels, and related flashing accessoried in accommon with reviewed shop drawings, erection drawings and manufacturer's erection directions.

3.03 SEALING

A. Provide roof panel manufacturer's standard sealing system panel at the panel are panel and panel and panel edges and masonry.

FASTENINGS

. Provide concerned fast gs for roof panels

 Where Exposed fasteners for roof panels and roof flashing solor of fasters shall match pages.

DAMACON MATERIAL OF FINISHES

A. Touch pepairable parasions to actory prefinished surfaces with factory supplied air dry spray enamel.

B. Replace sically day and material with matching material.

.06 WARANTY

- Confector Workmanship Warranty- Provide GMRI, Inc. with a two (2) year workmanship warranty that we defective workmanship on all roof sections and exterior wall cladding upon completion.
- B. Manufacturer Warranty- Provide GMRI, Inc. with a twenty (20) year Watertightness Warranty and a twenty (20) year finish warranty from the manufacturer upon completion.
- 4.0 SPECIAL INSTRUCTIONS
- A. All aspects of this work shall follow all local and state building code requirements and regulations and manufacturer recommendations.
- B. The contractor selected to complete the re-roofing project will be required to:
- 1. Attend the Pre-Construction Meeting with the restaurant General manager and Facility Manager.
- Discuss with Darden Construction Project Manager the proposed work schedule and plan for minimizing disruption to the restaurant and their customers.
- Submit cell phone numbers for the project foreman and an emergency contact to Darden Construction Project Manager.
- 4. Hold daily update meetings with Darden Construction Project Manager to insure constant communication and eliminate issues.



ECT FOR WHICH THEY WERE PREPARED. AND NOT FOR THE



8

1173

P1B (HIGH)

Restaurant #:

1711 GALLATIN RD

MADISON, TN

Drawing

ROOF SPECIFICATIONS

A6.3