

ACME TAG: KEF-1 Project: Domino's Location: Varies Engineer: MPW Engineering
 Acme Engineering and Manufacturing Corporation P.O. Box 978, Muskogee, OK 74402
 Print Date: 3/9/2015 11:29:46 AM

CR
Curb, Restaurant
Standard Construction Features
 1-1/2" fiberglass insulation R-8 Value, 3PCF (NA with Verted Curb)
 1/4" polyurethane gasket (Top Ledge)
 18 ga. galvanized steel
 2 year Fan/Motor Warranty
 Continuous welded seams
 Design to comply with applicable NFPA code requirements
 Integral base plate
Options & Accessories
 Self Flashing
 4 Sides With Vents

Qty	Model Size	Weight (lbs)
1	CR17.5 X 17.5	21.00

Manufacturer reserves the right to change specifications without notice. These are typical drawings for dimensional purpose only and are subject to change for normal installation requirements. They do not necessarily show actual construction.

3/9/2015 11:29:46 AM

ACME TAG: KEF-1 Project: Domino's Location: Varies Engineer: MPW Engineering
 Acme Engineering and Manufacturing Corporation P.O. Box 978, Muskogee, OK 74402
 Print Date: 3/9/2015 11:29:46 AM

GTR
Grease Trough Roof
Standard Construction Features
 Compartmentalized to separate grease/water
 Galvanized steel construction
 Mounted easily to roof type ventilators

Qty	Model Size	Weight (lbs)
1	PDU/PNU 060-295	29.00

Manufacturer reserves the right to change specifications without notice. These are typical drawings for dimensional purpose only and are subject to change for normal installation requirements. They do not necessarily show actual construction.

3/9/2015 11:29:46 AM

ACME TAG: KEF-1 Project: Domino's Location: Varies Engineer: MPW Engineering
 Acme Engineering and Manufacturing Corporation P.O. Box 978, Muskogee, OK 74402
 Print Date: 3/9/2015 11:29:46 AM

PDURG
Direct Drive Centrifugal Upblast Grease Roof Exhauster
Standard Construction Features
 2 year Fan/Motor Warranty
 Aluminum curb cap
 Backward inclined non-overloading aluminum wheel
 Conduit Post Through Windband
 Disconnect Switch - Weather Resistant Enclosure
 Heavy gauge aluminum housing
 Integral drain tube
 Motor bearings are permanently lubricated
 Quick release hood latches
 Restaurant applications
 Underwriters Laboratories (UL782) for restaurant hood applications

Volume (CFM)	SP (in wg)	Power (bhp)	TS (rpm)	Wdg (lbs)	Motor Info	Fan Rating: UL782 CSA
1228	1.000	0.489	1725	8097	124.0A	1/2 208 3 80 ODP 1725 1SP0

Manufacturer reserves the right to change specifications without notice. These are typical drawings for dimensional purpose only and are subject to change for normal installation requirements. They do not necessarily show actual construction.

3/9/2015 11:29:46 AM

PROJECT COORDINATOR/DESIGN CONSULTANT

idGROUP
 11 IRVING BLVD.
 DALLAS, TEXAS 75207
 TEL: 214-639-8900

ARCHITECT/ENGINEER

MPW
 MPW ENGINEERING, LLC
 133 W. 7TH STREET • SUITE 500 • TULSA, OK 74119
 (918) 582-4008 • (918) 582-4007 FAX

ALABAMA REGISTERED PROFESSIONAL ENGINEER
 SCOTT C. WEBB
 # 9272428

CLIENT PROJECT # 5879
 ARCHITECTURAL PROJECT NO.: 385-071
 DRAWN BY: RLJ
 CHECKED BY: MIM

DOMINO'S PIZZA
 30 FRANK LLOYD WRIGHT DRIVE
 ANN ARBOR, MI 48105
 TEL: 314.910.8560

DO NOT USE FOR GAS DETAIL: REFER TO DETAIL 4-P3.0 FOR GAS RISER.

INSTALL EXHAUST FANS A MINIMUM OF 10 FT FROM OUTSIDE AIR INTAKE OF HVAC UNITS.

Exhaust Fan
 Fan Curb
 Welded Duct
 HVAC Unit
 Duct Wrap (AS REQUIRED)
 1/2" All-thread Supported by Unistrut (4 Locations)
 Ceiling Joist
 Drop Ceiling
 Electrical Service Panel
 Finished Floor

AVI HOOD ROUGH-IN SPECIFICATIONS

Technical Support US: 888-443-2751
 Technical Support INTL: 314-910-2751

NOTE: IF HAVING ISSUES CONNECTING TO THE HOOD, CONTACT MANUFACTURER (XLT OVENS). PHONE NUMBER LOCATED ON HOOD.

OWNER TO PROVIDE RELAY IN OVEN HOOD TO INTERLOCK WITH MAU.

XLT Simple. Smart.
3255 Hood Double Stack

13 1/2" [343mm] Min
 48 5/8" [1228mm]
 111 5/8" [2835mm]
 69 5/8" [1769mm]
 20" [508mm]
 87 7/8" [2283mm]
 32" [813mm]

THE INFORMATION CONTAINED IN THIS DRAWING IS THE SOLE PROPERTY OF XLT INC. ANY REPRODUCTION IN PART OR WHOLE WITHOUT THE WRITTEN PERMISSION OF XLT INC IS PROHIBITED.

Domino's

DOMINO'S PIZZA #5879
 3871 AIRPORT BLVD.
 MOBILE, AL 36608

NO.	REVISIONS:	DATE:

PLANNING REVIEW ISSUE DATE: N/A
 CLIENT REVIEW ISSUE DATE: 09/13/2018
 LANDLORD REVIEW ISSUE DATE: 09/13/2018
 BID ISSUE DATE: 09/24/2018
 HEALTH DEPT. REVIEW ISSUE DATE: 09/24/2018
 BUILDING REVIEW ISSUE DATE: 09/24/2018
 CONSTRUCTION ISSUE DATE: 09/24/2018

DRAWING TITLE:
MECHANICAL HOOD DETAILS

DRAWING NUMBER:
M3.0

© 2018 idGROUP, LLC