

PLUMBING FIXTURE SCHEDULE

NO.	FIXTURE	SUPPLIER REFER TO SECTION 01000	MFR.	TYPE AND MODEL NO.	PIPE SIZES					REMARKS
					TRAP	WASTE	VENT	CW	HW	
S2	PREP ROOM THREE COMPARTMENT SINK (ADA COMPLIANT)	HUGHES SUPPLY INC	ELKAY	NA2877 NA2878 NA2876	-	2" (IND)	-	1/2"	1/2"	88"x26"x16" 3-COMPARTMENT SINK, RIGHT & LEFT DRAINBOARDS, 1 ZURN FAUCET, 2.0 GPM FLOW RATE MAXIMUM. ADJUST TO SWING GOOSENECK UPON INSTALLATION, WRIST BLADE HANDLES, (3) ADVANCE TABCO DRAIN FITTINGS WITH LEVER HANDLE, BASKET STRAINER, NSF CERTIFIED.
S3	HAND SINK (ADA COMPLIANT)	HUGHES SUPPLY INC	ADVANCE TABCO	NA2618 NA2619	1-1/2"	2"	1 1/2"	1/2"	1/2"	17-1/4" X 15-1/4" SINGLE BOWL 18 GAUGE TYPE 304 STAINLESS STEEL WALL MOUNTED WITH GOOSENECK FAUCET 2.0 GPM MAX WITH WRISTBLADE HANDLES.
S4	HAND SINK	HUGHES SUPPLY INC	MAINLINE	SINGLE BOWL MLUS7771	1 1/2"	2"	2"	1/2"	1/2"	TYPE 304 STAINLESS STEEL SINGLE BOW UNDER COUNTER SINK, MAINLINE SINGLE LEVER TREME FAUCET. THE DESK SINK AND FAUCET WITH TRIM ARE PROVIDED BY DESK VENDOR AND INSTALLED BY CONTRACTOR AND FINAL PLUMBING CONNECTIONS BY GENERAL CONTRACTOR.
WATER FILTER	WATER FILTER	HUGHES SUPPLY INC	EVERPURE	EV969231 (4FC-S)	-	-	-	3/8"	-	WATER FILTER LOCATED IN FOOD PREP ROOM ON WALL TO SUPPLY FILTERED WATER TO BEVERAGE STATION, KUREG MACHINES, AND COFFEE MAKER. REFER TO ARCHITECTURAL PLANS FOR EXACT LOCATION AND PLUMBING PLANS FOR PIPING DIAGRAM. WATER FILTER PROVIDED AND INSTALLED BY GENERAL CONTRACTOR.
P6	SINK	HUGHES SUPPLY INC	-	BBB-240	1-1/2" x 1-1/2"	1-1/2"	1-1/2"	1/2"	1/2"	COUNTER TOP SUPPORTED FIXTURE. INCLUDES: FAUCET, DRAIN, P-TRAP, SUPPLY WATER LINES AND SHUTOFF VALVES. PROVIDE AND INSTALL 120 V, 1/2 HP BADGER 5 MODEL INSINKERATOR.
P7	ELECTRIC WATER HEATER	HUGHES SUPPLY INC	RHEEM	ELDS40-TB	-	-	-	3/4"	3/4"	36 GALLON ELECTRIC WATER HEATER WITH (2) 4.0 KW ELEMENTS OPERATING SIMULTANEOUSLY FOR A TOTAL OF 8.0 KW INPUT AT 460V/3PH/60HZ WITH AN OPERATING TEMP. OF 120 DEGREES F. PROVIDE WATTS DET-S EXPANSION TANK.
P8	ELECTRIC INSTANT WATER HEATER	HUGHES SUPPLY INC	EEMAX OR EQUIVALENT	SP3208	-	-	-	3/8"	3/8"	TANKLESS WATER HEATER WITH 3KW INPUT. INSULATE ALL EXPOSED HW PIPES MOUNTED BELOW SINK. 208V, 3KW, 14.4 AMPS, 41" RISE @ 0.5 GPM. CONTRACTOR TO VERIFY COMPLIANCE WITH APPLICABLE CODES AND ORDINANCES BEFORE ORDERING. INSULATE ALL EXPOSED HW PIPES MOUNTED BELOW SINK.
GT-1	GREASE INTERCEPTOR	HUGHES SUPPLY INC	J.R. SMITH	8235	-	3"	3"	-	-	RECESSED 35 GPM & 70 LB GREASE INTERCEPTOR PROVIDE WITH FLOW CONTROL FITTING AND EXTENSION UP TO FINISH FLOOR. SEE PLAN FOR LOCATION.
FCO	FLOOR CLEAN OUT	HUGHES SUPPLY INC	ZURN	BBB-145	-	-	-	-	-	REFER TO PLAN FOR SIZES.
GCO	GRADE CLEAN OUT	HUGHES SUPPLY INC	ZURN	NA2535	-	-	-	-	-	ZURN ZN1400HD GRADE CLEAN OUT. REFER TO PLAN FOR SIZES.
FS	FLOOR SINK	HUGHES SUPPLY INC	ZURN	NA2607	3"	3"	1-1/2"	-	-	12"x12"x8" DEEP CAST IRON BODY RECEPTOR FOR INDIRECT WASTE WITH NICKEL BRONZE TOP AND 1/2 GRATE. FLOOR SINK SHALL BE PROVIDED WITH DOME BOTTOM STRAINER.
FD	FLOOR DRAIN	HUGHES SUPPLY INC	ZURN	NA2530	3"	3"	2"	-	-	TYPE B STRAINER, WITH STABILIZER Q-DECK, PROVIDE TRAP PRIMER CONNECTION.
TMV	THERMOSTATIC MIXING VALVE	HUGHES SUPPLY INC	SYMMONS	7-200	-	-	-	3/4"	3/4"	CHECK STOPS, REMOVABLE CARTRIDGE WITH STAINLESS STEEL PISTON AND THERMAL MOTOR AND TABULATOR
TPV	TRAP PRIMER VALVE	HUGHES SUPPLY INC	P.P.P.	NA2540	-	-	-	-	-	REFER TO DETAIL ON SHEET P3.1
WHA	WATER HAMMER ARRESTOR	HUGHES SUPPLY INC	SIoux CHIEF MANUF.	652A	-	-	-	-	-	SIZES AS REQUIRED BY FIXTURE UNITS AND MANUFACTURERS RECOMMENDATIONS.
WCO	WALL CLEAN OUT	HUGHES SUPPLY INC	ZURN	Z1468	-	-	-	-	-	REFER TO PLAN FOR SIZES.
SH-1	STAINLESS STEEL SHELF 12" OVER WORK TABLE	HUGHES SUPPLY INC	ADVANCE TABCO	NA2622	-	-	-	-	-	LENGTH: 6'-0"
SH-2	WIRE 14" PREP SHELVING DIRECT WALL MOUNT	HUGHES SUPPLY INC	ADVANCE TABCO	NA2621	-	-	-	-	-	LENGTH: 8'-0"
SH-3	WORK STORAGE SHELF 24" PREP WITH (4) SHELVES	HUGHES SUPPLY INC	ADVANCE TABCO	NA2621	-	-	-	-	-	LENGTH: 5'-0"
SH-4	WORK TABLE	HUGHES SUPPLY INC	ADVANCE TABCO	NA2620	-	-	-	-	-	LENGTH: 6'-0"
CM-1	COFFEE BREWER WITH WATER FILTRATION / AIRPOT AND AIRPOT RACK	HUGHES SUPPLY INC	BUNN	CWF15-APS	-	-	-	1/4"	-	CONTRACTOR TO PROVIDE AND INSTALL ALL OF THE FOLLOWING: BUNN SINGLE COFFEE BREWER W/ DIRECT WATER. BUNN COFFEE AIRPOT 2.0 GPM LEVER ACTION 6 PACK MODEL #3125.0100 AND (2) BUNN AIRPOT RACK UNIV-3 A MODEL #35728.0000. PROVIDE & INSTALL AN APPROVED 1/2" BACKFLOW PREVENTER TO THE COFFEE MAKER (MOUNT STUB @ 48" AFF) AND WATER SHUT-OFF VALVE TO ALLOW FOR WATER FILTER REPLACEMENT. LENGTH 5'-0"
R-1	REFRIGERATOR / FREEZER	HUGHES SUPPLY INC	TRUE MODEL	T-23DT REACH-IN	-	-	-	-	-	CONTRACTOR TO PROVIDE AND INSTALL ALL OF THE FOLLOWING: COMMERCIAL REACH-IN REFRIGERATOR-FREEZER; REF-31 CU FT, FRZ-8 CU FT; 7.3/8" H X 29.5" D; 115 VOLTS; 15 AMP CIRCUIT RECESSED SHELF KIT BY ARTIC AIR MODEL 216423800 - LAMINATE SELF KIT WITH MOUNTING CLIPS. DOOR SWINGS TO BE LEFT OR RIGHT HANDED. RIGHT HANDLE SWING. COORDINATE SWING WITH ARCHITECTURAL PLAN.

- NOTES:**
- PROVIDE TRAP PRIMERS AT ALL FLOOR DRAINS.
 - PROVIDE INSULATING KIT ON TRAPS AND HOT AND COLD WATER SUPPLIES TO ALL HANDICAPPED LAVATOIRES.
 - SEE ARCHITECTURAL DRAWINGS FOR LOCATIONS OF HANDICAPPED FIXTURES. ALL PLUMBING FIXTURES TO BE PROVIDED BY THE CONTRACTOR THROUGH A NATIONAL ACCOUNT AGREEMENT. FOR CONTACT INFORMATION CALL HUGHES SUPPLY INC. REFER TO PROJECT MANUAL.
 - ALL NOTED FIXTURES SHALL BE ACCESSIBLE TO INDIVIDUALS WITH DISABILITIES IN ACCORDANCE WITH THE "AMERICANS WITH DISABILITIES ACT OF 1990". FIXTURES AND THEIR INSTALLATION SHALL ALSO COMPLY WITH "AMERICAN NATIONAL STANDARDS INSTITUTE (ANSI) PUBLICATION A117.1 - PROVIDING ACCESSIBILITY AND USABILITY FOR PHYSICALLY HANDICAPPED PEOPLE AND/OR GOVERNING CODE.
 - ALL PLUMBING FIXTURES, EQUIPMENT, TRIM, AND FITTINGS SHALL COMPLY WITH LOCAL, STATE AND FEDERAL REGULATIONS AND CODES, INCLUDING, BUT NOT LIMITED TO, WATER AND ENERGY CONSERVATION CODES. THE SCHEDULED AND/OR SPECIFIED PLUMBING FIXTURES AND EQUIPMENT REPRESENT THE MINIMUM CRITERIA AND SHALL BE THE BASIS FOR THE CONTRACTOR'S BID. IF THE SCHEDULED OR SPECIFIED FIXTURES OR EQUIPMENT DO NOT COMPLY WITH GOVERNING CODES OR REGULATIONS IN ANY RESPECTS, THE CONTRACTOR SHALL PROVIDE AN ALTERNATE BID FOR COMPLYING FIXTURES, EQUIPMENT, TRIM, OR FITTINGS. THE ABSENCE OF AN ALTERNATE BID SHALL BE CONSTRUED TO MEAN THAT THE CONTRACTOR'S BID INCLUDES ALL COSTS NECESSARY TO COMPLY WITH ALL REGULATIONS AND CODES.
 - FLUSH VALVE HANDLES FOR HC, TOILET STALLS TO BE ON THE WIDE PORTION OF STALL.
 - SH-1 THRU 4 & R-1, FURNISHED BY PLUMBING CONTRACTOR AND INSTALLED BY GENERAL CONTRACTOR.

PUMP SCHEDULE										
MARK	MFR.	MODEL NO.	TYPE	DISCHARGE	GPM	FT. HD.	HP	MOTOR AMPS	ELEC	REMARKS
PUMP-1	LIBERTY	405	SUBMERSIBLE	2"	10	30	1/2	7.3	115/1/60	1,2,3,4,5
CP-1	WACO	005-SF	CIRCULATION	3/4"	4.0	8.0	1/35	-	115/1/60	2,3,5,6

GENERAL NOTES:

- PREP CHECK WATER UNION AT BASE OF DISCHARGE.
- PROVIDE MOTOR WITH THERMAL OVERLOAD PROTECTION, CAPACITOR AND START RELAY.
- PROVIDE DEDICATED BRANCH CIRCUIT TO SERVE PUMP.
- PUMP LOCATED BELOW MILLWORK ON SLAB. CONTRACTOR TO FIELD VERIFY BEST LOCATION FOR NEW PUMP UNDER MILLWORK.
- PUMP SHALL BE INSTALLED PER MANUFACTURERS RECOMMENDATIONS.
- PROVIDE CAST IRON PUMP WITH STAINLESS STEEL STRAINER.

ABBREVIATION LIST

IDENTIFIER	DESCRIPTION	IDENTIFIER	DESCRIPTION
AFG	ABOVE FINISH GRADE	MBH	BRITISH THERMAL UNITS PER HOUR
BFF	BELOW FINISH FLOOR	ORD	OVERFLOW ROOF DRAIN
BFP	BACKFLOW PREVENTER	PRV	PRESSURE REGULATOR VALVE
CO	CLEANOUT	RD	ROOF DRAIN
COOP	CLEANOUT DECK PLATE	RPZ	REDUCED PRESSURE ZONE BFP
FCO	CLEANOUT FLOOR MOUNTED	SS	SANITARY SINK
COG	CLEANOUT TO GRADE	ST	STORM
CTX	CONNECT TO EXISTING	SAN	SANITARY
WCO	CLEANOUT WALL MOUNTED	SS	SERVICE SINK
CW	COLD WATER	ST	STORM
EWC	ELECTRIC WATER COOLER	TYP.	TYPICAL
DFU	DRAINAGE FIXTURE UNITS	UR	URINAL
FU	FIXTURE UNITS	V	VENT
FD	FLOOR DRAIN	VTR	VENT THROUGH ROOF
G	GAS	W	WASTE
GPH	GALLONS PER HOUR	WC	WATER CLOSET
HB	HOSE BIBB	WFU	WATER SUPPLY FIXTURE UNITS
HW	HOT WATER	WH	WALL HYDRANT
HWH	HOT WATER HEATER	X	EXISTING TO BE MAINTAINED
HWR	HOT WATER RETURN	XR	EXISTING TO BE REMOVED
INV	INVERT	XRL	EXISTING TO BE RELOCATED
IW	INDIRECT WASTE	XNL	EXISTING RELOCATED, SHEET IN NEW LOCATION
LAV	LAVATORY		

SYMBOL LIST

IDENTIFIER	DESCRIPTION	IDENTIFIER	DESCRIPTION
II	GATE VALVE	-	EXISTING UTILITY AS INDICATED
OS	OSGATE VALVE	-SAN-	SANITARY SEWER PIPING BELOW GRADE
GLOBE VALVE		-GH-	GREASE WASTE PIPING
CHECK VALVE		-SAN-	SANITARY SEWER PIPING
1/4" TURN BALL VALVE		-PD-	PUMP DISCHARGE
GAS COCK		-ST-	STORM SEWER PIPING BELOW GRADE
GAS PRESSURE REGULATOR		-RC-	RAIN CONDUCTOR
GAS SOLENOID VALVE		-ORC-	OVERFLOW RAIN CONDUCTOR
SV	GAS SOLENOID VALVE	-V-	VENT PIPING
UNION		-CW-	COLD WATER PIPING
FCO	DENOTES FLOOR MOUNTED CLEANOUT	-FH-	FILTERED WATER PIPING
WCO	DENOTES CLEANOUT IN WALL	-HW-	HOT WATER PIPING
M	WATER METER	-G-	GAS
THERMOMETER		-RPS-2-	REGULATED PRESSURE GAS 2 PSI
WALL HYDRANT		-CD-	CONDENSATE DRAIN
FLOOR DRAIN		XX	EQUIPMENT DESIGNATION
		1	
		PX	PLUMBING FIXTURE NUMBER
		+	POINT OF CONNECTION
		○	INDICATES CODED NOTE

PLUMBING GENERAL NOTES

- PLUMBING CONTRACTOR SHALL FIELD VERIFY THE EXACT LOCATIONS AND SIZES OF ALL UTILITIES, INCLUDING THE DEPTHS OR HEIGHTS OF ALL BELOW FLOOR/GRADE SANITARY AND STORM SEWERS, PRIOR TO START OF WORK. THIS DRAWING IS NOT INTENDED TO INDICATE ALL EXISTING UTILITIES.
- CONTRACTOR SHALL BE FAMILIAR WITH LANDLORD'S STANDARDS, RULES AND REGULATIONS. ALL LANDLORD'S CRITERIA SHALL BE COMPLIED WITH AND INCLUDED IN THIS BID.
- CONTRACTOR SHALL VISIT SITE PRIOR TO SUBMITTING BID AND FIELD VERIFY EXISTING CONDITIONS TO ENSURE THAT THE WORK REPRESENTED ON THE DRAWINGS AND THESE SPECIFICATIONS CAN BE INSTALLED AS INDICATED. CONTRACTOR SHALL TAKE ALL INTERFERENCES INTO CONSIDERATION. PROVIDE ALL NECESSARY OFFSETS FOR SUIT FIELD CONDITIONS AS REQUIRED.
- CONTRACTOR SHALL VERIFY AND COORDINATE ALL UTILITY CONNECTIONS, INCLUDING SIZES AND INVERTS WITH EXISTING FIELD CONDITIONS PRIOR TO START OF WORK.
- MAKE ALL UTILITY CONNECTIONS AND INSTALLATIONS IN FULL ACCORDANCE WITH ALL UTILITY REGULATIONS. PROVIDE ALL ADDITIONAL APPURTENANCES AS REQUIRED BY UTILITY COMPANY. THE COMPLETED INSTALLATION SHALL BE IN ACCORDANCE WITH ALL APPLICABLE INDUSTRY STANDARDS, GOOD PRACTICE AND SAFETY, AND THE MANUFACTURERS' STRUCTURAL CONNECTIONS FOR EQUIPMENT AND PRODUCT APPLICATION AND INSTALLATION.
- THE CONTRACTOR SHALL OBTAIN AND PAY FOR ALL PERMITS AND INSPECTIONS RELATED TO THE INSTALLATION OF THE WORK.
- ALL WORK SHALL COMPLY WITH ALL APPLICABLE FEDERAL, STATE AND LOCAL CODES, LAWS, ACTS AND ALL AUTHORITIES HAVING JURISDICTION AND LANDLORD'S CRITERIA.
- MAINTAIN ALL MANUFACTURERS' RECOMMENDED SERVICE CLEARANCES FOR ALL FIXTURES AND EQUIPMENT. REFER TO ARCHITECTURAL PLANS FOR EXACT LOCATIONS OF PLUMBING FIXTURES.
- CUTTING OF ROOF AND FLASHING OF PIPE CURBS, SANITARY VENT THROUGH ROOF, ETC. SHALL BE COORDINATED WITH AND PERFORMED BY LANDLORD'S ROOFING CONTRACTOR AT THIS CONTRACTOR'S EXPENSE, TO MAINTAIN ROOF WARRANTY. ALL VENT OUTLETS SHALL BE A MINIMUM OF 10'-0" AWAY FROM OR 3'-0" ABOVE ANY AIR INTAKES ON HVAC EQUIPMENT.
- ALL HORIZONTAL FIRE PROTECTION SPRINKLER PIPING AND ALL ABOVE GRADE EXPOSED HORIZONTAL PIPING IS TO BE INSTALLED AS HIGH AS POSSIBLE.
- CONTRACTOR SHALL COORDINATE TIMES TO WORK IN SPECIFIC AREAS OF THE EXISTING BUILDING WITH THE BUILDING MANAGER AND WITH THE OCCUPANTS OF THE AREA AFFECTED BY THE WORK.
- CONTRACTOR TO VERIFY ALL EXISTING CONDITIONS AND SHALL NOTIFY THE ENGINEER OF ANY DISCREPANCIES WITH THE CONTRACT DOCUMENTS BEFORE COMMENCING ANY WORK.
- VERIFY EXISTING SANITARY AND GREASE DRAIN INVERTS/DEPTHS PRIOR TO START OF WORK. IF SANITARY AND GREASE INVERTS/DEPTHS ARE NOT DEEP ENOUGH TO INSTALL THE GREASE TRAP AND RECONNECT TO THE EXISTING SANITARY DRAIN INSIDE THE BUILDING, NOTIFY THE ARCHITECT IMMEDIATELY.
- SLEEVE AND SEAL ALL PIPE PENETRATIONS OF WALLS AND FLOORS. APPLY INTUMESCENT FIRE SAFING COMPOUND AT PENETRATIONS OF FIRE-RATED WALLS AND FLOORS, MAINTAINING INTEGRITY AND RATING OF FIRE SEPARATION. SLEEVES THROUGH FLOORS SHALL EXTEND 2" ABOVE FLOOR, BE GROUTED INTO PLACE AND WATERPROOFED. PIPING THROUGH EXTERIOR WALLS SHALL BE SLEEVED AND SEALED HEATHER TIGHT WITH SILICONE CAULK.
- ALL DOMESTIC COLD, HOT AND TEMPERED WATER PIPING TO BE INSULATED WITH RIGID FIBERGLASS INSULATION WITH TYPE 'ASJ' JACKET. COLD WATER PIPES TO HAVE 1/2" THICK INSULATION. DOMESTIC HOT AND TEMPERED WATER PIPES TO HAVE 1" THICK INSULATION. INSULATE SANITARY WASTE AND GREASE PIPING ABOVE OCCUPIED SPACES AND IN CEILING CAVITIES WITH 1/2" FIBERGLASS INSULATION WITH TYPE 'ASJ' JACKET.
- CONTRACTOR SHALL VERIFY ALL VOLTAGE AND POWER REQUIREMENTS AND COORDINATE WITH ELECTRICAL CONTRACTOR.
- THE CONTRACTOR SHALL LOCATE ALL EQUIPMENT WHICH MUST BE SERVICED, OPERATED OR MAINTAINED IN FULLY ACCESSIBLE POSITION. EQUIPMENT SHALL INCLUDE, BUT NOT BE LIMITED TO, VALVES, TRAPS, CLEAN OUTS, MOTORS, CONTROLLERS, DRAIN POINTS, ETC. IF REQUIRED FOR ACCESSIBILITY. FURNISH ACCESS DOORS FOR THIS PURPOSE. MINOR DEVIATIONS FROM THE DRAWINGS MAY BE MADE TO ALLOW FOR BETTER ACCESSIBILITY, AND ANY CHANGE FOR THAT PURPOSE SHALL BE SUBMITTED FOR APPROVAL AND FIELD DOCUMENTED ON REDLINE DRAWING PRINTS.
- LAYOUT SHOWN IS DIAGRAMMATIC. THE CONTRACTOR IS RESPONSIBLE FOR REVIEWING THE ARCHITECTURAL, CIVIL, STRUCTURAL, MECHANICAL & ELECTRICAL DRAWINGS TO ENSURE ALL PLUMBING WORK IS PROVIDED TO FACILITATE PLUMBING SERVICES FOR ALL EQUIPMENT PROVIDED ON THE PROJECT, NEW OR EXISTING TO REMAIN. PROVIDE NECESSARY OFFSETS, RISERS, AND PIPING TO COORDINATE WITH THE BUILDING STRUCTURE AND THE WORK OF OTHER TRADES.
- CONTRACTOR IS RESPONSIBLE FOR COORDINATING ALL UNDER-SLAB PLUMBING WITH THE STRUCTURAL, FRAMING DRAWINGS, STRUCTURAL FOUNDATION DRAWINGS, GRADE BEAMS, THICKENED SLABS, AND ALL FOOTINGS.
- NO PLUMBING PIPING IS ALLOWED IN AN EXTERIOR WALL. THE CONTRACTOR SHALL NOTIFY THE ARCHITECT IF CHASE SPACE IS INADEQUATE OR IF FIXTURES ARE LOCATED ON OUTSIDE WALLS. ROUTE ALL PIPING ON HARM SIDE OF BUILDING INSULATION.
- THE P.C. IS TO INSPECT THE EXISTING SANITARY DRAIN TO VERIFY THAT IT HAS SUFFICIENT DEPTH FOR THE NEW WORK AND TO VERIFY THE DIRECTION OF FLOW. PRESSURE TEST THE EXISTING SANITARY DRAIN PRIOR TO THE START OF WORK. VERIFY THAT SEWER IS ACTIVE BY FLUSHING WITH WATER, A MINIMUM OF FIVE (5) GALLONS PER MINUTE FOR FOUR (4) HOURS PRIOR TO START OF WORK.

QUICK CONNECT FITTING SCHEDULE

SYMBOL	TYPE	QTY	DESCRIPTION	MODEL	SIZE AND CONNECTION	LOCATION	MANUFACTURER	CATALOG SERIES	REMARKS
	A	0	UNION ELBOW	1017B-04	1/4" OD	REFER TO PLAN	WATTS	QUICK-CONNECT SERIES 10	1, 2, 3 & 4
	B	2	REDUCING ELBOW	1017RB-0604	3/8" OD X 1/4" OD	REFER TO PLAN	WATTS	QUICK-CONNECT SERIES 10	1, 2, 3 & 4
	C	1	UNION TEE	1023B-06	3/8" OD	REFER TO PLAN	WATTS	QUICK-CONNECT SERIES 10	1, 2, 3 & 4
	D	1	REDUCING TEE	1024RB-060604	3/8"OD X 3/8"OD X 1/4"OD	REFER TO PLAN	WATTS	QUICK-CONNECT SERIES 10	1, 2, 3 & 4
	E	3	UNION STOP VALVE	1039B-04	1/4" OD	REFER TO PLAN	WATTS	QUICK-CONNECT SERIES 10	1, 2, 3, 4 & 5
	-	-	WATERPEX TUBING	WPTC04-100W WPTC06-100W	1/4" ID X 3/8" OD 3/8" ID X 1/2" OD	REFER TO PLAN	WATTS	WHITE COILS	1, 2, & 4

- REMARKS:**
- FURNISHED AND INSTALLED BY CONTRACTOR.
 - REFER TO PLAN FOR WATERPEX TUBE SIZE.
 - VERIFY ALL FITTING SIZES AND QUANTITY PRIOR TO ORDER AND INSTALLATION.
 - EQUAL BY JOHN GUEST.
 - UNION STOP VALVE SIZE TO BE VERIFIED WITH KEURIG INSTALLATION CUT SHEET PRIOR TO START OF WORK.
- NOTE:**
P.C. TO VERIFY FINAL FITTING COUNTS PRIOR TO BID AND ORDERING EQUIPMENT. VERIFY ALL QUANTITIES OF NEW FITTINGS.

IGI
INTEGRATED GRAPHICS & IMAGING

BEYOND
Beyond any store of its kind.

BED BATH & BEYOND
CORPORATE OFFICES:
650 LIBERTY AVE
UNION, NJ 07083
(908) 688-0888 (OFFICE)
(908) 688-0285 (FAX)

PROJECT NAME & LOCATION:
103 ALPHARETTA, GA
6050 NORTH POINT PARKWAY
ALPHARETTA, GA 30022

REVISION	DATE
OWNER REVIEW	09/13/18
PERMIT SET	09/25/18

ARCH. PROJECT # : _____

DRAWN BY : DC

CHECKED BY : JJ

DRAWING TITLE:

P1.1