



25 INTO ATE NOR PKV

### SPECIFICATIONS

#### SECTION 220100 - PLUMBING GENERAL:

:RAL

- CONTRACTOR SHALL PROVIDE ALL MATERIALS, EQUIPMENT, TOOLS AND LABOR NECESSARY TO PROVIDE A COMPLETE PLUMBING SYSTEM COMPLIANT WITH ALL REQUIRED CODES & STANDARDS.
- 2. DRAWINGS ARE SCHEMATIC IN NATURE AND SHALL NOT BE SCALED.
- ALL REQUIRED PERMITS & INSPECTIONS SHALL BE SECURED & PAID FOR UNDER THIS CONTRACT. INSPECTION CERTIFICATIONS SHALL BE PROVIDED TO THE OWNER.

#### C. IDENTIFICATION

 PERMANENT BAKELITE TAGS WITH 1\* TALL LETTERS SHALL BE PROVIDED FOR ALL EQUIPMENT. EQUIPMENT NUMBER SHALL MATCH BUILDING STANDARDS.

# SHALL M

- 1. ALL MOTORS SHALL BE PROVIDED WITH MAGNETIC MOTOR STARTERS WITH OVERLOAD PRO
- 2. STARTERS SHALL BE PROVIDED WITH HAND-OFF-AUTO SWITCHES.
- 3. INDOOR MOTOR STARTERS SHALL BE FURNISHED WITHIN A NEMA 1 ENCLOSURE.
- 4. OUTDOOR MOTOR STARTERS SHALL BE FURNISHED WITHIN A NEMA 3R ENCLOSURE

### E. SUBMITTALS & SHOP DRAWINGS

CONTRACTOR SHALL SUBMIT SHOP DRAWINGS & PRODUCT ATA FOR ALL PLUMBING EQUIPMENT ASTEMS TO PROVIDED AND/OR INSTALLED.

#### E SUBSTITUTE MANUFACTURERS

- CONTRACTOR SHALL BE RESPONDIBLE FOR COORDINATION & COURSE ALL CHANGES RESPONDED FOR INSTALLATION OF
- 2. CAREFULLY TOWATE SUBSTITION TE MANUFACTURER'S INSTALLATION SHE MENTS WITH ALL OTHER TRADES INCLUDE A SULTIMIZED TO SIDICTURE, ELECTRICAL, PLUMBING CHIEFCTURAL, ALL INSTALLATION COSUSTATION AND ALL OWN AND AL
- ASSOCIATED IN THE SUBSTITUTE MANUFACTURER SIZE TO ENCLUDED IN BID. NO ALLOWANCES SHA

  GIVEN FOR CH.

  SOCIATE WITH INSTALLATION SUBSTITUTE EQUIPMENT & SYSTEM

  OF ALLATION OF SUBSTITUTE FOR THE STATE OF THE STATE OF

# Co. OCIATED V TH CHA. UIRED TO OTHER TRADES.

#### G. WARRANTT

1. CONTRACTOR SHOULD RRANT ALL EQUIPMENT, MATERIALS AND WORKMANSHIP FOR A PERIOD OF NOT LESS THAN ONE

ALL HVAC COMPRESSORS SHALL BE WARRANTED FOR A PERIOD OF NOT LESS THAN 5 YEARS

### AS-BUILT DRAWA

1. CONTRACTOR SHALL KEEP REDLINE SET OF DRAWINGS ON SITE DURING CONSTRUCTION TO UPDATE LOCATION OF ALL EQUIPMENT AND SYSTEMS AS THE CONSTRUCTION PROGRESSES. REDLINE SET OF DRAWINGS SHALL BE TURNED OVER TO OWNER AT COMMETION OF CONSTRUCTION.

# I. OPERATION & MAINTENANCE MANUALS

 CONTRACTOR SHALL PROVIDE AN ELECTRONIC SET AND ONE (1) SET OF HARD COPIES OF INSTALLATION AND MAINTENANCE MANUALS FOR ALL EQUIPMENT & SYSTEMS PROVIDED UNDER THIS CONTRACT.

# J. INSTRUCTION

 CONTRACTOR SHALL THOROUGHLY INSTRUCT OWNER ON OPERATION AND RECOMMENDED MAINTENANCE PROCEDURES OF ALL INSTALLED EQUIPMENT & SYSTEMS.

## SECTION 24000 PLUMBING SYSTEMS

- A. ALL SANITARY PIPING SHALL BE SLOPED AT 1/8" PER FOOT
- B. SANITARY & STORM PIPING SHALL BE SCHEDULE 40 PVC BELOW GRADE.
- C. SANITARY, STORM & VENT PIPING SHALL BE HUBLESS CAST IRON ABOVE GRADE.
- D. DOMESTIC WATER & CONDENSATE PIPING SHALL BE TYPE L HARD COPPER WITH LEAD FREE SOLDERED JOINTS. CONDENSATE PIPING SHALL BE INSTALLED WITH DWY TYP FITTINGS.
  E. ALL CONDENSATE, HOT & COLD WATER PIPING SHALL BE INSULATED WITH 1/2" THICK FIBERGLASS INSULATION WITH WHITE ALL SERVICE JACKET.
- F. WATER HAMMER ARRESTORS SHALL BE PROVIDED & SIZED PER PDI GUIDELINES AT ALL QUICK CLOSING VALVES. ALL PIPING SHALL BE PRESSURE TESTED PRIOR TO CONCEALING OR INSULATING THE PIPING.
- G. ALL PIPING SHALL BE CONCEALED WITHIN WALLS OR ABOVE CEILING.
- G. ALL PIPING SHALL BE CONCEALED WITHIN WALLS OR ABOVE CEILING.

  H. PIPING INSTALLED ABOVE CEILING SHALL BE INSTALLED AS HIGH AS POSSIBLE
- ALL VALVES LOCATED ABOVE CEILING SHALL BE LOCATED WITHIN 1' OF ACCESS PANEL OR 1' ACCESSIBLE CEILING.
- J. REFER TO ARCHITECTURAL FLOOR PLANS & ELEVATIONS FOR EXACT LOCATIONS OF PLUMBING FIXTURES.
- K. PLUMBING SYSTEMS SHALL NOT BE INSTALLED WITHIN OR PASSING THROUGH, ELECTRICAL CLOSETS, SWITCHGEAR ROOMS, TELEPHONE ROOMS, ELEVATOR EQUIPMENT ROOMS OR ABOVE ELECTRICAL PANELS.
- L. INSTALL IDENTIFICATION MARKERS ON ALL PIPING SYSTEMS & VALVES THAT INCLUDE SERVICE TYPE & DIRECTION OF FLOW PER ASME A13.1.
- M. ALL DOMESTIC WATER PPING SYSTEMS SHALL BE FLUSHED & DISINFECTED. SYSTEMS SHALL BE FLLED WITH AN EVENLY DISTRIBUTED DOSE OF 510 200 PPIN CHLORIE. ALL FIXTURES & OUTLETS SHALL BE TESTED TO ENSURE EVEN DISTRIBUTION. AFTER 12 HOURS THE RESIDUAL CHIORIES SHALL BE STEED. DISINFECTION PROCEQUINE SHALL BE REPEATED UNTIL RESIDUAL CHIORIES EVEN LE GREATER THAN 10 PPIN AFTER SITTING WINDISTRIBED FOR 12 HOURS. ONCE DISINFECTION PROCEQUINE SCOWNETE. SYSTEM SHALL BE THOOGHOUTH Y LURSHOW WITH CLEAN WATER.

#### SECTION 21525 FIRE PROTECTION SYSTEMS

- A. FIRE PROTECTION SYSTEM SHALL BE DESIGNED BY A LICENSED FIRE TO THE OWN OF THE PROTECTION CON
- B. FIRE PROTECTION SYSTEM SHALL CONFORM TO NEW ALL CODE REQUIREMENTS.
- C. FIRE PROTECTION SYSTEM DESIGN SHALL STANFACT TO THE PROVADE ARSHALL AND THE OWNER
- D. DOUBLE CHECK BACKELOW DO AGED SHALL WASTES 700 OF
- PING 2" AND LARGER SHALL BE SAMEULE 10 WITH ALL GROOMED VICTAU
- F. SON G SMALLER THAN 2" SHALL BE SON BULE 40 STEE SON THE THREADED JOINTS AND MALIABLE IRON FITTINGS
- 6. THE OF LIGHTWALL PIPING SUCH AS 100 ML / BLT, IS NOT ACCEPTABLE.
- H. SPRING HEADS LOCATED IN A Y-IN COLINGS SHALL BE SEMI-RECESSED CHROME PLATED.
- SPRINKE THAT SADS LOCATED AND CELLINGS SHALL BE FULLY RECESSED WITH COVER MATCHING THE COLOR OF THE CELLING.
- AREAS WITH WHITE INGS SHALL HAVE UPRIGHT, BRASS HEADS
- RE PROTECTION SYSTEM SHALL BE TESTED PRIOR TO OWNER ACCEPTANCE.

RENOVATIONS
TO
THE FLOYD COUNTY JAIL
2526 NEW CALHOUN HIGHWAY N.E.
ROME, GEORGIA 30161



DATE	REVISION	
		_
		_
		_
	+	
	1	

PROJECT NO:
420.03.01

DATE:
MAY 18, 2018

DRAWING TITLE:
SPECIFICATIONS - PLUMBING

P0.02

THIS DRAWING AND ANY REPRODUCTIONS
ARE THE PROPERTY AND COPYRIGHT OF
PEACOCK ARCHITECTS, INC. AND MAY
NOT BE USED IN ANY MANNER WITHOUT
THE EXPRESSED WITTEN PERMISSION

