

# J. ROY ROWLAND FEDERAL COURTHOUSE FIRE SPRINKLER SYSTEM UPGRADE

100 FRANKLIN STREET  
DUBLIN, GEORGIA 31021


DRAWING INDEX		
FP-1	COVER SHEET	0 3/7/2018
FP-2	FIRE SPRINKLER DESIGN CRITERIA	0 3/7/2018
FP-3	FIRE SPRINKLER SITE PLAN	0 3/7/2018
FP-4	BASEMENT FIRE SPRINKLER LAYOUT	0 3/7/2018
FP-5	1ST FLOOR FIRE SPRINKLER LAYOUT	0 3/7/2018
FP-6	2ND FLOOR FIRE SPRINKLER LAYOUT	0 3/7/2018
FP-7	FIRE SPRINKLER DETAILS	0 3/7/2018
FP-8	FIRE SPRINKLER PHOTOGRAPHS	0 3/7/2018
FA-1	FIRE ALARM DESIGN CRITERIA	0 3/7/2018
FA-2	BASEMENT - PARTIAL FIRE ALARM LAYOUT	0 3/7/2018
FA-3	1ST FLOOR - PARTIAL FIRE ALARM LAYOUT	0 3/7/2018
FA-4	2nd FLOOR - PARTIAL FIRE ALARM LAYOUT	0 3/7/2018
FA-5	FIRE ALARM PHOTOGRAPHS	0 3/7/2018
C100	CIVIL PLAN-EXISTING SURVEY	0 3/7/2018
C200	UTILITY PLAN-EXTERIOR POTABLE WATER	0 3/7/2018
C300	UTILITY PLAN-INTERIOR FIRE SUPPLY	0 3/7/2018
C400	UTILITY PLAN-CIVIL DETAILS	0 3/7/2018
M100	MECHANICAL DETAILS	0 3/7/2018
E100	ELECTRICAL DETAILS	0 3/7/2018

ALL WORK MUST BE PERFORMED IN COMPLIANCE WITH THE FOLLOWING APPLICABLE LOCAL, STATE & NFPA CODES, AS WELL AS APPLICABLE GSA AND CITY OF DUBLIN LOCAL ORDINANCES:


- IBC 2015 INTERNATIONAL BUILDING CODE
- IFC 2015 INTERNATIONAL FIRE CODE
- IPC 2015 INTERNATIONAL PLUMBING CODE
- ANSI/ASME 2015 EDITION OF ANSI AND ASME STANDARDS
- NFPA 13 STANDARD FOR THE INSTALLATION OF SPRINKLER SYSTEMS, 2013 EDITION
- NFPA 24 STANDARD FOR THE INSTALLATION OF PRIVATE FIRE SERVICE MAINS AND THEIR APPURTENANCES, 2013 EDITION
- NFPA 70 NATIONAL ELECTRIC CODE, 2014 EDITION
- NFPA 72 NATIONAL FIRE ALARM AND SIGNALING CODE, 2013 EDITION
- PBS-P100 GSA - FACILITIES STANDARDS FOR THE PUBLIC BUILDINGS SERVICE, ISSUED MARCH 2015




MARCH 7, 2018  
100% DRAWINGS  
APPROVED FOR CONSTRUCTION



GENERAL SERVICES ADMINISTRATION  
PUBLIC BUILDING SERVICE  
DESIGN & CONSTRUCTION DIVISION  
77 FORSYTH STREET, SUITE 64  
ATLANTA, GA 30303




NEPTUNE  
FIRE PROTECTION ENGINEERING LLC  
John Orville, P.E., GA License #PD042893  
80 Ocean Blvd., Ste. 6  
Atlantic Beach, FL 32233  
(904) 650-0000 PHONE




AKEA INC.  
3603 NW 98th Street, STE B  
Gainesville, FL 32606  
Phone: (352) 474-6124  
COA: FL #26693

KEY PLAN



PROFESSIONAL SEAL



REVISION NUMBER	REVISION DESCRIPTION	REVISION DATE

CONTRACT NO.	GS-04P-16-EX-C-7070
CONSTRUCTION NO.	EQ4PC1-16-5002
PRIME A/E	AKEA, INC.
ADDRESS	3603 NW 98TH STREET GAINESVILLE FL 32606
PRIME A/E	JAMEY CLAYTON
SUB A/E	NEPTUNE FIRE PROTECTION ENG. LLC
ADDRESS	80 OCEAN BLVD., STE. 6 ATLANTIC BEACH FL 32233
SUB A/E	
ADDRESS	
NAME	J. ROY ROWLAND CT
ADDRESS	300 NORTH FRANKLIN ST. DUBLIN GA 31021
BLDG NO.	GAD0336ZZ
ADDT. FACILITY	
TITLE	INSTALL FIRE SPRINKLER SYSTEM
DESCRIPTION	DESIGN-BUILD (DB) FIRE SPRINKLER SYSTEM
PERMISSION	100% DRAWINGS SUB. DATE 3/07/2018
PROJ. MGR.	MICHAEL POPE
SEAL ENCL.	ARNOLD J. HEDDT, III
PROJ. NO.	VGA00038 / EQ4PC1-16-5002
DRAWN BY	CEG DATE DRAWN 3/06/2018
CHKD BY	NJO DATE CHKD 3/06/2018
FILE NAME	FP_DRAWINGS.DWG
FLOOR NO.	N/A
TITLE	COVER SHEET
NUMBER	1 of 20
DISCIPLINE	
SHEET TYPE	
SEQUENCE	

Order Plans @ WWW.IDLINE.COM