VARIABLE REFRIGERANT FLOW MULTI-SPLIT SYSTEM HEAT PUMP UNITS

MANUFACTURER	CARRIER											
HEAT PUMP UNITS												
HEAT PUMP UNIT IDENTIFICATION TAG	HPV-1	HPV-2										
UNIT SIZE DESIGNATION	(240)	(216)										
HEAT PUMP MODEL NUMBER (PURY-)	38VMA240	38VMA216										
TOTAL CAPACITY (BTUH)	240,000	216,000										
OUTSIDE AMBIENT TEMPERATURE (°F)	95	95										
MIN. IEER AT AHRI CONDITIONS	18	18										
REFRIGERANT LINE SIZE LIQUID/SUCTION	1-1/8" / 1-3/8"	1-1/8" / 1-1/8"										
HEAT PUMP OUTPUT (BTUH)	270,000	243,000										
OUTSIDE AMBIENT TEMPERATURE (°F)	47	47										
HEAT PUMP OUTPUT (BTUH)	201,000	180,000										
OUTSIDE AMBIENT TEMPERATURE (°F)	17	17										
BC CONTROLLER												
UNIT DESIGNATION	BC-1-1	BC-1-2	BC-2									
CONTROLLER MODEL NUMBER	40VMD16ML	40VMD06S	40VMD16ML									
NUMBER OF BRANCHES	16	6	16									
NUMBER OF ACTIVE BRANCHES	11	6	16									
UNIT SIZE DESIGNATION	F08C	F12C	F15C	F18C	F24C	F12	F18	F24	F30	F36		
FAN COIL MODEL NUMBER	PLFY-P08NCMU-E	PLFY-P12NCMU-E	PLFY-P15NCMU-E	PLFY-P18NBMU-E	PLFY-P24NBMU-E	PEFY-P12NMAU-E	PEFY-P18NMAU-E	PEFY-P24NMAU-E	PEFY-P30NMAU-E	PEFY-P36NMAU-E		
FAN COIL TYPE	SQUARE CASSETTE	SQUARE CASSETTE	SQUARE CASSETTE	SQUARE CASSETTE	SQUARE CASSETTE	MED PRESS FAN COIL	MED PRESS FAN COIL	MED PRESS FAN COIL	MED PRESS FAN COIL	MED PRESS FAN COIL		
FAN-COIL MAX CABINET SIZE (INCHES)	22x22	22x22	22x22	33x33	33x33							
SUPPLY AIR (CFM)	320	350	390	560	630	400	600	800	1000	1200		
EXTERNAL STATIC PRESSURE ("H_2O)	---	---	---	---	---	35	35	35	35	35		
TOTAL COOLING CAPACITY (BTUH)	8,000	12,000	15,000	18,000	24,000	12,000	18,000	24,000	30,000	36,000		
ENTERING AIR TEMPERATURE DB/WB (°F)	80/67	80/67	80/67	80/67	80/67	80/67	80/67	80/67	80/67	80/67		
REFRIGERANT LINE SIZE LIQUID/SUCTION	1/4" / 1/2"	1/4" / 1/2"	1/4" / 1/2"	1/4" / 1/2"	3/8" / 5/8"	1/4" / 1/2"	1/4" / 1/2"	1/4" / 1/2"	3/8" / 5/8"	3/8" / 5/8"		
HEAT OUTPUT (BTUH)	9,000	13,500	17,000	20,000	27,000	13,500	20,000	27,000	34,000	40,000		
ENTERING AIR TEMPERATURE (°F)	70	70	70	70	70	70	70	70	70	70		
WALL-MOUNTED HARD-WIRED CONTROLLER	SIMPLE MA	SIMPLE MA	SIMPLE MA	SIMPLE MA	SIMPLE MA	SIMPLE MA	SIMPLE MA	SIMPLE MA	SIMPLE MA	SIMPLE MA		
PAC-TISAD ADAPTER FOR EMS START/STOP	YES	YES	YES	YES	YES	YES	YES	YES	YES	YES		
BUILT-IN CONDENSATE LIFT MECHANISM	YES	YES	YES	YES	YES	YES	YES	YES	YES	YES		
OUTSIDE AIR DUCT CONNECTION	YES	YES	YES	YES	YES	NO	NO	NO	NO	NO		
FILTER BOX WITH 2" FILTERS	NO	NO	NO	NO	NO	YES	YES	YES	YES	YES		
CENTRALIZED CONTROLLER BACNET												

NOTES:
1. PROVIDE TWINNING KIT FOR PAIRED SYSTEMS.
2. FURNISH FILER BOX WITH ACCES DOOR IN THE BOTTOM SIMILAR TO WATER SOURCE HEAT PUMPS.

DUCTLESS SPLIT COOLING UNIT

UNIT DESIGNATION	FC12 / CU12	FC30 / CU30
MANUFACTURER	MITSUBISHI	MITSUBISHI
FAN-COIL UNIT MODEL NUMBER	PKA-A12KA/L	PKA-A30KA/L
CONDENSING UNIT MODEL NUMBER	PUY-A12NHA	PUY-A30NHA
SUPPLY FAN PERFORMANCE		
SUPPLY AIR (CFM)	425	705
EXTERNAL STATIC PRESSURE (" H_2O)	---	---
COOLING PERFORMANCE		
TOTAL CAPACITY (BTUH)	12,000	30,000
ENTERING AIR TEMPERATURE DB/WB (°F)	80/67	80/67
OUTSIDE AMBIENT TEMPERATURE (°F)	95	95
MIN. SEER AT ARI CONDITIONS	13.8	13.0
REFRIGERANT LINE SIZE LIQUID/SUCTION	1/4" / 1/2"	1/2" / 3/4"
ACCESSORIES		
WALL-MOUNTED, HARD-WIRED CONTROLLER	YES	YES
PAC-TISAD ADAPTER FOR EMS START/STOP	YES	YES
LOW AMBIENT CONTROL, CRANKCASE HEATER	YES	YES
SNAP-ON LINESET COVERS	YES	YES
CONDENSATE PUMP		
GP-1, 60 GPH @ 5', WITH SAFETY SWITCH		HARTELL KT15

DUCTLESS SPLIT SYSTEM HEAT PUMP UNITS

UNIT DESIGNATION	FGH / HP18	FGH12 / HP12
MANUFACTURER	MITSUBISHI	MITSUBISHI
FAN-COIL UNIT MODEL NUMBER	PLA-A18BA	PKA-KA12NA
HEAT PUMP MODEL NUMBER	PUZ-A18NHA3	SUZ-KA12NA
SUPPLY FAN PERFORMANCE		
SUPPLY AIR (CFM)		425
EXTERNAL STATIC PRESSURE (" H_2O)	---	---
COOLING PERFORMANCE		
TOTAL CAPACITY (BTUH)	18,000	12,000
ENTERING AIR TEMPERATURE DB/WB (°F)	80/67	80/67
OUTSIDE AMBIENT TEMPERATURE (°F)	95	95
MIN. SEER AT ARI CONDITIONS	18	10
REFRIGERANT LINE SIZE LIQUID/SUCTION	1/4" / 1/2"	1/4" / 3/8"
HEATING PERFORMANCE		
HEAT PUMP OUTPUT (BTUH)	19,000	13,600
ENTERING AIR TEMPERATURE (°F)	70	70
OUTSIDE AMBIENT TEMPERATURE (°F)	47	47
ACCESSORIES		
WALL-MOUNTED, HARD-WIRED CONTROLLER	YES	YES
PAC-TISAD ADAPTER FOR EMS START/STOP	YES	YES
INTEGRAL CONDENSATE PUMP	YES	YES

CONDENSATE PUMPS

PUMP DESIG.	SERVICE	GPM	HEAD FT H_2O	PUMP EFF.	HP	RPM	MIN. GPM	TYPE	MANUFACTURER & MODEL NUMBER
CP-1	CONDENSATE PUMP	45	6	--	--	--	--	WALL MOUNTED	LITTLE GIANT VCMA-20

EXHAUST FANS

FAN DESIG.	TYPE	CFM	EXT. S.P. "H O	MOTOR POWER	DRIVE TYPE	MAX. RPM	MAX. SONES	MANUFACTURER & MODEL NO.	CONTROL SEQUENCE
EF-1	POWER ROOF VENTILATOR	1800	.125	1/3 HP	DIRECT	1300	10.0	PENN DX165	EMS
EF-2	POWER ROOF VENTILATOR	300	.25	1/11 HP	DIRECT	1300	6.0	PENN DX115	EMS
EF-3	AIR DOOR	3550	-	1/2 HP	DIRECT	1750	-	POWERED AIRE ADE-1-60	SM ①
EF-4	24" OSCILLATING WALL MOUNTED	5400 (LOW)	-	1/4 HP	DIRECT	1100 2 SPEED	-	[illegible]	SM ②
EF-5	POWER ROOF VENTILATOR	600	.25	1/12 HP	DIRECT	[illegible]	5.0	PE[illegible]	EMS
EF-6	POWER ROOF VENTILATOR	300	.25	1/11 HP	DIRECT	1300	[illegible]	PENN DX115	EMST
EF-7	POWER ROOF VENTILATOR	200	.25	1/2HP	DIRECT	1550	6.0	PENN DX10R	SM
EF-8	POWER ROOF VENTILATOR	500	.25	[illegible]	DIRECT	1550	6.0	PENN DX10R	SM
EF-9	CEILING MOUNTED	[illegible]	.20	80	DIRECT	1050	9.0	PENN ZB15	EMST

① PROVIDE STAINLESS STEEL CABINET AND MAGNETIC REED SWITCH ON DOOR JAM.
② MOUNT TOP OF GUARD 4" BELOW CEILING.

UTILITY DISTRIBUTION SYSTEM

DESIGNATION	UDS-1	
MANUFACTURER	DUO AIRE	
ELECTRICAL		
480V-3Ø-3 WIRE		
CONNECTED LOAD		
SPARE CAPACITY		
MAIN BREAKER		
208Y/120V-3Ø-4 WIRE		
CONNECTED LOAD		
SPARE CAPACITY		
MAIN BREAKER		
PLUMBING		
CONNECTED LOAD	750 CFH	
GAS PIPE SIZE	2"	
COLD WATER PIPE SIZE	3/4"	
HOT WATER PIPE SIZE	3/4"	

SEE KITCHEN EQUIPMENT DRAWINGS FOR REQUIREMENTS & ACTUAL LOAD OF EACH INDIVIDUAL PIECE OF EQUIPMENT.

RANGE HOOD

DESIGNATION	RH-1	
MANUFACTURER	DUO-AIRE	
MODEL NUMBER	I-192-III	
LENGTH X WIDTH	16' x 13'	
STYLE	ISLAND	
SERVICE	RANGE / OVEN	
NFPA 17A, FIRE SUPPRESSION SYSTEM	YES	
VAPORPROOF LIGHTS	YES	
CONTROL PANEL LOCATION	UDS	
EXHAUST FAN		
FAN DESIGNATION	REF-1	
EXHAUST AIR (CFM)	2 @ 4,000	
MOTOR HORSEPOWER	2	
SUPPLY FAN		
FAN DESIGNATION	RSF-1	
SUPPLY AIR (CFM)	2 @ 3360	
MOTOR HORSEPOWER	2	

ELECTRIC UNIT HEATERS

HEATER DESIG.	TYPE MOUNTING	kW / V / Ph.	MANUFACTURER & MODEL NUMBER	ACCESSORIES
EH-1	RECESSED CEILING MOUNTED	3 / 277V / 1Ø	QMARK CDE	INTEGRAL DISCONNECT, 24V CONTROL TRANSFORMER & RELAY
EH-2	CEILING SUSPENDED BOTTOM 8' AFF	3.3 / [illegible] / 1Ø	QMARK MUH	INTEGRAL DISCONNECT, 24V CONTROL TRANSFORMER & RELAY, WALL/CLG. BRACKET
EH-3	SURFACE WALL MOUNTED	[illegible] / 277 / 1	[illegible] AW	SURFACE BOX, 16 GA. GRILLE INTEGRAL T'STAT, DISCONNECT

AIR DISTRIBUTION DEVICES

MARK	TYPE	NOMINAL SIZE	NECK SIZE	BRANCH DUCT SIZE	SERVICE
		9 x 9	6"Ø	6"Ø - FLEX, MAX. 5' LONG	SUPPLY
A	CD	9 x 9	6"Ø	6"Ø - FLEX, MAX. 5' LONG	SUPPLY
B	LGD	12 x 12	8"Ø	8"Ø - FLEX, MAX. 5' LONG	SUPPLY
BB	CD	12 x 12	8"Ø	8"Ø - FLEX, MAX. 5' LONG	SUPPLY
C	LGD	12 x 12	10"Ø	10"Ø - FLEX, MAX. 5' LONG	SUPPLY
D	LGD	15 x 15	12"Ø	12"Ø - FLEX, MAX. 5' LONG	SUPPLY
E	LGG	24 x 24	22 x 22	-	RETURN
EE	GG	24 x 24	22 x 22	-	RETURN
F	LGG	24 x 14	22 x 12	-	RETURN
G	GG	14 x 14	14 x 14	-	RETURN
H	GR	8 x 8	6"Ø	6"Ø - FLEX, MAX. 5' LONG	EXHAUST
J	GR	10 x 10	8"Ø	8"Ø - FLEX, MAX. 5' LONG	EXHAUST
K	GR	12 x 12	10"Ø	10"Ø - FLEX, MAX. 5' LONG	EXHAUST
L	LBG	48 x 5	48 x 5	-	SUPPLY
M	TR	16 x 8	16 x 8	-	SUPPLY
N	TG	16 x 8	16 x 8	-	RETURN
O	OBD	DUCT SIZE	SEE PLANS	-	SUPPLY
P	TR	16 x 6	16 x 6	-	SUPPLY
Q	LBG	78 x 16	78 x 16	-	RETURN
R	LBG	48 x 3	48 x 3	-	SUPPLY
S	LBG	48 x 8	48 x 8	-	RETURN

NOTE: DESIGNATIONS FOR TYPE 'A' THROUGH 'D' FOLLOWED BY A NUMBER INDICATES THROW OTHER THAN 4-WAY. (I.E. "A3" IS THREE-WAY THROW).

AIR DISTRIBUTION DEVICES LEGEND

SYMBOL	DESCRIPTION	FINISH
LGD	LAY-IN CEILING SUPPLY DIFFUSER - KRUEGER 35H, SQUARE LOUVERED FACE ALUMINUM DIFFUSER WITH 24"x24" LAY-IN FRAME. DIFFUSER SHALL BE FOUR WAY THROW UNLESS OTHERWISE NOTED ON PLANS.	WHITE ANODIC ACRYLIC
CD	CEILING SUPPLY DIFFUSER - KRUEGER 35H, SQUARE LOUVERED FACE ALUMINUM DIFFUSER WITH OPPOSED BLADE DAMPER & FLAT SURFACE MOUNT FRAME. DIFFUSER SHALL BE FOUR WAY THROW UNLESS OTHERWISE NOTED ON PLANS.	WHITE ANODIC ACRYLIC
LGG	LAY-IN CEILING RETURN GRILLE - KRUEGER 66GS, ALUMINUM EGGCRATE GRILLE, 1/2"x1/2"x1/2" GRID CORE WITH 24"x24" LAY-IN FRAME AND DUCT CONNECTION FLANGE.	WHITE ANODIC ACRYLIC
GG	CEILING RETURN GRILLE - KRUEGER 66GS, ALUMINUM EGGCRATE GRILLE, 1/2"x1/2"x1/2" CORE AND FLAT SURFACE MOUNT FRAME.	WHITE ANODIC ACRYLIC
GR	CEILING EXHAUST REGISTER - KRUEGER 66GS, ALUMINUM EGGCRATE GRILLE, 1/2"x1/2"x1/2" CORE, OPPOSED BLADE VOLUME DAMPER AND FLAT SURFACE MOUNT FRAME.	WHITE ANODIC ACRYLIC
LBG	SIDEWALL LINEAR BAR DIFFUSER - KRUEGER 1600, ALUMINUM BAR GRILLE WITH 1/8" BARS AT 1/2" BLADE SPACING, 0° DEFLECTION, CONCEALED MOUNTING & 1" FLAT FRAME.	SELECTED BY ARCH.
OBD	OPPOSED BLADE VOLUME DAMPER - KRUEGER OBD2M STEEL OPPOSED BLADE DAMPER FOR SQUARE DUCT, PRDIO FOR ROUND DUCT, OR SPIN-IN FITTING WITH DAMPER, SEE PLANS.	MILL
TG	HIGH SIDEWALL RETURN GRILLE - KRUEGER 580H, GRILLE WITH HORIZONTAL ANGLE ALUMINUM BLADES SPACED 1/2" @ 35° UP, FLAT ALUMINUM FRAME.	SELECTED BY ARCH.
TR	HIGH SIDEWALL SUPPLY REGISTER - KRUEGER 580S, DOUBLE DEFLECTION ALUMINUM REGISTER WITH REVERSIBLE CORE AIMED 15 DEGREES DOWN, REAR BLADES, AND CURVED FRAME. OMIT REAR BLADES IN RETURN.	WHITE ANODIC ACRYLIC

NOTE: MANUFACTURER SHALL FURNISH FINISHED SCREWS FOR ALL AIR DISTRIBUTION DEVICES TO MATCH FINISH OF THAT DEVICE.

Order Plans @ WWW.LDLINE.COM

DRAWING ISSUE RECORD		
DATE:	REVISIONS:	NO.
11-1-18	ISSUE TO BID	

HARMONY LELAND-CHASTAIN MIDDLE SCHOOL
REPLACEMENT ELEMENTARY SCHOOL
6326 FACTORY SHOALS RD.
MABLETON, GA 30126
FOR COBB COUNTY SCHOOL DISTRICT
CCSD PROJECT No. A004 / DOE FACILITY CODE

DRWG. BY: CP/RL/MT
JOB NO.: BHL-2021-18
DATE: 11-1-18

cunningham, forehand, matthews & moore, architects, inc. - 2011 manchester street, n.e. - atlanta, georgia 30324 - phone (404) 873-2152

DO NOT DUPLICATE WITHOUT PERMISSION

GEORGIA REGISTERED No. 019103 PROFESSIONAL ENGINEER REBECCA L. MILLS

SPURLOCK & ASSOCIATES, INC.
consulting engineers
2970 Clairmont Rd., Suite 620 | Atlanta, GA 30329
P: 404.633.0245 | F: 404.633.1756
JOB NO. 1822

M3.2