

Order Plans

PANEL HE: SERVICE: 480Y/277V, 3Ø MAIN: 400A M.L.O. PANEL A.I.G.: 25,000A. Table with columns: SERVES, VA, CIR. BKR., CIR. #, A B C, CIR. #, CIR. BKR., VA, SERVES. Includes a 3-phase diagram.

PANEL HD: SERVICE: 480Y/277V, 3Ø MAIN: 400A M.L.O. PANEL A.I.G.: 25,000A. Table with columns: SERVES, VA, CIR. BKR., CIR. #, A B C, CIR. #, CIR. BKR., VA, SERVES. Includes a 3-phase diagram.

PANEL HC: SERVICE: 480Y/277V, 3Ø MAIN: 400A M.L.O. PANEL A.I.G.: 25,000A. Table with columns: SERVES, VA, CIR. BKR., CIR. #, A B C, CIR. #, CIR. BKR., VA, SERVES. Includes a 3-phase diagram.

PANEL HB: SERVICE: 480Y/277V, 3Ø MAIN: 400A M.L.O. PANEL A.I.G.: 25,000A. Table with columns: SERVES, VA, CIR. BKR., CIR. #, A B C, CIR. #, CIR. BKR., VA, SERVES. Includes a 3-phase diagram.

PANEL HA: SERVICE: 480Y/277V, 3Ø MAIN: 400A M.L.O. PANEL A.I.G.: 25,000A. Table with columns: SERVES, VA, CIR. BKR., CIR. #, A B C, CIR. #, CIR. BKR., VA, SERVES. Includes a 3-phase diagram.

PANEL HEL: SERVICE: 480Y/277V, 3Ø MAIN: 100A M.L.O. PANEL A.I.G.: 25,000A. Table with columns: SERVES, VA, CIR. BKR., CIR. #, A B C, CIR. #, CIR. BKR., VA, SERVES. Includes a 3-phase diagram.

PANEL HDL: SERVICE: 480Y/277V, 3Ø MAIN: 100A M.L.O. PANEL A.I.G.: 25,000A. Table with columns: SERVES, VA, CIR. BKR., CIR. #, A B C, CIR. #, CIR. BKR., VA, SERVES. Includes a 3-phase diagram.

PANEL HCL: SERVICE: 480Y/277V, 3Ø MAIN: 100A M.L.O. PANEL A.I.G.: 25,000A. Table with columns: SERVES, VA, CIR. BKR., CIR. #, A B C, CIR. #, CIR. BKR., VA, SERVES. Includes a 3-phase diagram.

PANEL HBL: SERVICE: 480Y/277V, 3Ø MAIN: 100A M.L.O. PANEL A.I.G.: 25,000A. Table with columns: SERVES, VA, CIR. BKR., CIR. #, A B C, CIR. #, CIR. BKR., VA, SERVES. Includes a 3-phase diagram.

PANEL HAL: SERVICE: 480Y/277V, 3Ø MAIN: 100A M.L.O. PANEL A.I.G.: 25,000A. Table with columns: SERVES, VA, CIR. BKR., CIR. #, A B C, CIR. #, CIR. BKR., VA, SERVES. Includes a 3-phase diagram.


PANEL LE: SERVICE: 208Y/120V, 3Ø MAIN: 225A-3P MAIN BREAKER PANEL A.I.G.: 10,000A. SECTION #1. Table with columns: SERVES, VA, CIR. BKR., CIR. #, A B C, CIR. #, CIR. BKR., VA, SERVES. Includes a 3-phase diagram.

PANEL LD: SERVICE: 208Y/120V, 3Ø MAIN: 150A-3P MAIN BREAKER PANEL A.I.G.: 10,000A. SECTION #1. Table with columns: SERVES, VA, CIR. BKR., CIR. #, A B C, CIR. #, CIR. BKR., VA, SERVES. Includes a 3-phase diagram.

PANEL LB: SERVICE: 208Y/120V, 3Ø MAIN: 225A-3P MAIN BREAKER PANEL A.I.G.: 10,000A. SECTION #1. Table with columns: SERVES, VA, CIR. BKR., CIR. #, A B C, CIR. #, CIR. BKR., VA, SERVES. Includes a 3-phase diagram.

PANEL LA: SERVICE: 208Y/120V, 3Ø MAIN: 225A-3P MAIN BREAKER PANEL A.I.G.: 10,000A. SECTION #1. Table with columns: SERVES, VA, CIR. BKR., CIR. #, A B C, CIR. #, CIR. BKR., VA, SERVES. Includes a 3-phase diagram.

PANEL LA: SERVICE: 208Y/120V, 3Ø MAIN: 225A-3P MAIN BREAKER PANEL A.I.G.: 10,000A. SECTION #2. Table with columns: SERVES, VA, CIR. BKR., CIR. #, A B C, CIR. #, CIR. BKR., VA, SERVES. Includes a 3-phase diagram.



DATE NO. DESCRIPTION table with project milestones and dates.

DOE FACILITY CODE: 660-3066 RIVERWOOD HIGH SCHOOL-PHASE 3-8 AUDITORIUM / GYMNASIUM ADDITION 5900 RAIDER DRIVE NW SANDY SPRINGS, GA 30328 FULTON COUNTY SCHOOLS RFP NO. 411-19

ELECTRICAL SCHEDULES & DETAILS

PROJECT NO. 16015.02 DATE 09/17/18 DRAWN BY: G.T.R. CHECKED BY: B.L.S.

SHEET NO. E-6.13