

LEGEND


1. 8" UNDERGROUND STUB
2. 8" FLANGE AT 0'-6" AFF
3. 8" SPOOL PIECE F&G
4. 8" GROOVED FLANGE
5. 8" GROOVED ELL
6. NOT USED
7. 8" GROOVED TEE
8. 8" GROOVED BUTTERFLY VALVE W/ TAMPER SWITCH
9. 6" GROOVED ELL
10. WEATHERPROOF HORN / STROBE
11. NOT USED
12. TEST AND DRAIN VALVE W/ 1/2" ORIFICE (PRESSURE RELIEF SET AT 175 PSI)
13. WATER FLOW INDICATOR
14. 300# PSI GAUGE
15. 4-WAY SWAY BRACE REQUIRED
16. 8" WELDED MANIFOLD W/GROOVED OUTLETS & ENDS (OUTLETS TO BE SIZED AS REQUIRED)
17. 8" GROOVED ECCENTRIC DRAIN CAP W/1" AUX. & PLU
18. PIPE STAND
19. FLOOR DRAIN
20. NOT USED
21. 6" GROOVED BUTTERFLY VALVE W/ TAMPER SWITCH
22. SPRAY HEAD CABINET (TYPICAL #2)
23. 8" TILE FOR FULL FLOW TEST W/ BACKFLOW ASSEMBLY
24. 8" 4000SS REDUCED PRESSURE ASSEMBLY OR APPROVED EQUAL

WWW.LDILINE.COM

Order Plans @



CONSULTANT
DRAWN BY: WJK
REVIEWED BY: DLW



DATE: 10/23/2018
ISSUE: 05X OWNER REVIEW
11/01/2018 10/23/2018

DATE REVISION

PROJECT TITLE
KROGER STORE R543

1000 W. Mainway Blvd
Hampton, VA 23666

COMMISSION NO: 518344
ISSUE DATE: 10/23/2018

SHEET TITLE
FIRE PROTECTION DETAILS

SHEET NO.
FP3