



CONTROL MATRIX

CONDITION	IF:					THEN:					NOTES	
	EXHAUST FAN	ELECTRIC POWER TO COOKING EQUIPMENT	Mechanical EQUIPMENT	FMAC VALVE	FMAC KNOBS	MAKE-UP AIR UNITS (IF AVAILABLE)	EXHAUST FAN	ELECTRIC POWER TO COOKING EQUIPMENT	Mechanical EQUIPMENT	FMAC VALVE		FMAC KNOBS
FAN SWITCH IS TURNED ON	ON	ON	ON	ON	ON	ON	ON	ON	ON	ON	ON	FMAC MUST BE ON FOR EXHAUST FAN TO OPERATE
FAN SWITCH IS TURNED OFF	OFF	OFF	OFF	OFF	OFF	OFF	OFF	OFF	OFF	OFF	OFF	
FIRE SUPPRESSION DISCHARGES	ON	OFF	OFF	OFF	OFF	OFF	ON	OFF	OFF	OFF	OFF	POWER TO COOKING EQ. OFF VIA CURRENT SENSOR
FAN BELT IS SLIPPING	ON	OFF	ON	ON	ON	OFF	ON	OFF	ON	OFF	OFF	POWER TO COOKING EQ. OFF VIA CURRENT SENSOR
FAN BELT IS BROKEN	ON	OFF	ON	ON	ON	OFF	ON	OFF	ON	OFF	OFF	POWER TO COOKING EQ. OFF VIA CURRENT SENSOR
LOSS OF POWER	OFF	OFF	ON	OFF	OFF	OFF	OFF	OFF	ON	OFF	OFF	
FMAC IS SWITCHED OFF	OFF	OFF	ON	OFF	OFF	OFF	OFF	OFF	ON	OFF	OFF	

1218/14 15-SIZE ADDITION
Date: 12/18/14
Drawn/Checked: C.W.W./C.W.W.

BURGER KING
06-1/2" FRYER HOOD INSTALLATION DETAILS

3 OF 3

Order Plans @ www.worldline.com

6.23.17
REVISION

BURGER KING

CAMBRIDGE FRANCHISE HOLDINGS

IA ARCHITECTURE

BURGER KING
06-1/2" FRYER HOOD INSTALLATION DETAILS

SEPTEMBER, 2016 DESIGN RELEASE
BURGER KING RESTAURANT
OFF OF I-40, THEN MAYBELLINE RD.
GALLOWAY, AR

M 5