VOLTAGE 480/277 | PHASE 3 WIRE 4 | PANEL **HG** | MAIN AMPS **400** | LOCATION MECH 102 | MOUNTING SURFACE | MAIN BREAKER

SERVING	VA	BREAKER AMPS	BREAKER P	CKT	PH	CKT	BREAKER AMPS	BREAKER P	VA	SERVING
LIGHTING	300	20	1	1	A	2	1	20	3,000	CH-1
LIGHTING	660	20	1	3	B	4	1	20	3000	CH-2
LIGHTING (GYM)	2250	20	1	5	C	6	1	20		SPARE
SPARE		20	1	7	A	8	1	20		SPARE
SPARE		20	1	9	B	10	1	20		SPARE
SPARE		20	1	11	C	12	1	20		SPARE
SPARE		20	1	13	A	14	1	20		SPARE
SPARE		20	1	15	B	16	1	20		SPARE
SPARE		20	1	17	C	18	1	20		SPARE
SPARE		20	1	19	A	20	3	20		SPARE
SPARE		20	1	21	B	22				
SPARE		20	1	23	C	24				
SPARE		30	3	25	A	26	3	20	4000	BOOSTER PUMP
				27	B	28				
				29	C	30				
SPARE		60	3	31	A	32	3	110		SPARE
				33	B	34				
				35	C	36				
ATS	9,000	30	3	37	A	38	3	110		SPARE
				39	B	40				
				41	C	42				
RTU-1	74500	125	3	43	A	44	3	100	58800	TRANSFORMER TG
				45	B	46				
				47	C	48				
RTU-2	74,500	125	3	49	A	50	3	40		T.V.S.S.
				51	B	52				
				53	C	54				

REMARKS:
1.
2. -
3. -

VOLTAGE 480/277 | PHASE 3 WIRE 4 | PANEL **HLSG** | MAIN AMPS **30** | LOCATION MECH 102 | MOUNTING SURFACE | MAIN BREAKER

SERVING	VA	BREAKER AMPS	BREAKER P	CKT	PH	CKT	BREAKER AMPS	BREAKER P	VA	SERVING
LIGHTING (GYM)	2100	20	1	1	A	2	1	20		SPARE
LIGHTING (EXTERIOR)	500	20	1	3	B	4	1	20		SPARE
SPARE		20	1	5	C	6	1	20		SPARE
SPARE		20	1	7	A	8	1	20		SPARE
SPARE		20	1	9	B	10	1	20		SPARE
SPARE		20	1	11	C	12	1	20		SPARE
SPARE		20	1	13	A	14	1	20		SPARE
SPARE		20	1	15	B	16	1	20		SPARE
SPARE		20	1	17	C	18	1	20		SPARE
SPARE		20	1	19	A	20	3	30	6200	TRANSFORMER TEG
SPARE		20	1	21	B	22				
SPARE		20	1	23	C	24				
SPARE		20	1	25	A	26	3	40		T.V.S.S.
SPARE		20	1	27	B	28				
SPARE		20	1	29	C	30				

REMARKS:
1.
2. -
3. -

VOLTAGE 208/120 | PHASE 3 WIRE 4 | PANEL **LEG** | MAIN AMPS **60** | LOCATION MECH 102 | MOUNTING SURFACE | MAIN BREAKER

SERVING	VA	BREAKER AMPS	BREAKER P	CKT	PH	CKT	BREAKER AMPS	BREAKER P	VA	SERVING
RECEPTACLES (DATA)	900	20	1	1	A	2	1	20	800	FIRE ALARM CONTROL PANEL
RECEPTACLES (DATA)	900	20	1	3	B	4	1	20	800	INTRUSION ALARM CONTROL PNL
RECEPTACLES (LOCAL SOUND)	800	20	1	5	C	6	1	20	800	GENERATOR HEATER
SPARE		20	1	7	A	8	1	20	800	GENERATOR CONTROLS
SPARE		20	1	9	B	10	1	20		SPARE
SPARE		20	1	11	C	12	1	20		SPARE
SPARE		20	1	13	A	14	1	20		SPARE
SPARE		20	1	15	B	16	1	20		SPARE
SPARE		20	1	17	C	18	1	20		SPARE
SPARE		20	1	19	A	20	1	20		SPARE
SPARE		20	1	21	B	22	1	20		SPARE
SPARE		20	1	23	C	24	1	20		SPARE
SPARE		20	1	25	A	26	1	20		SPARE
SPARE		20	1	27	B	28	2	15	2000	IHP/OHP-5
SPARE		20	1	29	C	30				
SPARE		20	1	31	A	32	1	20		SPARE
SPARE		20	1	33	B	34	1	20		SPARE
SPARE		20	1	35	C	36	1	20		SPARE
SPARE		20	1	37	A	38	3	40		SPARE
SPARE		20	1	39	B	40				
SPARE		20	1	41	C	42				

REMARKS:
1.
2. -
3. -

VOLTAGE 208/120 | PHASE 3 WIRE 4 | PANEL **LG1** | MAIN AMPS **225** | LOCATION MECH 102 | MOUNTING SURFACE | MAIN BREAKER

SERVING	VA	BREAKER AMPS	BREAKER P	CKT	PH	CKT	BREAKER AMPS	BREAKER P	VA	SERVING
BASKETBALL BACKSTOP	2000	25	1	1	A	2	1	20	600	SCOREBOARD CONTROL
BASKETBALL BACKSTOP	2000	25	1	3	B	4	1	20	600	SCOREBOARD
BASKETBALL BACKSTOP	2000	25	1	5	C	6	1	20	600	SCOREBOARD
BASKETBALL BACKSTOP	2000	25	1	7	A	8	1	20		SPARE
BASKETBALL BACKSTOP	2000	25	1	9	B	10	1	20		SPARE
BASKETBALL BACKSTOP	2000	25	1	11	C	12	1	20		SPARE
SPARE		20	1	13	A	14	1	20		SPARE
SPARE		20	1	15	B	16	1	20		SPARE
SPARE		20	1	17	C	18	1	20		SPARE
SPARE		20	1	19	A	20	1	20	500	F-1,F-2
SPARE		20	1	21	B	22	2	15	2000	WH-1
SPARE		20	1	23	C	24				
SPARE		20	1	25	A	26	2	15	2000	WH-2
SPARE		20	1	27	B	28				
SPARE		20	1	29	C	30	2	15	2000	IHP/OHP-3
SPARE		20	1	31	A	32				
SPARE		20	1	33	B	34	2	15	2000	IHP/OHP-4
SPARE		20	1	35	C	36				
SPARE		20	1	37	A	38	2	30	4500	WATER HEATER P-8
SPARE		20	1	39	B	40				
SPARE		30	2	41	C	42	2	25	3000	IHP/OHP-1
				43	A	44				
SPARE		20	2	45	B	46	2	25	3000	IHP/OHP-2
				47	C	48				
BLEACHERS	10,000	60	3	49	A	50	3	40		T.V.S.S.
				51	B	52				
				53	C	54				

REMARKS:
1. PROVIDE FEED THRU LUGS.
2. -
3. -

VOLTAGE 208/120 | PHASE 3 WIRE 4 | PANEL **LG2** | MAIN AMPS **225** | LOCATION MECH 102 | MOUNTING SURFACE | MAIN MLO

SERVING	VA	BREAKER AMPS	BREAKER P	CKT	PH	CKT	BREAKER AMPS	BREAKER P	VA	SERVING
RECEPTACLES	900	20	1	1	A	2	1	20	800	WATER COOLER
RECEPTACLES	900	20	1	3	B	4	1	20	800	WATER COOLER
SPARE		20	1	5	C	6	1	20	2000	HAND DRYER
RECEPTACLES	900	20	1	7	A	8	1	20	2000	HAND DRYER
RECEPTACLES	720	20	1	9	B	10	1	20	2000	HAND DRYER
RECEPTACLES	720	20	1	11	C	12	1	20		HAND DRYER
IRRIGATION CONTROL PANEL	180	20	1	13	A	14	1	20		RECEPTACLES
SPARE		20	1	15	B	16	1	20	2000	HAND DRYER
SPARE		20	1	17	C	18	1	20		SPARE
SPARE		20	1	19	A	20	1	20		SPARE
SPARE		20	1	21	B	22	1	20		SPARE
SPARE		20	1	23	C	24	1	20		SPARE
SPARE		20	1	25	A	26	1	20		SPARE
SPARE		20	1	27	B	28	1	20		SPARE
SPARE		20	1	29	C	30	1	20		SPARE
SPARE		20	1	31	A	32	1	20		SPARE
SPARE		20	1	33	B	34	1	20		SPARE
SPARE		20	1	35	C	36	1	20		SPARE
SPARE		20	1	37	A	38	1	20		SPARE
SPARE		20	1	39	B	40	1	20		SPARE
SPARE		20	1	41	C	42	1	20		SPARE
SPARE		20	1	43	A	44	1	20		SPARE
SPARE		20	1	45	B	46	1	20		SPARE
SPARE		20	1	47	C	48	1	20		SPARE
SPARE		20	1	49	A	50	1	20		SPARE
SPARE		20	1	51	B	52	1	20		SPARE
SPARE		20	1	53	C	54	1	20		SPARE

REMARKS:
1.
2. -
3. -

VOLTAGE 208/120 | PHASE 3 WIRE 4 | PANEL **LM** | MAIN AMPS **100** | LOCATION E718 | MOUNTING SURFACE | MAIN MLO

SERVING	VA	BREAKER AMPS	BREAKER P	CKT	PH	CKT	BREAKER AMPS	BREAKER P	VA	SERVING
IHP/OHP-6	1997	15	2	1	A	2	1	20	400	SUMP PUMP & WATER HEATER
				3	B	4	1	20	800	WATER COOLER
IHP/OHP-7	1997	15	2	5	C	6	1	20	800	WATER COOLER
				7	A	8	1	20	800	WATER COOLER
IHP/OHP-8	1997	15	2	9	B	10	1	20	800	WATER COOLER
				11	C	12	1	20	2000	HAND DRYER
IHP/OHP-9	1977	15	2	13	A	14	1	20	2000	HAND DRYER
				15	B	16	1	20	2000	HAND DRYER
LOCAL SOUND SYTEM	800	20	1	17	C	18	1	20	2000	HAND DRYER
SPARE		20	1	19	A	20	1	20	2000	HAND DRYER
SPARE		15	2	21	B	22	1	20	2000	HAND DRYER
				23	C	24	1	20	2000	HAND DRYER
SPARE		20	3	25	A	26	1	20	2000	HAND DRYER
				27	B	28	1	20	2000	HAND DRYER
				29	C	30	1	20		SPARE
SPARE		20	3	31	A	32	1	20		SPARE
				33	B	34	1	20		SPARE
				35	C	36	1	20		SPARE
SPARE		30	3	37	A	38	1	20	1000	EXISTING LOAD
				39	B	40	1	20	1000	EXISTING LOAD
				41	C	42	1	20	1000	EXISTING LOAD
				43	A	44				
				45	B	46				
				47	C	48				
				49	A	50				
				51	B	52				
				53	C	54				

REMARKS:
1.
2. -
3. -

Order Plans @ WWW.DLine.com

dickinson ARCHITECTS
Architecture | Interior Design | Planning
771 Broad Street, Suite 200
Augusta, Georgia 30901
706.722.7488
mail@dickinsonarchitects.com
www.dickinsonarchitects.com
Member of the American Institute of Architects

THIS DRAWING IS THE PROPERTY OF DICKINSON ARCHITECTS, P.C., AND IS NOT TO BE REPRODUCED OR COPIED IN WHOLE OR IN PART OR USED FOR ANY PURPOSE WHATSOEVER WITHOUT THE WRITTEN AND VISUAL CONSENT OF DICKINSON ARCHITECTS, P.C. THE INTENTION OF DICKINSON ARCHITECTS, P.C., AND IS TO BE PERFORMED IN ITS ENTIRETY BY DICKINSON ARCHITECTS, P.C.

PROJECT TITLE:
MURPHEY MIDDLE SCHOOL P.E. BUILDING
PROJECT # B-17-005-3756.1

REVISIONS

REV #	DATE	APRVD BY	REVISION
	11/02/18	MAP	STATE FINAL
	11/20/18	MAP	ISSUE FOR BID

GEORGIA REGISTERED ARCHITECT NO. 019 MICHAEL A. PYLES PRATT
11•20•18

DA PROJECT NUMBER & NAME:
1707.1

DRAWING TITLE:
PANELBOARD SCHEDULES

DRAWING NO:
E502