Drawing name: L:\005031 - RaceTrac - Cartersville (E Main Street)_GA\CADD\CONSTR\005031 - 07 - UTILITY.dwg UTILITY PLAN Oct 26, 2018 2:51pm by: tradd.anderson

24 HOUR CONTACT:
MR. MARK MCGINNIS - 678.773.7063
RACETRAC PETROLEUM, INC

CONTACT RACETRAC PETROLEUM, INC. PROJECT MANAGER PRIOR TO ANY REVISIONS TO THE PLAN SUPPLIED BY RACETRAC PETROLEUM, INC

OWNER/DEVELOPER
RACETRAC PETROLEUM, INC.
200 GALLERIA PKWY, SUITE 900
ATLANTA, GA 30339
770.431.7600 X1900
MR. SAMMIE ABDULHAFIZ
sabdulhafiz@racetrac.com

CIVIL ENGINEER
LeCRAW ENGINEERING, INC.
3475 CORPORATE WAY
SUITE A
DULUTH, GA 30096
678.546.8100
MR. MICHAEL TOOTHAKER, P.M.
michael.toothaker@lecraweng.com

SURVEYOR
LECRAW ENGINEERING, INC.
3475 CORPORATE WAY
DULUTH, GA 30096
678.546.8100
MR. ART CANNINGTON, RLS
art.cannington@lecraweng.com

NOT TO SCALE

CARTERSVILLE DDC TAP DETAIL

CITY OF CARTERSVILLE	FIRE SERVICE TAP DETAIL	SSWR-DWG NO.	SSWR-DWG NO.
WADE DEMARCO	CONSTRUCTION STANDARD	APPROVED	SPEC


TOP OF WATER METER TO BE NEARLY FLUSH WITH TOP OF GROUND
ALL FITTINGS ARE TO BE RESTRAINED
3061 SERVICE VAULT
MAIN 3/4" IRRIGATION METER W/ DOUBLE CHECK VALVE BFP
FROM 3" WATER METER W/ DOUBLE CHECK VALVE BFP
6" BASIC VALVE
6" MAINLINE COUPLING
6"X6" TEE
6"X6" ANCHOR TEE
3" MAINLINE TEE
3" ASPHALT COUPLING
2" ELL
2" ELL PIPING
3" ASPHALT BALL VALVE
6"X6" ANCHOR TEE
6" MAINLINE COUPLING
6" GATE VALVE
6" ANCHOR COUPLING
FIRE HYDRANT (TYPICAL)
3" ANCHOR COUPLING
3" ANCHOR ELL
3" ANCHOR COUPLING
3" ASPHALT BALL VALVE
3" ANCHOR COUPLING
3" ANCHOR ELL
3" ANCHOR COUPLING
3" ASPHALT BALL VALVE
SOIL MIXTUR