ELECTRICAL PACKAGE — Job#3552594

NO.	TAG	PACKAGE #	LOCATION	SWITCHES		OPTION	FANS CONTROLLED					
				LOCATION	QUANTITY		FAN TAG	TYPE	#	H.P.	VOLTS	FLA
1		SC-E101011MA	Wall Mount In SS Box	65 - SS Wall Mount Box	1 Light 1 Fan	Smart Controls Thermostatic Control w/ Relay On/OFF with Supply	E56370112	Exhaust	1	0.233	115	4.4
								Exhaust	3	0.500	230	1.7

JOB NO 3552594 | MODEL NUMBER SC-E101011MA | DESCRIPTION OF OPERATION: Power supplied and wired for 1 Ph. Exhaust Fan. VAV 2% Exhaust Fan Exhaust to 0 Fire lights out in Fan. Fans Horsepower Amperage Volt / Phase Motor Protection Overload Type Temperature Sensor Shipped Loose For

JOB NAME Pizza Hut NPC 4 Wetumpka AL #_

BREAKER PANEL TO PRIMARY CONTROL PANEL
Responsibility: Electrician
BREAKER SIZE SHOWN IS THE MAXIMUM ALLOWED

CONTROL PANEL TO FANS
Responsibility: Electrician

CONTROL PANEL TO ACCESSORY ITEMS
Responsibility: Electrician

BREAKER PANEL TO FANS
Responsibility: Electrician



Order Plans @ www.LDILine.com

CAPITAL
1901 Royal Lane Suite 101, DALLAS, TX. 75229 PHONE: (214) 220-3669 FAX: (214) 220-0088 EMAIL: reps1@capitalwestinc.com
Dallas Office
www.capitalwestinc.com

REVISIONS

DESCRIPTION	DATE

Pizza Hut NPC 4 Wetumpka AL #1845
WETUMPKA, AL

DATE: 9/19/2018
DWG.#: 3552594
DRAWN BY: BJL-45
SCALE: 3/4" = 1'-0"
MASTER DRAWING

SHEET NO. 3

08/10/18
JOB NO: 1845
DRAWN: BH,MJ,SO
CHECKED: AR,CF
ACG #: 1820228

HOOD DWGS.

FRANCHISEE

7300 W. 129TH STREET
OVERLAND PARK, KANSAS
66213
PHONE: (913) 327-5555
FAX: (913) 327-5850

PIZZA HUT #1845
5229 US HWY 231
WETUMPKA, ALABAMA

FOR REFERENCE ONLY

SHEET NUMBER
M3.2

REVISIONS: