


Submission	Date
OWNER/LL REVIEW	11/01/2018
BID SET	11/01/2018
PERMIT SET	11/01/2018

#	Description	Date



NOV 02 2018



**GAS LOADS SUMMARY**

ID	MANUFACTURER	MODEL NO.	GAS LOAD
DOAS-1	TRANE	QADG120	150000 Btu/h
RTU-1	TRANE	THC060F3	80000 Btu/h
RTU-2	TRANE	120F3RLA	140000 Btu/h
WH-1	RINNAI	REL1303FFUD	190000 Btu/h
WH-2	RINNAI	REL1207FFUD	160000 Btu/h
TOTAL CONNECT GAS LOAD:			768000 Btu/h

NATURAL GAS SYSTEM OPERATING PRESSURE OF 14" WC  
 CENTRAL GAS SYSTEM SIZED WITH TOTAL DEVELOPED LENGTH FROM GAS  
 METER TO MOST REMOTE PIECE OF EQUIPMENT OF 120' STRAIGHT PIPE + 25% FOR FITTINGS + 150'  
 WITH A PRESSURE DROP OF 0.5" WC