



Signed & Sealed: 08/30/18

Copyright © 2014 YSM Design, P.C.
All rights reserved. No part of this document may be reproduced, stored in a retrieval system, or transmitted in any form or by any means, electronic, mechanical, photocopying, recording, or by any information storage and retrieval system, without the prior written permission of YSM Design, P.C. It is to be returned upon request. There is no warranty and only what is on the drawing counts.

Rev	Date	Comments
	08/30/18	Permit/Bid Set

BID SET


Every Contractor or Subcontractor, by submitting a bid for this project declares that they have reviewed all aspects of this project and have included all work required to provide a complete project that meets all building codes.

If questions or discrepancies are found between trades, these should be submitted by the bidding General Contractor as a Request For Information before bids are due. These clarifications will be issued to all Bidders in Accordance. No consideration will be given after the bid date for issues that could clearly have been answered during the Bidding Period.

Information to all Bidders:
For more information about this bid, including a list of the most current documents, instructions to Bidders, Responsibility Chart, answers to RFIs, etc., go to project website. Note this address will be provided to bidders with invitation to bid.

It is the responsibility of ALL Bidders to become familiar with this site and the additional information that is contained therein. If you do not have access to the internet you MUST contact your General Contractor for this information. No Change Orders will be accepted for not reviewing this information.

No consideration will be given for Change Order Requests based on any of the following:
1. Items requiring clarification but not clearly indicated as an exception on the bid set.
2. Items requiring clarification but not submitted to architect as a request for information during bidding.
3. Items deemed to be industry standard for a particular system or assembly.
4. Items that can reasonably be inferred from contract documents.



Key Plan - Proposed



**JIM ELLIS
CADILLAC**

5880 PEACHTREE BLVD
ATLANTA, GA 30341

Project:

**JIM ELLIS
CADILLAC**

5880 PEACHTREE BLVD
ATLANTA, GA 30341

Project Number: 18020
Drawn By: GD
Checked By: DF
Approved By: SM

Sheet Title:

**POWER PLAN -
SECOND FLOOR**

Sheet Number:

E302

KEY NOTES	
①	DISCONNECTING MEANS MOUNTED ADJACENT TO ELECTRIC WATER COOLER CHILLER, COORDINATE LOCATION WITH PLUMBING DRAWINGS.
②	RECEPTACLE LOCATED ON MECHANICAL ROOFTOP EQUIPMENT, AVOID ACCESS PANELS AND LOUVERS.

GENERAL NOTE	
*	CONTRACTOR SHALL COORDINATE FINAL LOCATIONS OF FLOOR BOXES AND CONDUIT STUB-UPS PRIOR TO ROUGH-IN. REFER TO ARCHITECTURAL DOCUMENTS AND SITE SPECIFIC FURNITURE INFORMATION. -VISIBLE EXPOSED CONDUIT AND / OR SURFACE MOUNTED ELECTRICAL BOXES AT CONDUIT STUB-UP LOCATIONS SHALL NOT BE ACCEPTABLE. ENSURE STUB-UPS ARE EITHER BELOW REMOVABLE ACCESSIBLE FURNITURE PANELS OR CONCEALED FROM VIEW ADJACENT TO FURNITURE PANELS MINIMUM 18" FROM OPEN SIDE OF FURNITURE. -NECESSARY FLOOR BOXES SHALL BE LOCATED BENEATH FURNITURE FROM WHICH ELECTRICAL DEVICES WITH CORD AND PLUGS WILL CONNECT. BOXES SHALL NOT BE LOCATED IN SPACE BELOW FURNITURE DEDICATED FOR CHAIRS AND SHOES. WHERE BOXES MUST BE LOCATED ADJACENT TO FURNITURE, INSURE THAT EXPOSED CORDS DO NOT EXCEED 6" FROM EXPOSED PLUGS TO FURNITURE.

GENERAL MECHANICAL POWER NOTE	
	REFER TO SHEET E301, MECHANICAL EQUIPMENT-ELECTRICAL SCHEDULE, FOR POWER REQUIREMENTS TO ALL MECHANICAL EQUIPMENT / MOTORIZED DAMPERS INDICATED ON THIS SHEET.

1 POWER PLAN - SECOND FLOOR
E302 1/8" = 1'-0"

Order Plans

www.LDILine.com

