



- MECHANICAL KEY NOTES:**
1. THERMOSTAT MOUNTED AT 60" A.F.F. COORDINATE WIRING WITH MECHANICAL CONTRACTOR.
 2. PROVIDE DRYER EXHAUST WALL CAP. MOUNT TOP OF WALL CAP 20" BELOW STRUCTURE.
 3. ROUTE EXHAUST UP THRU ROOF. PROVIDE EXHAUST ROOF CAP AT ROOF PENETRATION.
 4. TOP OF LOUVER MOUNTED 20" BELOW STRUCTURE.
 5. BOTTOM OF LOUVER MOUNTED 72" A.F.F.

1 ENLARGED PUBLIC POOL OVERALL PLAN - LEVEL 1 (HVAC)
M302
1/4" = 1'-0"

WINDSOR AUGHTRY
HOME2 ASHEVILLE

380 AIRPORT RD.
ASHEVILLE, NC 28704

SHEET ISSUE:
07/30/18
FOR CONSTRUCTION

Revisions		
Number	Description	Date

PRINCIPAL IN CHARGE:
PROJECT ARCHITECT:
DRAWN BY:
SHEET TITLE:
**ENLARGED PUBLIC
POOL OVERALL
PLAN - HVAC**

SHEET NO. PROJ. NO.
017878.00

M302

Order Plans @ www.LDLine.com

MCMILIAN PAZDAN SMITH ARCHITECTURE, INC. IS PROVIDING THESE DOCUMENTS TO YOU FOR YOUR INFORMATION ONLY. THE INFORMATION CONTAINED HEREIN IS THE PROPERTY OF MCMILIAN PAZDAN SMITH ARCHITECTURE, INC. AND IS NOT TO BE REPRODUCED, COPIED, OR TRANSMITTED IN ANY FORM OR BY ANY MEANS, ELECTRONIC OR MECHANICAL, INCLUDING PHOTOCOPYING, RECORDING, OR BY ANY INFORMATION STORAGE AND RETRIEVAL SYSTEM, WITHOUT THE WRITTEN PERMISSION OF MCMILIAN PAZDAN SMITH ARCHITECTURE, INC. ALL RIGHTS ARE RESERVED.