

**ELECTRICAL GENERAL NOTES:**

**GENERAL**  
THESE GENERAL NOTES PRESENT AND/OR SUMMARIZE KEY PRODUCT INFORMATION FOR THE PLAN READER'S CONVENIENCE. SEE PLANS AND SPECIFICATIONS FOR FURTHER REQUIREMENTS.

WORK COVERED BY THIS DOCUMENT SHALL INCLUDE ALL LABOR, MATERIAL, PRODUCTS, AND SERVICES FOR, AND INCIDENTAL TO, INSTALLATION OF COMPLETE AND OPERATING ELECTRICAL SYSTEMS DRAWN OR SPECIFIED.

ALL WORK SHALL CONFORM TO ALL APPLICABLE FEDERAL, STATE AND LOCAL CODES INCLUDING, BUT NOT LIMITED TO, THE NATIONAL ELECTRICAL CODE (NFPA 70-2017). ALL MATERIALS SHALL BE NEW AND UL LISTED/LABELED AS APPROPRIATE. FINAL LOCATIONS FOR ROUGH-IN'S SHALL BE VERIFIED WITH ACTUAL EQUIPMENT BEING CONNECTED. SUPPORT AND ATTACH ELECTRICAL EQUIPMENT IN ACCORDANCE WITH SEISMIC CONDITIONS AS DETERMINED BY THE STRUCTURAL ENGINEER/BUILDING DESIGNER AND THE INTERNATIONAL BUILDING CODE 2012. AFTER COMPLETING INSTALLATION, REMOVE BURRS, DIRT, AND CONSTRUCTION DEBRIS FROM ALL ELECTRICAL WORK.

COORDINATE OUTLET LOCATIONS WITH ARCHITECTURAL PLANS, ELEVATIONS AND DETAILS.

COORDINATE HVAC AND PLUMBING EQUIPMENT LOCATIONS WITH MECHANICAL PLANS, ELEVATIONS AND DETAILS.

COORDINATE SITE LIGHTING AND SITE UTILITIES WITH LANDSCAPING/CIVIL PLANS AND DETAILS.

ALL SIGNAL RACEWAYS SHALL BE 3/4" DIA. MIN. UNLESS OTHERWISE NOTED.

COORDINATE ELECTRICAL SERVICE AND METERING REQUIREMENTS WITH SERVING UTILITY PRIOR TO BID AND INSTALLATION.

COORDINATE SIGNAL SERVICE REQUIREMENTS WITH SERVING UTILITY.

ELECTRICAL INSTALLATION SHALL BE SEISMIC BRACED PER APPLICABLE SECTIONS OF THE STANDARD BUILDING CODE.

CONSULT MANUFACTURERS' SHOP DRAWINGS FOR REQUIREMENTS AND EXACT LOCATION OF ELECTRICAL CONNECTIONS FOR EQUIPMENT FURNISHED BY OTHERS. BRANCH-CIRCUIT WIRING SHALL MEET ALL REQUIREMENTS OF THE EQUIPMENT MANUFACTURER.

SIZE DISCONNECT SWITCHES AND OVERCURRENT PROTECTION IN ACCORDANCE WITH THE EQUIPMENT MANUFACTURERS' RECOMMENDATIONS AND THE N.E.C.

SIZE FUSES IN ACCORDANCE WITH THE EQUIPMENT MANUFACTURERS' RECOMMENDATIONS AND THE N.E.C.

INSTALL JUNCTION BOXES, CONDUIT BODIES, AND HANDHOLE ENCLOSURES SUCH THAT WIRING WITHIN IS ACCESSIBLE IN ACCORDANCE WITH NEC 314.29.

MOUNTING HEIGHT DIMENSIONS FOR WIRING DEVICES ARE FROM THE FINISHED FLOOR UP TO THE CENTER OF THE OUTLET BOX.

CENTER OUTLETS HORIZONTALLY IN ARCHITECTURAL FEATURES.

DO NOT SCALE DRAWINGS. DEVICE LOCATIONS ARE APPROXIMATE UNLESS DIMENSIONED. ACTUAL DEVICE LOCATIONS SHALL BE FIELD COORDINATED WITH ALL OTHER TRADES AND APPLICABLE CODES.

INSTALL PHOTO CELL(S) ABOVE ROOF. ORIENT TO NORTHERN EXPOSURE AND SHIELD FROM EXTRANEOUS LIGHT. PROVIDE FLASHING AND SEAL ROOF PENETRATIONS(S).

INSTALL ADDITIONAL BRANCH-CIRCUIT CONDUCTORS TO PROVIDE UN-SWITCHED CONNECTION TO EACH EMERGENCY FIXTURE BATTERY.

DO NOT USE COMMON NEUTRALS FOR MULTI-WIRE CIRCUITS. INSTALL A NEUTRAL FOR EACH PHASE.

ALL CONDUCTORS SHALL BE NO SMALLER THAN #12.

GENERAL CONTRACTOR TO PROVIDE ACCESS PANELS FOR ALL INACCESSIBLE, ABOVE-CEILING ELECTRICAL EQUIPMENT AND JUNCTION BOXES PER 2017 NEC SECTION 314.29. COORDINATE LOCATIONS WITH ARCHITECT PRIOR TO INSTALLATION.

**CONDUCTORS**  
INSULATION SHALL COMPLY WITH NEMA WC 5. CONDUCTORS #6 AWG AND LARGER SHALL BE CONCENTRIC STRANDED. CONDUCTORS #10 AND SMALLER SHALL BE SOLID.

**TYPE AND INSULATION (SERVICE):** COPPER, TYPE THWN  
**TYPE AND INSULATION (FEEDER):** COPPER, TYPE THHN/THWN  
**TYPE AND INSULATION (BRANCH):** COPPER, TYPE THHN/THWN  
COPPER, TYPE MC

**COLOR CODING (208/120 V, 3Ø):** A-BLACK, B-RED, C-BLUE, N-WHITE, G-GREEN

**RACEWAYS**

CONDUIT BODIES AND FITTINGS FOR RIGID METAL CONDUIT SHALL BE CAST THREADED TYPE. CONDUIT FITTINGS FOR ELECTRICAL METALLIC TUBING SHALL BE COMPRESSION TYPE. INSTALL 200 lb NYLON PULL CORD IN ALL EMPTY RACEWAYS FOR FUTURE USE. APPLY FIRESTOPPING TO ELECTRICAL PENETRATIONS OF FIRE-RATED FLOOR AND WALL ASSEMBLIES TO RESTORE ORIGINAL FIRE-RESISTANCE RATING OF ASSEMBLY.

**OUTDOORS EXPOSED:** RIGID GALVANIZED STEEL CONFORMING TO ANSI C80.5  
**OUTDOORS UNDERGROUND:** RIGID NONMETALLIC CONDUIT (SCHEDULE 40 PVC) CONFORMING TO NEMA TC 2

**OUTDOORS CONNECTED TO VIBRATING OR MOTORIZED EQUIPMENT:** LIQUIDTIGHT FLEXIBLE METAL CONDUIT CONFORMING TO UL 360  
**INDOORS CONCEALED:** ELECTRICAL METALLIC TUBING CONFORMING TO ANSI C80.3  
**INDOORS EXPOSED:** ELECTRICAL METALLIC TUBING CONFORMING TO ANSI C80.3  
**INDOORS CONNECTED TO VIBRATING OR MOTORIZED EQUIPMENT:** FLEXIBLE METALLIC CONDUIT CONFORMING TO UL 1

**OUTLET BOXES**

BOXES SHALL COMPLY WITH NEMA OS 1 AND SHALL BE SHEET METAL TYPE WITH PLASTER RING IN DRY LOCATIONS. BOXES SHALL COMPLY WITH NEMA FB 1 AND SHALL BE CAST METAL TYPE FD WITH GASKETED COVER IN DAMP OR WET LOCATIONS.

**PULL AND JUNCTION BOXES**

BOXES SHALL BE HOT-DIPPED GALVANIZED STEEL. BOX COVERS SHALL BE GASKETED TYPE WITH SCREWED OR BOLTED FASTENERS.

**WIRING DEVICES**

DEVICES SHALL COMPLY WITH NEMA WD 1 AND WD 6. DEVICES SHALL BE COMMERCIAL SPECIFICATION GRADE OR BETTER. ALL DEVICES SHALL BE OF THE GROUNDING TYPE. DEVICES SHALL BE MOUNTED FLUSH WITH THE LONG DIMENSION VERTICAL AND GROUNDING TERMINAL OF RECEPTACLES ON TOP. SWITCHES SHALL BE QUIET TYPE, RATED 20 AMPERES AT 120/277 VOLTS. GROUND FAULT CIRCUIT INTERRUPTERS SHALL BE FEED-THROUGH TYPE. WEATHERPROOF COVERS SHALL BE PROVIDED IN DAMP OR WET LOCATIONS. PROGRAM OCCUPANCY SENSORS FOR FIFTEEN MINUTES WITH MEDIUM SENSITIVITY. TRAIN OWNER TO ADJUST TIME AND SENSITIVITY.

**DEVICE COLOR:** SELECTED BY ARCHITECT.  
**DEVICE COVER:** SMOOTH PLASTIC WITH COLOR TO MATCH DEVICE COLOR

**ELECTRICAL IDENTIFICATION**

IN ADDITION TO CODE-REQUIRED LABELING, ALL PANELBOARDS, ELECTRICAL ENCLOSURES, TRANSFORMERS, AND DISCONNECT SWITCHES SHALL BE IDENTIFIED WITH AN ENGRAVED PLASTIC LAMINATED NAMEPLATE. LETTERING SHALL BE 1/2" INCHES HIGH AND SHALL BE WHITE ON A BLACK BACKGROUND. NAMEPLATES SHALL BE ATTACHED TO EQUIPMENT WITH STAINLESS STEEL SELF-TAPPING SCREWS. CONTRACTOR TO COORDINATE WITH THE UTILITY COMPANY TO DETERMINE THE AVAILABLE FAULT CURRENT AT THE PANEL LOCATION SHOWN ON THE DRAWINGS. CONTRACTOR TO PROVIDE ELECTRICAL EQUIPMENT WITH AIC RATINGS OVER THE CALCULATED FAULT CURRENT. CALCULATED FAULT CURRENT SHALL BE LISTED ON EACH PIECE OF ELECTRICAL EQUIPMENT. CONTRACTOR TO PROVIDE AND AFFIX ARC FLASH WARNING LABELS ON ALL ELECTRICAL SWITCHBOARDS, PANELBOARDS, MOTOR CONTROL CENTERS, LOAD CENTERS, DISCONNECTS AND ENCLOSED CIRCUIT BREAKERS PER 2017 NEC ARTICLE 110.16.

**GROUNDING**

GROUNDING AND BONDING COMPONENTS SHALL COMPLY WITH UL 467. AN INSULATED EQUIPMENT-GROUNDING CONDUCTOR SHALL BE INSTALLED WITH CIRCUIT CONDUCTORS FOR ALL FEEDER AND BRANCH CIRCUITS. EXOTHERMIC-WELDED CONNECTIONS SHALL BE USED FOR ATTACHMENT TO STRUCTURAL STEEL AND UNDERGROUND CONNECTIONS. GROUNDING ELECTRODES SHALL BE 3/4" x 10' COPPERWELD TYPE.

**PANELBOARDS**  
PANELBOARDS SHALL COMPLY WITH NEMA PB 1. SHOP DRAWINGS FOR EACH PANELBOARD SHALL BE SUBMITTED AND SHALL INCLUDE BUS CONFIGURATION AND CURRENT RATINGS, OVERCURRENT DEVICE ARRANGEMENT AND SETTINGS, AND PANELBOARD SHORT CIRCUIT RATING. PHASE AND NEUTRAL BUSES SHALL BE COPPER. AN EQUIPMENT GROUND BUS SHALL BE PROVIDED AND SHALL BE BONDED TO THE PANEL BOX. PANELBOARDS WITH A MAIN SERVICE DISCONNECT SHALL BE LISTED FOR USE AS SERVICE EQUIPMENT. PANELBOARD TRIM SHALL BE BOLT-ON TYPE. CIRCUIT BREAKERS SHALL BE BOLT-ON TYPE. CIRCUIT BREAKERS SHALL BE LISTED FOR SWD, HID OR HACR USE AS APPROPRIATE. MULTI-POLE CIRCUIT BREAKERS SHALL HAVE A COMMON TRIP. TANDEM CIRCUIT BREAKERS SHALL NOT BE USED. FILLER PLATES SHALL BE INSTALLED IN UNUSED SPACES. A TYPED CIRCUIT DIRECTORY SHALL BE INSTALLED ON THE INSIDE OF THE PANELBOARD DOOR.

**FUSES**

FUSES SHALL BE NEMA FU 1 CARTRIDGE TYPE. VOLTAGE RATING SHALL BE CONSISTENT WITH CIRCUIT VOLTAGE. ARRANGE FUSES IN FUSIBLE DEVICES SO FUSE RATINGS ARE READABLE WITHOUT REMOVING FUSE. INSTALL TYPED WRITTEN LABELS ON INSIDE DOOR OF EACH FUSIBLE DEVICE TO INDICATE FUSE REPLACEMENT INFORMATION.

**MOTOR FEEDER AND BRANCH CIRCUITS:** UL CLASS RK5, TIME DELAY  
**OTHER FEEDER AND BRANCH CIRCUITS:** UL CLASS RK1, NON-TIME DELAY

**DISCONNECT SWITCHES**

SWITCHES SHALL BE FUSED OR NONFUSED NEMA KS 1 TYPE HD. SWITCHES SHALL BE HANDLE LOCKABLE AND INTERLOCKED WITH COVER IN CLOSED POSITION. ENCLOSURES SHALL BE NEMA TYPE 1 IN INDOOR LOCATIONS AND NEMA TYPE 3R IN OUTDOOR LOCATIONS. HVAC EQUIPMENT DISCONNECTS ARE TO BE CONSIDERED ELECTRICAL EQUIPMENT AND SHALL BE INSTALLED TO MAINTAIN WORKING SPACE PER 2017 NEC ARTICLE 110.26.

**INTERIOR LIGHTING**

FIXTURE MOUNTING HARDWARE AND TRIM SHALL BE COORDINATED WITH THE CEILING SYSTEM. RECESSED FIXTURES SHALL BE SUPPORTED FROM THE BUILDING STRUCTURAL SYSTEM. FLUORESCENT FIXTURE BALLASTS SHALL BE CBM LABELED, CLASS P, SOUND RATING "A", ELECTRONIC, HIGH POWER FACTOR TYPE.

**VOICE AND DATA SYSTEMS**

SYSTEM COMPONENTS AND INSTALLATION SHALL CONFORM TO CITY OF AUGUSTA'S 2016 NEW BUILDING AND CABLING GUIDELINES, EIA/TIA 568-B AND 569-A. MAIN DISTRIBUTION FRAME, INTERMEDIATE DISTRIBUTION FRAME, AND CROSS-CONNECT RACKS SHALL BE WALL MOUNTED TYPE WITH "66" OR "110" STYLE TERMINALS. WORKSTATION JACKS SHALL BE TYPE RJ-45.

**HORIZONTAL CABLE (VOICE):** 4-PAIR CATEGORY 6 UNSHIELDED TWISTED PAIR  
**HORIZONTAL CABLE (DATA):** 4-PAIR CATEGORY 6 UNSHIELDED TWISTED PAIR










































**TRANSFER SWITCH**


SWITCH SHALL COMPLY WITH UL 1008-89. SWITCH SHALL BE SIZED TO MATCH THE GENERATOR. SWITCH SHALL HAVE A SOLID NEUTRAL, EXERCISER TIME CLOCK AND BATTERY CHARGER.

**ENGINE GENERATOR**

THE EMERGENCY POWER SUPPLY SYSTEM SHALL BE LEVEL 2 IN ACCORDANCE WITH NFPA 110. ENGINE GENERATOR SHALL BE COMPLETE WITH WEATHERPROOF HOUSING, FUEL TANK, STARTING BATTERIES AND OUTPUT CIRCUIT BREAKER.

**ELECTRICAL SYMBOLS**

-  CEILING-MOUNTED EXIT SIGN - SHADING INDICATES FACE(S)
-  WALL-MOUNTED EXIT LIGHT FIXTURE  
SHADING INDICATES FACE(S); ARROW(S) INDICATE PATH OF EGRESS
-  DOWNLIGHT
-  DOWNLIGHT W/ EMERGENCY BATTERY PACK
-  2'x4' FIXTURE
-  2'x4' FIXTURE W/ EMERGENCY BATTERY PACK
-  4' STRIP FIXTURE
-  4' STRIP FIXTURE WITH EMERGENCY BATTERY BACK UP
-  WALL-MOUNTED LIGHT FIXTURE
-  UNDER CABINET LIGHT
-  GROUND MOUNTED EXIT FIXTURE
-  POLE MOUNTED LIGHT FIXTURE
-  SPST TOGGLE SWITCH 48" AFF TOP OF BOX
-  3-WAY TOGGLE SWITCH 48" AFF TOP OF BOX
-  4-WAY TOGGLE SWITCH 48" AFF TOP OF BOX
-  DUPLEX CONVENIENCE OUTLET 18" AFF
-  DUPLEX CONVENIENCE OUTLET 6" ABOVE COUNTER/BACKSPASH, 48" AFF MAX TO TOP OF BOX  
COORDINATE MOUNTING HEIGHTS WITH MILLWORK
-  DUPLEX CONVENIENCE OUTLET 18" AFF GROUND FAULT INTERRUPTER TYPE
-  DUPLEX CONVENIENCE OUTLETS 6" ABOVE COUNTER/BACKSPASH, 48" AFF MAX TO TOP OF BOX. COORDINATE MOUNTING HEIGHTS WITH MILLWORK. GROUND FAULT INTERRUPTER TYPE
-  DUPLEX CONVENIENCE OUTLET 18" AFF WEATHERPROOF GROUND FAULT INTERRUPTER TYPE
-  DUPLEX RECEPTACLE - CONCEAL BEHIND OR WITHIN ENCLOSURE OF ELECTRIC WATER COOLER.
-  QUADRUPLEX CONVENIENCE OUTLET 18" AFF
-  TELEPHONE BOARD 48" x 96" x 3/4" SHEETS OF FIRE TREATED PLYWOOD  
PROVIDE BACKBOARD ON THREE SIDES OF IT ROOM AS INDICATED.
-  COMBINATION DATA/VOICE OUTLET 18" AFF
-  MOTOR - SEE SCHEDULE
-  SPECIAL OUTLET - SEE SCHEDULE
-  CEILING-MOUNTED OCCUPANCY SENSOR - HUBBELL OMNI DT OR APPROVED EQUAL
-  WALL-SWITCH OCCUPANCY SENSOR 48" AFF  
HUBBELL LIGHTHAWK DT OR APPROVED EQUAL
-  WALL MOUNTED OCCUPANCY SENSOR 48" AFF  
HUBBELL OL DT OR APPROVED EQUAL
-  WALL-SWITCH OCCUPANCY SENSOR / DIMMER 48" AFF  
HUBBELL LIGHTHAWK2 DIMMING OR APPROVED EQUAL
-  FLOW SWITCH
-  TAMPER SWITCH
-  FIRE ALARM CONTROL PANEL (FACP)
-  REMOTE ANNUNCIATOR PANEL
-  GENERATOR REMOTE ANNUNCIATOR
-  FIRE ALARM MANUAL PULL STATION 48" AFF TOP OF BOX
-  FIRE ALARM AUDIO/VISUAL DEVICE 80" AFF
-  FIRE ALARM WALL MOUNTED VISUAL DEVICE 80" AFF
-  FIRE ALARM CEILING MOUNTED SMOKE DETECTOR
-  FIRE ALARM CEILING MOUNTED HEAT DETECTOR
-  WIRELESS ACCESS POINT (WAP)




JOHNSON, LASCOR & ASSOCIATES, P.C.  
AUGUSTA, GA • MT. PLEASANT, SC  
TEL: (706) 724-5756 • TEL: (843) 619-4656  
FAX: (706) 724-3935  
WWW.THEJLAGROUP.COM

CLIENT: AUGUSTA, GA  
535 TELFAIR STREET, AUGUSTA, GA 30901

PROJECT NAME: FIRE STATION #2

PROJECT LOCATION: 928 TELFAIR ST., AUGUSTA, GA 30901



8/29/18

REV	DATE	BY	ISSUED FOR PERMITTING	DESCRIPTION
0	08/29/18	FAK		

PROJECT NO. 3042.1604  
DRAWN BY: JAP/JFP  
CHECKED BY: FAK  
DATE: 10/18/17

SHEET TITLE:  
**ELECTRICAL GENERAL NOTES AND LEGEND**

SCALE: AS NOTED  
DRAWING NO. **E-001** REV. 0

Order Plans @

WWW.LDOnline.com

This document is the property of Johnson, Lascobor & Associates, P.C. The unauthorized reproduction, copying or otherwise use of this document is strictly prohibited and any infringement thereupon may be subject to legal action.