

Order Plans @ www.dline.com

-- FAN SCHEDULE --							
ITEM	LOCATION	C.F.M.	S.P.	HP.	R.P.M.	MAX SONES	REMARKS (1)
F-1	TLT 109/112	140	0.25	1/60	1300	2.8	G-070-G (1)(3)
F-2	TLT 104/105/116	210	0.25	1/30	1550	4.4	G-070-D (1)(2)
F-3	TLT 124	70	0.20	1/60	1330	3.5	G-060-D (1)(3)
F-4	TLT 137/163	800	0.25	1/8	1487	8.7	G-095-D (1)(2)
F-5	KILN 141	1020	0.50	1/4	1725	12.8	G-099-A (1)(6)
F-6	ROOM 152/153/154	350	0.25	1/25	1300	5.5	G-090-G (1)(2)
F-7	ELEC 157	700	0.125	1/15	1550	7.5	G-090-D (1)(4)
F-8	KITCHEN 148	1000	0.30	1/4	1725	12.8	G-099-A (1)(7)
F-9	DISHWASH 146	1400	0.30	1/6	1140	9.3	G-133-B (1)(5)
F-10	CUSTODIAN 302	100	0.125	1/100	1300	2.7	G-060-G (1)(3)
F-11	ELECTRICAL 307	500	0.125	1/25	1300	5.5	G-090-G (1)(4)
F-12	STORAGE 306	500	0.125	1/25	1300	5.5	G-090-G (1)(4)
F-13	STORAGE 305	530	0.125	1/30	1050	4.5	G-095-E (1)(4)
F-14	TLT 303/304	280	0.25	1/30	1050	4.5	G-095-E (1)(2)
F-15	TLT 418/419	980	0.25	1/6	1688	10.2	G-095-VG (1)(2)
F-16	MECHANICAL 435	400	0.125	1/40	1050	3.9	G-090-E (1)(4)
F-17	CUSTODIAN 436	150	0.125	1/100	1050	1.5	G-070-E (1)(2)
F-18	TLT 442/443	280	0.30	1/25	1300	5.5	G-090-G (1)(2)
F-19	ELECTRICAL 417	500	0.125	1/25	1300	5.5	G-090-G (1)(4)
F-20	TLT 400/415	140	0.25	1/60	1300	2.8	G-070-G (1)(3)
F-21	ROOMS 410/451	200	0.25	1/30	1550	4.4	G-070-D (1)(3)
F-22	TLT 236	70	0.20	1/60	1330	3.5	G-060-D (1)(3)
F-23	CUSTODIAN 218	150	0.125	1/100	1050	1.5	G-070-E (1)(2)
F-24	ROOM 210	130	0.125	1/100	1050	1.5	G-070-E (1)(4)
F-25	TLT 213	70	0.20	1/60	1330	3.5	G-060-D (1)(3)
F-26	TLT 211/212	980	0.25	1/6	1688	10.2	G-095-VG (1)(2)
F-27	ELECTRICAL 215	600	0.125	1/15	1550	7.5	G-090-D (1)(4)
F-28	TLT 235	70	0.20	1/60	1330	3.5	G-060-D (1)(3)
F-29	MECHANICAL 159	500	0.125	1/25	1300	5.5	G-090-G (1)(4)

- (1) COMPLETE WITH BACKDRAFT DAMPER, ADAPTOR CURB, BIRDSCREEN AND DISCONNECT MEANS.
- (2) CONTROL WITH FACILITY MANAGEMENT SYSTEM (OR TIME CLOCK).
- (3) SWITCH WITH ROOM LIGHTS. FURNISH CONTACTORS AS REQUIRED.
- (4) CONTROL WITH THERMOSTAT SET AT 85° (ADI.).
- (5) INTERLOCK CONTROL WITH DISHWASHER.
- (6) CONTROL WITH FACILITY MANAGEMENT SYSTEM USING INTERVAL TIMER.
- (7) CONTROL WITH WALL SWITCH BY DIV. 16.

-- WALL MOUNT GAS UNIT --										
ITEM	SUPPLY C.F.M.	EXT. S.P. W.C.	O.A. C.F.M.	COOLING CAP. MBH (1)	E.E.R. MIN.	HEATING CAP. (1)		MODEL NO. (2)(3)(4)		
						INPUT	OUTPUT			
WGU-1	1000	0.15	200	35.0	10.2	68,000	55,500	BARO W36G		
WGU-2	1000	0.15	200	35.0	10.2	68,000	55,500	BARO W36G		
WGU-3	1000	0.15	200	35.0	10.2	68,000	55,500	BARO W36G		
WGU-4	1000	0.15	200	35.0	10.2	68,000	55,500	BARO W36G		
WGU-5	1000	0.15	200	35.0	10.2	68,000	55,500	BARO W36G		
WGU-6	1000	0.15	200	35.0	10.2	68,000	55,500	BARO W36G		
WGU-7	1000	0.15	200	35.0	10.2	68,000	55,500	BARO W36G		
WGU-8	1000	0.15	200	35.0	10.2	68,000	55,500	BARO W36G		
WGU-9	1000	0.15	200	35.0	10.2	68,000	55,500	BARO W36G		
WGU-10	1000	0.15	200	35.0	10.2	68,000	55,500	BARO W36G		
WGU-11	1000	0.15	200	35.0	10.2	68,000	55,500	BARO W36G		
WGU-12	1000	0.15	200	35.0	10.2	68,000	55,500	BARO W36G		
WGU-13	1000	0.15	200	35.0	10.2	68,000	55,500	BARO W36G		
WGU-14	1000	0.15	200	35.0	10.2	68,000	55,500	BARO W36G		
WGU-15	1000	0.15	200	35.0	10.2	68,000	55,500	BARO W36G		
WGU-16	1000	0.15	200	35.0	10.2	68,000	55,500	BARO W36G		
WGU-17	1000	0.15	200	35.0	10.2	68,000	55,500	BARO W36G		
WGU-18	1000	0.15	200	35.0	10.2	68,000	55,500	BARO W36G		
WGU-19	1000	0.15	200	35.0	10.2	68,000	55,500	BARO W36G		
WGU-20	1000	0.15	200	35.0	10.2	68,000	55,500	BARO W36G		
WGU-21	1000	0.15	200	35.0	10.2	68,000	55,500	BARO W36G		
WGU-22	1000	0.15	200	35.0	10.2	68,000	55,500	BARO W36G		
WGU-23	1000	0.15	200	35.0	10.2	68,000	55,500	BARO W36G		
WGU-24	1000	0.15	200	35.0	10.2	68,000	55,500	BARO W36G		
WGU-25	1000	0.15	200	35.0	10.2	68,000	55,500	BARO W36G		
WGU-26	1000	0.15	200	35.0	10.2	68,000	55,500	BARO W36G		
WGU-27	1000	0.15	200	35.0	10.2	68,000	55,500	BARO W36G		
WGU-28	1000	0.15	200	35.0	10.2	68,000	55,500	BARO W36G		
WGU-29	1000	0.15	200	35.0	10.2	68,000	55,500	BARO W36G		
WGU-30	1000	0.15	200	35.0	10.2	68,000	55,500	BARO W36G		
WGU-31	1000	0.15	200	35.0	10.2	68,000	55,500	BARO W36G		
WGU-32	1000	0.15	200	35.0	10.2	68,000	55,500	BARO W36G		
WGU-33	1000	0.15	200	35.0	10.2	68,000	55,500	BARO W36G		
WGU-34	1000	0.15	200	35.0	10.2	68,000	55,500	BARO W36G		
WGU-35	1000	0.15	200	35.0	10.2	68,000	55,500	BARO W36G		
WGU-36	1000	0.15	200	35.0	10.2	68,000	55,500	BARO W36G		
WGU-37	1000	0.15	200	35.0	10.2	68,000	55,500	BARO W36G		
WGU-38	1000	0.15	200	35.0	10.2	68,000	55,500	BARO W36G		

- (1) NOT USED.
- (2) FURNISH ION GENERATOR AS SCHEDULED.
- (3) UNITS SHALL HAVE INTEGRAL DISCONNECTS AND HOT GAS REHEAT DEHUMIDIFICATION SYSTEM.
- (4) UNITS SHALL HAVE WALL MOUNTED ADAPTOR CURB.

-- INDOOR HEAT PUMP SCHEDULE --										
ITEM	LOCATION	SUPPLY C.F.M.	EXT. S.P. (IN.) W.C.	O.A. C.F.M.	FAN HP.	DRIVE	COOLING CAP. MBH (1)		MODEL NO.	REMARKS
							SENSIBLE	TOTAL		
IHP-1	DRY FOOD 149	400	0.0	--	1/25	DIR.	3.1	2.6	MSZ-FH09NA	(2)(3)
IHP-2	TESTING 411	90	0.0	--	1/25	DIR.	2.0	1.7	MSZ-FH09NA	(3)
IHP-3	TIMEOUT 412	90	0.0	--	1/25	DIR.	2.0	1.7	MSZ-FH09NA	(3)
IHP-4	LOUNGE 414	70	0.0	--	1/25	DIR.	2.8	1.7	MSZ-FH09NA	(3)
IHP-5	LOUNGE 214	70	0.0	--	1/25	DIR.	2.8	1.7	MSZ-FH09NA	(3)

- (1) RATINGS IN ACCORDANCE WITH A.R.I. STANDARD 240.
- (2) PROVIDE GRAVITY FED CONDENSATE PUMP KIT FOR NEW INDOOR HEAT PUMP. RECTORSER OR EQUIVALENT MANUFACTURER. COLOR OF CONDENSATE PUMP SHALL MATCH COLOR OF INDOOR UNIT.
- (3) PROVIDE LINE HIDE KIT FOR NEW INDOOR HEAT PUMP.

-- OUTDOOR HEAT PUMP SCHEDULE --									
ITEM	COOLING CAP. MBH (1)	E.E.R. MIN.	HEATING CAP. MBH (1)			C.O.P. (1)		MODEL NO.	
			HI	LO	HI	LO	HI		
OHP-1	6.0	19.1	8.7	1.6	4.68	2.80		MUZ-FH09NA	
OHP-2	6.0	19.1	14.0	1.7	4.68	2.80		MUZ-FH09NA	
OHP-3	6.0	19.1	14.0	1.7	4.68	2.80		MUZ-FH09NA	
OHP-4	6.0	19.1	8.7	1.1	4.68	2.80		MUZ-FH09NA	
OHP-5	6.0	19.1	8.7	1.1	4.68	2.80		MUZ-FH09NA	

- (1) RATINGS IN ACCORDANCE WITH A.R.I. STANDARD 240.

-- ELECTRIC HEATER SCHEDULE --			
ITEM	LOCATION	WATTS	Q-MARK MODEL NO.
CH-1	CORRIDOR 217	4000	CU-900 SERIES (1)
CH-2	CORRIDOR 161	4000	CU-900 SERIES (1)
CH-3	TOILET 154	3000	CU-900 SERIES (1)
CH-4	CUSTODIAN 153	4000	CU-900 SERIES (1)
CH-5	NOT USED	--	--
CH-6	NOT USED	--	--
CH-7	VESTIBULE 145	5000	CU-900 SERIES (1)
CH-8	VESTIBULE 201	5000	CU-900 SERIES (1)
CH-9	BOYS TOILET 211	3000	CU-900 SERIES (1)
CH-10	GIRLS TOILET 212	3000	CU-900 SERIES (1)
CH-11	CORRIDOR 217	5000	CU-900 SERIES (1)
CH-12	TOILET 235	3000	CU-900 SERIES (1)
CH-13	TOILET 236	3000	CU-900 SERIES (1)
CH-14	CORRIDOR 227	5000	CU-900 SERIES (1)
CH-15	STORAGE 306	4000	CU-900 SERIES (1)
CH-16	STORAGE 305	4000	CU-900 SERIES (1)
CH-17	BOYS TOILET 304	3000	CU-900 SERIES (1)
CH-18	GIRLS TOILET 303	3000	CU-900 SERIES (1)
CH-19	VESTIBULE 401	5000	CU-900 SERIES (1)
CH-20	TOILET 451	3000	CU-900 SERIES (1)
CH-21	TESTING 411	4000	CU-900 SERIES (1)
CH-22	TIMEOUT 412	4000	CU-900 SERIES (1)
CH-23	VESTIBULE 416	5000	CU-900 SERIES (1)
CH-24	GIRLS TOILET 418	3000	CU-900 SERIES (1)
CH-25	BOYS TOILET 419	3000	CU-900 SERIES (1)
CH-26	CORRIDOR 1/M2.02	5000	CU-900 SERIES (1)
CH-27	GIRLS TOILET 442	3000	CU-900 SERIES (1)
CH-28	BOYS TOILET 4		