



NOTES:

1. ROUTE DUCTWORK ENTIRELY THROUGH STRUCTURE.
2. 16" HOOD DUCT COLLAR CONNECTION SIZE. CONNECT TO RECTANGULAR DUCTWORK. DUCT SHALL BE STAINLESS STEEL. GREASE DUCT LISTED AND LABELED IN ACCORDANCE WITH UL 157B BY CAPTURE AREA OR APPROVED EQUAL. MAIN TRUNK DUCT SHALL BE FULLY WELDED BLACK STEEL WITH (2) LAYERS OF DUCT FIRE WRAP.
3. 24x10 HOOD DUCT COLLAR CONNECTION SIZE (TYPICAL OF 3). BALANCE AIRFLOW TO 640 CFM EACH.
4. 26x8 HOOD DUCT COLLAR CONNECTION SIZE (TYPICAL OF 2). BALANCE AIRFLOW TO 360 CFM EACH.
5. EQUIPMENT SHOWN TO BE PROVIDED BY OTHERS BUT INSTALLED BY MECHANICAL CONTRACTOR.
6. FIELD VERIFY EXHAUST AND MAKE UP AIR CONNECTIONS. DUCT SIZES SHALL MATCH CONNECTION SIZES.
7. 24x4 DUCT DOWN TO TYPE 'G' GRILLE. CONNECT TO DUCTWORK. SIZE OF GRILLE SHALL BE MOUNT GRILLE 36" AFF.
8. MOUNT TEMPERATURE SENSOR IN SUPPLY DUCTWORK BEFORE TAKEOFFS AND ROUTE CONTROL WIRE TO ASSOCIATED THERMOSTAT.
9. 24x4 DUCT DOWN TO TYPE 'G' GRILLE. CONNECT TO FULL SIZE GRILLE. MOUNT GRILLE 72" AFF.
10. REFRIGERANT PIPING LAYOUT IS SCHEMATIC IN NATURE. CONTRACTOR SHOULD FOLLOW MANUFACTURER'S REQUIREMENTS FOR SIZING AND ROUTING.

Order Plans @

WWW.DULOHERYWEKS.COM



PARKER'S CANE BAY

THE PARKER COMPANIES
17 WEST MCCONOUGH ST.
SAVANNAH, GA 31401

Parkers



Revisions

NO.	DATE	DESCRIPTION

MECHANICAL PLAN

Scale: 1/4" = 1'-0"
Date: 07/01/19
Project: P-100
Drawing No. M101

M101



1/4" = 1'-0"
FIRST FLOOR PLAN MECHANICAL

2/1/2019 9:13:59 AM