


WWW.LDOnline.com

GENERAL NOTES:
 A. ALL CONDUITS TO HAVE FIRST JOINT OUT OF THE GROUND AT EACH END TO BE THREADABLE WITH A POURABLE SEAL-OFF.
 B. COORDINATE UNDERGROUND TANK AND FUEL PUMP QUANTITIES AND LOCATIONS WITH OWNER AND FUEL EQUIPMENT INSTALLER PRIOR TO ORDERING MATERIALS AND PRIOR TO ROUGH-IN, NO EXCEPTIONS. COORDINATE ELECTRICAL REQUIREMENTS.

- NOTES:**
1. PROVIDE 1-3/4" C WITH 3 #12 THHN FOR SUB PUMP MOTOR AND 1-3/4" C WITH 4 SHIELDED PAIR 18G TEFLON COATED WIRE FOR SUB PUMP SUMP.
 2. PROVIDE 1-3/4" C WITH 3 #12 THHN FOR SUB PUMP MOTOR AND 1-3/4" C WITH 3 SHIELDED PAIR 18G TEFLON COATED WIRE FOR SUB PUMP SUMP.
 3. PROVIDE 1-3/4" C WITH 3 #12 THHN FOR SUB PUMP MOTOR AND 1-3/4" C WITH 2 SHIELDED PAIR 18G TEFLON COATED WIRE FOR SUB PUMP SUMP.
 4. PROVIDE AT MDP: 1-3/4" C WITH 6 #14 THHN AND 4 #16 THHN 1-3/4" C WITH 1 SHIELDED PAIR 18G TEFLON COATED WIRE AND 1-3/4" C WITH 2 SHIELDED PAIR 18G TEFLON COATED WIRE.
 5. PROVIDE AT MDP: 1-3/4" C WITH 6 #14 THHN AND 4 #16 THHN 1-3/4" C WITH 1 SHIELDED PAIR 18G TEFLON COATED WIRE.
 6. PROVIDE 2-3/4" C. AT COLUMN FOR CANOPY LIGHTING, ETC. COORDINATE EXACT WIRING REQUIREMENTS.
 7. PROVIDE 1-3/4" C WITH 2 SHIELDED PAIR 18G TEFLON COATED WIRE AND LOOP BETWEEN EACH MDP AS INDICATED ON DRAWING.





LYNCH
ENGINEERING

400 East Lenoir Street
 Savannah, GA 31401
 Phone: 912.433.1110
 Fax: 912.433.1119
 www.lynch-engineering.com

PARKER'S CANE BAY

THE PARKER COMPANIES
 17 WEST MCDONOUGH ST.
 SAVANNAH, GA 31401

Parkers

Revisions

NO.	DATE	DESCRIPTION

FUEL CANOPY DETAILS

Title: _____
 Date: _____
 Project: _____
 Drawing #: _____

E003

NOT TO SCALE
 FUEL ISLAND ELECTRICAL

Order Plans



2/1/2019 9:21:07 AM