


PARKER'S CANE BAY

THE PARKER COMPANIES
17 WEST MCCONOUGH ST.
SAVANNAH, GA 31401

Parkers



Revisions

NO.	DATE	DESCRIPTION

FIRST FLOOR
PLAN-POWER


Scale: 1/4" = 1'-0"
Date: 07/01/19
Project: P-19-001
Drawing: P-19-001

E201



1/4" = 1'-0"
FIRST FLOOR PLAN-POWER

2/1/2019 9:21:15 AM



- NOTES:**
- PROVIDE (8) 1/2" WITH SEAL-OFFS FROM TELEPHONE BACKBOARD TO MDP'S. EACH MDP SHALL HAVE (1) 1/2" STUBBED UP FROM TELEPHONE BACKBOARD.
 - FOR COMMERCIAL MICROWAVE MOUNTED IN CASEWORK, COORDINATE MOUNTING HEIGHT WITH CASEWORK INSTALLER.
 - FOR AUTOMATIC FLUSHING URINAL SENSOR, COORDINATE LOCATION WITH AND REQUIREMENTS WITH URINAL INSTALLER.
 - PROVIDE JUNCTION BOX AT THIS LOCATION FOR DOOR LOCK. PROVIDE 3/4" TO TELEPHONE BACKBOARD FOR DOOR LOCK. COORDINATE EXACT CONNECTION REQUIREMENTS WITH SYSTEM INSTALLER.
 - PROVIDE CONNECTION AT EACH FREEZER/COOLER DOOR FOR HEATERS AS REQUIRED.
 - STUB OUT (16) 3/4". WITH SEAL-OFFS UNDER EACH BEVERAGE PANEL F.
 - STUB OUT (10) 3/4". WITH SEAL-OFFS BEYOND TRUCK UNDER TANK MONITOR.
 - EXTEND (2) 1/2" FROM TELEPHONE BACKBOARD TO COUNTER.
 - EXTEND (6) TO GROUND BUSBAR IN PANEL AND BUILDING REBAR GROUND AT 40' UNLESS NOTED IN FIELD. SEE GROUND DETAIL ON SHEET 100.
 - STUB OUT (2) 1/2" AT PANEL EDP FOR LIGHTNING PROTECTION AND IRRIGATION.
 - STUB OUT (2) 1/2" TO PROPERTY LINE FOR TELEPHONE AND INTERNET UTILITY. COORDINATE EXACT LOCATION IN FIELD.
 - PROVIDE (1) 1/2" THROUGH ROOF FOR SECURITY LOTTO ABOVE TELEPHONE BACKBOARD.
 - STUB OUT (1) 1/2" AT EACH BUILDING CORNER FOR LIGHTNING PROTECTION. EXTEND THROUGH ROOF AND INTO GRASS ISLANDS.
 - EXTEND 3/4" FROM ATM MACHINE TO TELEPHONE BACKBOARD.
 - EMERGENCY STOP SWITCH FOR PANEL F.
 - STUB OUT (2) 3/4" FOR DATA FROM OFFICE TO SIGNS.
 - EXTEND (2) 2" EACH TO OFFICE FROM TELEPHONE BACKBOARD.
 - FOR LOTTERY MACHINE, COORDINATE EXACT LOCATION OF MACHINE WITH OWNER PRIOR TO ROUGH-IN.
 - PROVIDE 3 JUNCTION BOXES WITH 3/4" STUBBED ABOVE CEILING FOR THERMOSTAT WIRES. COORDINATE WITH MECHANICAL CONTRACTOR.
 - EQUIPMENT FED FROM CONDENSERS ON ROOF.
 - STUB OUT (2) 3/4" FROM ISLANDS TO TELEPHONE BACKBOARD FOR CAMERAS.
 - PROVIDE 1" FROM FIRST ATM DATA TO SECOND ATM DATA.
 - INTERLOCK RANGE HOOD FIRE SUPPRESSION SYSTEM WITH SHUNT TRIP BREAKERS SERVING EQUIPMENT UNDER THE HOOD SUCH THAT UPON ACTIVATION ALL POWER IS SHUT OFF. RANGE HOOD EXHAUST FAN SHALL REMAIN ON AND MAKE-UP AIR FAN AND RHP-3 SHALL BE SHUT OFF.
 - STUB UP ALL CONDUITS FOR COUNTER IN ONE LOCATION. COORDINATE LOCATION WITH ARCHITECT.
 - FOR FLY CONTROL, MOUNT AT 80" AFF. PROVIDE RECESSED CLOCK RECEPTACLE. BASIS OF DESIGN IS HUBBELL RR201CHWTR OR EQUAL.
 - STUB UP 1" FROM IT BACKBOARD FOR DATA CABLING.
 - PROVIDE DATA JUNCTION BOX ON EXTERIOR OF BUILDING IN WEATHERPROOF ENCLOSURE FOR SERVICE ANTENNA. COORDINATE EXACT LOCATION AND MOUNTING HEIGHT OF DATA JUNCTION BOX WITH OWNER PRIOR TO ROUGH-IN.
 - PROVIDE 1-1/4" ROUTED TO ELECTRICAL PANELS FOR FUTURE USE. MOUNT BELOW COUNTER AT 36" AFF.
 - PROVIDE 1" FLEXIBLE CONDUIT FROM DATA JUNCTION BOX TO ABOVE CEILING FOR FUTURE USE.
 - PROVIDE 3/4" STUBBED BELOW SPRAYED INSULATION THROUGH WALL FOR CAMERAS.
 - PROVIDE JUNCTION BOX ABOVE CEILING FOR CAMERA WIRE AT DOOR.
 - PROVIDE 3/4" TO TELEPHONE BACKBOARD FOR LOTTERY.

Order Plans @

WWW.LDLINE.COM