



1 SECOND FLOOR PLAN - LIFE SAFETY
 A1.2 SCALE: 1/8" = 1'-0"

LEGEND	
FIRE RATED WALLS AND BARRIERS	
	ONE HOUR RATED BARRIER (LSC SECTION 8.2.3, IBC 706 AND/OR 706)
	TWO HOUR RATED BARRIER
	THREE HOUR RATED BARRIER (LSC SECTION 8.2.3, IBC SECTION 706 AND/OR 706)
PARTITIONS AND NON-RATED WALLS	
	SMOKE PARTITION WALL (LSC SECTION 101.8.2.4)
	SMOKE PARTITIONS SHALL COMPLY WITH ALL WALLS, SERVING EDUCATION OCCUPANCY
	SMOKE PARTITIONS SHALL COMPLY WITH ALL WALLS, SERVING EDUCATION OCCUPANCY
	SMOKE PARTITIONS SHALL COMPLY WITH ALL WALLS, SERVING EDUCATION OCCUPANCY
	NON-SMOKING PARTITIONS: ONLY CHAIR WALLS AND ADJACENT PRIVATE CLOSETS IN
	RECESSED AND AS NOTED ON PLANS, TO EXTEND 8" ABOVE CEILING MINIMUM
	CABINET WITH MULTIPURPOSE DRY CHEMICAL EXTINGUISHER (MULTIPURPOSE)
	CABINET WITH CARBON DIOXIDE EXTINGUISHER (ELECTRICAL FIRES)
	CABINET WITH DRY CHEMICAL EXTINGUISHER (KITCHEN FIRES)
	BRACKET MOUNTED MULTIPURPOSE DRY CHEMICAL EXTINGUISHER (MULTIPURPOSE)
	BRACKET MOUNTED CARBON DIOXIDE EXTINGUISHER (ELECTRICAL FIRES)
	BRACKET MOUNTED DRY CHEMICAL EXTINGUISHER (KITCHEN FIRES)

LIFE SAFETY NOTES

- A. GENERAL NOTES**
- IT SHALL BE THE RESPONSIBILITY OF THE GENERAL CONTRACTOR TO HAVE, ON SITE, A COPY OF ANY AND ALL UL DESIGNS OR REGULATIONS CITED BY, BUT NOT LIMITED TO ARCHITECT ENGINEER, MANUFACTURER OR SUBCONTRACTOR.
 - CODES ENFORCED BUT NOT LIMITED TO THE FOLLOWING - IBC, IECC, IFC, IMC, IPC, OF THE ICC 2006 ED. WITH GEORGIA DCA AMENDMENTS, NFPA 101, 2000 ED., NATIONAL FIRE CODE 2006 ED., WI 120-3-3 GEORGIA MIN. FIRE SAFETY STD., 2010 ADA STANDARDS FOR ACCESSIBLE DESIGN.
 - FIRE EXTINGUISHER, INDICATED AS "FE 3", TO BE LOCATED NO LESS THAN 15 FEET FROM ANY RESIDENTIAL STOVE OR COMMERCIAL COOKING EQUIPMENT.
 - FIRE EXTINGUISHER, INDICATED AS "FE 2 OR FEC 2", TO BE LOCATED IN ALL ELECTRICAL AND MECHANICAL ROOMS.
- B. SMOKE PARTITIONS AND NON RATED WALLS**
- ALL WALLS (CONC. MASONRY AND METAL STUD WITH GYPSUM BOARD) SHALL EXTEND TO THE FLOOR OR ROOF DECK ASSEMBLY ABOVE (UNLESS NOTED OTHERWISE).
 - IF C.M.U. IS NOT REQUIRED STRUCTURALLY, THE WALL MAY CHANGE FROM C.M.U. TO METAL STUD 8" ABOVE CEILING UNLESS NOTED OTHERWISE. METAL STUD SIZE SHOULD MEET THE MINIMUM SPECIFIED REQUIREMENT WITH GYPSUM BOARD ON BOTH SIDES AND ACCOUSTICAL BATT. SEAL OPENINGS, PENETRATIONS AND INTERSECTIONS TO RESIST SOUND TRANSFER.
 - SMOKE PARTITIONS SHALL EXTEND TO FLOOR OR ROOF ASSEMBLY ABOVE. IF CMU IS NOT REQUIRED STRUCTURALLY, THE WALL MAY CHANGE FROM CMU TO METAL STUDS 8" ABOVE CEILING UNLESS NOTED OTHERWISE. SEAL OPENINGS, PENETRATIONS, AND INTERSECTIONS TO RESIST PASSAGE OF SMOKE. DOORS IN SMOKE PARTITIONS SHALL BE SELF-CLOSING OR AUTOMATIC CLOSING (EXCEPT IN CLASSROOMS).
 - ALL CORRIDORS TO BE SMOKE PARTITIONS. ALL GLAZING IN SMOKE PARTITION CORRIDOR WALLS TO BE SMOKE RESISTANT.
- C. RATED WALLS/BARRIERS**
- EXTEND ALL FIRE RATED PARTITIONS TO FLOOR OR ROOF DECK ASSEMBLY (UNLESS NOTED OTHERWISE). SEAL BETWEEN PARTITIONS AND THE ASSEMBLIES WITH MATERIALS SPECIFIED & REQUIRED TO MAINTAIN INDICATED RATING.
 - SEAL ALL PENETRATIONS THROUGH RATED PARTITIONS AND ASSEMBLIES WITH MATERIAL AND METHODS REQUIRED TO MAINTAIN RATINGS AND AS REQUIRED BY LOCAL AUTHORITIES.
 - 1 HR. RATED METAL STUD WALLS SHALL COMPLY WITH UL #465. 2 HR. RATED METAL STUD WALLS SHALL COMPLY WITH UL #425.

JOHN A. TUTEN & ASSOCIATES
 ARCHITECTS
 4680 U.S. HIGHWAY 17, SUITE 100
 BRUNSWICK, GEORGIA 31525
 www.jatuten.com

GLYNN ACADEMY HIGH SCHOOL
 SCIENCE BLDG. (5015) MODERNIZATION
 1001 MANSFIELD ST. BRUNSWICK GA, 31520
 GLYNN COUNTY BOARD OF EDUCATION

CAPITAL OUTLAY
 PROJECT # TBD
 SYSTEM CODE: 663
 SCHOOL CODE: 4752
 FTE: 1793

SECOND FLOOR PLAN - LIFE SAFETY

ISSUED FOR:
 BID SET

DRAWN BY:
 CHECKED BY:
 APPROVED BY:
 01/19/19
 PROJECT DATE:
 1802
 PROJECT NUMBER

SHEET NUMBER:
A1.2

Copyright (c) 2019
 All Rights Reserved

1/18/2019 11:22:23 C:\Users\jmt\Documents\Revit\Local1802_GA_Science Building\1802_Science Building.rvt