

SCOPE: This NOA is being issued under the applicable rules and regulations governing the use of construction materials. The documentation submitted has been reviewed and accepted by Miami-Dade County RER - Product Control Section to be used in Miami Dade County and other areas where allowed by the Authority Having Jurisdiction (AHJ).

This NOA shall not be valid after the expiration date stated below. The Miami-Dade County Product Control Section (in Miami Dade County) and/or the AHJ (in areas other than Miami Dade County) reserve the right to have this product or material tested for quality assurance purposes. If this product or material fails to perform in the accepted manner, the manufacturer will incur the cost of such testing and the AHJ may immediately revoke, modify, or suspend the use of such product or material within their jurisdiction. RER reserves the right to revoke this acceptance, if it is determined by Miami-Dade County Product Control Section that this product or material fails to meet the requirements of the applicable building code.

This product is approved as described herein, and has been designed to comply with the Florida Building Code, including the High Velocity Hurricane Zone.

DESCRIPTION: Series "550 IR" Aluminum Outswinging Storefront Door-L.M.I. APPROVAL DOCUMENT: Drawing No. 1569 Rev D, titled "350 IR 9' Outswinging Aluminum Storefront Doors - L.M.I.", sheets 1 through 9 of 9, prepared by W.W. Schaefer Engineering & Consulting, P.A., dated 04/02/08 and last revised on June 11, 2015, signed and sealed by Warren W. Schaefer, P.E., bearing the Miami-Dade County Product Control Revision stamp with the Notice of Acceptance number and expiration date by the Miami-Dade County Product Control Section.

MISSILE IMPACT RATING: Large and Small Missile Impact Rating.

Limitations: 1. See sheet 1 for door size & 3-point lock option and sheet 2 for door size & Panic lock options 2, 3 & 4. 2. Doors are not rated/approved, where water infiltration is required unless overhang complying w/FBC requirements.

3. When doors are installed into Kawneer's Storefronts or Curtain Wall System (under separate approval), such system must provide reinforced mullions per detail G17 & G27, proper Door opening sizes limitations and door mullion and anchors and to be reviewed by Building Official. Lower Design Pressure of the Door or the System shall control the entire assembly.

LABELING: Each unit shall bear a permanent label with the manufacturer's name or logo, city, state, model/series, and following statement: "Miami-Dade County Product Control Approved", unless otherwise noted herein.

RENEWAL of this NOA shall be considered after a renewal application has been filed and there has been no change in the applicable building code negatively affecting the performance of this product.

TERMINATION of this NOA will occur after the expiration date or if there has been a revision or change in the materials, use, and/or manufacture of the product or process. Misuse of this NOA, as an endorsement of any product, for sales, advertising or any other purposes shall automatically terminate this NOA. Failure to comply with any section of this NOA shall be cause for termination and removal of NOA.

ADVERTISEMENT: The NOA number provided for the words Miami-Dade County, Florida, and

NOA No. 15-0622.11 Expiration Date: April 23, 2019 Approval Date: February 19, 2016 Page 1

followed by the expiration date may be displayed in advertising literature. If any portion of the NOA is displayed, then it shall be done in its entirety.

INSPECTION: A copy of this notice NOA shall be provided to the user by the manufacturer or its distributors and shall be available for inspection at the job site at the request of the Building Official. This NOA revises NOA# 14-0622.01 and consists of page 1, this page 2 and evidence pages E-1 and E-2, as well as approval document mentioned above. The submitted documentation was reviewed by Jorge M. Plasencia, P.E.

NOA No. 15-0622.11 Expiration Date: April 23, 2019 Approval Date: February 19, 2016 Page 2

NOTICE OF ACCEPTANCE EVIDENCE SUBMITTED

- A. DRAWINGS 1. Manufacturer's die drawings and sections. (Submitted under previous NOA No. 14-0622.01 & 11-1071.15) 2. Drawing No. 1569 Rev D, titled "350 IR 9' Outswinging Aluminum Storefront Doors - L.M.I.", sheets 1 through 9 of 9, prepared by W.W. Schaefer Engineering & Consulting, P.A., dated 04/02/08 and last revised on June 11, 2015, signed and sealed by Warren W. Schaefer, P.E.

- B. TESTS 1. Test reports on: 1) Uniform Static Air Pressure Test, Loading per FBC TAS 202-94 2) Large Missile Impact Test per FBC, TAS 201-94 3) Cyclic Wind Pressure Loading per FBC, TAS 203-94 4) Forced Entry Test, per FBC 2411.3.2.1, TAS 202-94 along with marked-up drawings and installation diagrams of aluminum 9' Tall 350 IR Doors with Trifab 350 Swinging Doors - Double, prepared by Architectural Testing, Test Reports No. E0437-01-550-18, dated 12/15/14, signed and sealed by Shawn G. Collins, P.E.

- 2. Test reports on: 1) Air Infiltration Test, per FBC, TAS 202-94 2) Uniform Static Air Pressure Test, Loading per FBC TAS 202-94 3) Large Missile Impact Test per FBC, TAS 201-94 4) Cyclic Wind Pressure Loading per FBC, TAS 203-94 5) Forced Entry Test, per FBC 2411.3.2.1, TAS 202-94 along with marked-up drawings and installation diagrams of aluminum outswinging storefront doors, prepared by Architectural Testing, Test Reports No. D3741-01-550-18, dated 04/23/14, signed and sealed by Vinm J. Abraham, P.E. (Test report revised by addendum letter dated Nov 07, 2014, issued by Architectural Testing). (Submitted under NOA No. 14-0622.01)

- 3. Test reports on: 1) Air Infiltration Test, per FBC, TAS 202-94 2) Uniform Static Air Pressure Test, Loading per FBC TAS 202-94 3) Large Missile Impact Test per FBC, TAS 201-94 4) Cyclic Wind Pressure Loading per FBC, TAS 203-94 5) Forced Entry Test, per FBC 2411.3.2.1, TAS 202-94 along with marked-up drawings and installation diagrams of aluminum outswinging storefront doors, prepared by Hurricane Test Laboratory, LLC, Test Reports No. HTL-0449-0411-04 dated 06-07-04, HTL-0609-1106-04 dated 11/03/04 and C049-1005-06 dated 10/03/06, all signed and sealed by Vinm J. Abraham, P.E. (Test reports have been revised by addendum letters, issued by Hurricane Testing Lab, dated FEB 10, 2009, signed & sealed by Vinm J. Abraham, P.E.) (Submitted under NOA No. 14-0622.01)

NOA No. 15-0622.11 Expiration Date: April 23, 2019 Approval Date: February 19, 2016 Page 2

NOTICE OF ACCEPTANCE EVIDENCE SUBMITTED (continued)

- C. CALCULATIONS 1. Anchor verification calculations, complying with FBC 2014(5th edition), prepared by W. W. Schaefer Engineering & Consulting, P.A., dated 02/04/14 and last revised on 10/07/14, signed and sealed by Warren W. Schaefer, P.E. (Submitted under previous NOA No. 14-0622.01) 2. Glazing complies with ASTM E1300-02 & 04

- D. QUALITY ASSURANCE 1. Miami-Dade Department of Regulatory and Economic Resources (RER)

- E. MATERIAL CERTIFICATIONS 1. Notice of Acceptance No. 14-0423.17 issued to Eastman Chemical Company (MA) for their "Saflex Clear and Color-Glass Interlayers", expiring on 05/21/16.

- F. STATEMENTS 1. Statement letter of conformance to FBC 2014(5th edition) & "No firming" test, prepared by W. W. Schaefer Engineering & Consulting, P.A., dated 04/11/14, signed and sealed by Warren W. Schaefer, P.E. (Submitted under previous NOA No. 14-0622.01) 2. Statement of Lab compliance, as part of above referenced test reports.

- G. OTHERS 1. Notice of Acceptance No. 14-0602.01 issued to Kawneer Company, Series "350IR" Aluminum Outswinging Storefront Door - L.M.I., application G171.915 and expiring on 04/23/19. 2. Kawneer 1600 System 1 Curtain wall, IR 500 & IR 500 Storefront System, under separate approval. 3. Test proposals dated 07/26/14, approved by RER.

NOA No. 15-0622.11 Expiration Date: April 23, 2019 Approval Date: February 19, 2016 Page 2



PANDA EXPRESS, INC. 1683 Walnut Grove Ave. Rosemead, California 91770 Telephone: 626.799.9898 Facsimile: 626.372.8288

All ideas, designs, arrangement and plans indicated or represented by this drawing are the property of Panda Express Inc. and were created for use on this specific project. None of these ideas, designs, arrangements or plans may be used by or disclosed to any person, firm or corporation without the written permission of Panda Express Inc.

Table with 2 columns: REVISIONS, and empty rows for revision tracking.

Table with 2 columns: ISSUE DATE, and entries for 'ISSUE FOR BUILDING PERMIT 08-16-18' and 'ISSUE FOR BID 11-29-18'.

DRAWN BY: RR

PANDA PROJECT # S8-19-D6558 ARCH PROJECT # 1804

RANDY REYNOLDS ARCHITECT 315 WALTER ROBERTS ST • FRANKLIN, TN 37064 PHONE (615) 496-8750 • FAX (666) 584-1265 REGISTERED FLORIDA ARCHITECT # AR0015526



PANDA EXPRESS US 98 and PORTSIDE DRIVE 3868 GULF BREEZE PARKWAY GULF BREEZE, FL 2200 TRUE - R1 - DAB 12

NOA - 1.2

NOA DOCUMENTATION STOREFRONT DOORS - HIGH WIND, I.R.

Order Plans @

