

# ELECTRICAL SPECIFICATIONS

# GENERAL NOTES

**PART 1 - GENERAL**

1.01 COORDINATION OF TRADES: SCHEDULE AND COORDINATE WORK WITH THAT OF OTHER DIVISIONS AND SECTIONS.

1.02 GUARANTEE IN WRITING THE ELECTRICAL INSTALLATION, AND ALL WORK UNDER THIS SECTION, FOR A PERIOD OF ONE YEAR FROM THE DATE OF FINAL ACCEPTANCE BY THE OWNER AGAINST ALL EVIDENCE OF IMPERFECT WORKMANSHIP OR FAILURE OR MALFUNCTION OF MATERIALS.

**PART 2 - PRODUCTS**

2.01 MATERIALS AND EQUIPMENT

A. MATERIAL FURNISHED UNDER THIS CONTRACT, UNLESS OTHERWISE NOTED, SHALL BE NEW, FREE FROM DEFECTS AND SHALL CONFORM WITH THE STANDARDS OF UL.

B. VOLTAGE, AMPERE, AND OTHER RATINGS OF EQUIPMENT SHALL BE SUITABLE FOR USE INTENDED. DISCONNECT SWITCHES SHALL BE PROPERLY RATED AND SUITABLE FOR VOLTAGE, CURRENT, AND AMPERE RATING OF LOAD.

C. THE DRAWINGS GENERALLY INDICATE THE RACEWAY SIZE, THE NUMBER, SIZE, AND INSULATION TYPE OF CONDUCTORS TO BE PROVIDED AND INSTALLED, WHERE THESE ITEMS DO NOT MEET MINIMUM APPLICABLE CODES, FOR EQUIPMENT BEING SERVED, COMPLY AS REQUIRED AT NO ADDITIONAL COST.

2.02 RACEWAYS

A. GALVANIZED RIGID CONDUIT (GRC) INCLUDING ELBOWS AND COUPLINGS.

B. INTERMEDIATE METAL CONDUIT (IMC) INCLUDING ELBOWS AND COUPLINGS.

C. ELECTRIC METALLIC TUBING (EMT) WITH FITTINGS OF PRESSED STEEL OR MALLEABLE IRON, COMPRESSION TYPE WITH INSULATED THROATS.

D. RIGID NON-METALLIC CONDUIT (PVC) U.L. LABELED SCHEDULE 40 P.V.C.

2.03 DEVICE AND JUNCTION BOXES: INCLUDE PLASTER RINGS, COVERS, AND KO SEALS AS REQUIRED.

2.04 WIRE AND CABLE: UNLESS OTHERWISE NOTED, WIRE AND CABLE SHALL BE SOFT DRAWN, ANNEALED COPPER. WIRE SIZES NO. 8 AND LARGER AND CONDUCTORS SERVING MOTORS AND SUBJECT TO VIBRATIONS SHALL BE STRANDED CABLE. INSULATION TO BE THW/THHN, JACKETED 90C INSULATED WIRE. PROVIDE WIRE COLOR IDENTIFICATION: NEUTRAL WIRE - WHITE, LIVE WIRE - BLACK, RED, BLUE ON 120/208 VOLT SYSTEM; NEUTRAL WIRE - GREY, LIVE WIRE - BROWN, ORANGE YELLOW ON 277/480 VOLT SYSTEM; GROUND - GREEN.

2.05 ADDED PANELS TO BE PANELBOARDS - LOAD CENTERS ARE NOT ACCEPTABLE UNLESS SPECIFICALLY APPROVED.

2.06 SERVICE ENTRANCE AND DISTRIBUTION GEAR BY G.E. SQUARE "D" CUTLER HAMMER/SIEMENS ONLY. INTERIOR PANELBOARDS SHALL BE RECESSED WITH FLANGED/REMOVABLE SCREW-ON COVER. SURFACE MOUNTED PANELBOARDS OR HINGED/FLUSH COVERS NOT ALLOWED.

2.07 SWITCHBOARDS: COPPER BUSING WITH FULL CAPACITY NEUTRAL.

2.11 120/208 VOLT AND 277/480 VOLT PANELBOARDS, 3 PHASE, 4 WIRE, COPPER BUS, COMPOSED OF AN ASSEMBLY OF BOLT-IN-PLACE MOLDED CASE CIRCUIT BREAKERS WITH THERMAL AND MAGNETIC TRIP AND TRIP FREE POSITION SEPARATE FROM EITHER ON OR OFF POSITIONS.

2.13 SAFETY SWITCHES: FUSED, HEAVY DUTY, HORSEPOWER RATED.

2.14 STARTERS: CONTACTORS AND CONTROL DEVICES: PROVIDE AS SHOWN AND AS REQUIRED BY CODE. FURNISH COMPLETE WITH PILOT LIGHTS, AUXILIARY CONTACTS, PUSH BUTTONS, HAND-OFF-OFF SWITCHES, CONTROL DEVICES, AND OVERLOAD RELAYS. THERMAL OVERLOADS TO BE SIZED PER MANUFACTURER'S RECOMMENDATIONS. AMBIENT COMPENSATE ALL HEATERS EXPOSED TO HIGH TEMPERATURE OR INSTALLATION OUTSIDE.

2.16 NAMEPLATES: PROVIDE BLACK LAMICOID NAMEPLATES WITH 3/16" HIGH WHITE ENGRAVED LETTERS ON PANELS, SWITCHBOARDS, MAINS AND SUBMANS, DISTRIBUTION EQUIPMENT, REMOTE SAFETY SWITCHES, CIRCUIT BREAKERS, TIME SWITCHES, CONTACTORS, AND STARTERS.

2.17 WIRING DEVICES

A. HUBBELL OR COMPARABLE LEVITON OR BRYANT. WHITE AND GREY IN COLOR - AS NOTED ON DRAWINGS. 15 AMP DEVICES ALLOWED ONLY WHEN SPECIFICALLY DENOTED ON ELECTRICAL CONSTRUCTION DRAWINGS.

B. TOGGLE SWITCHES: SINGLE POLE - HUBBELL 1221-20A, 120/277V, THREE WAY - HUBBELL 1223-20A, 120/277V, FOUR WAY - HUBBELL 1224-20A, 120/277V.

C. RECEPTACLES: DUPLEX GRADING TYPE, SPECIFICATION GRADE, 125 VOLT, 20 AMPERES, SINGLE PHASE, HUBBELL NO. 5262 OR COMPARABLE.

D. GROUND FAULT INTERRUPTER TYPE RECEPTACLE: DUPLEX GRADING TYPE, SPECIFICATION GRADE, 125 VOLT, 20 AMPERES, SINGLE PHASE, 5 mA GROUND TRIP, FEED THROUGH CONSTRUCTION.

2.18 DEVICE PLATES: LEXAN (STA-KLEEN), SMOOTH FINISH IN STAINLESS STEEL - AS NOTED ON PLANS. MULTI-GANG OUTLET PLATES SHALL BE USED FOR MULTI-GANG BOXES.

2.19 NOT USED

2.20 LIGHTING FIXTURES

A. ALL INTERIOR / BUILDING MOUNTED LIGHTING PROVIDED BY PX AND INSTALLED BY GC.

B. ALL EXTERIOR SITE LIGHTING IS PROVIDED AND INSTALLED BY GC.

**PART 3 - EXECUTION**

3.01 GENERAL INSTALLATION

A. THE ENTIRE ELECTRICAL INSTALLATION SHALL BE MADE IN A NEAT, APPROVED, FINISHED, AND SAFE MANNER.

B. INSPECT AND MAKE TIGHT ALL CONNECTIONS FOR ALL EQUIPMENT, INCLUDING FACTORY CONNECTIONS, TORQUE ALL CONNECTIONS PER MANUFACTURER'S RECOMMENDATIONS.

C. LIGHTING FIXTURES INSTALLED AND USED FOR LIGHTING DURING CONSTRUCTION SHALL BE RELAMPED WITH NEW LAMPS JUST PRIOR TO FINAL ACCEPTANCE OF THE PROJECT.

D. INSTALL SEISMIC RESTRAINT DEVICES FOR ALL CEILING MOUNTED EQUIPMENT, I.E. FLUORESCENT LAY-IN FIXTURES. PROVIDE GRID CLIPS AND #12 SLACK WIRES FROM FIXTURE CORNERS TO STRUCTURE.

3.02 RACEWAYS

A. INSTALL COMPLETE RACEWAY SYSTEMS FOR ALL ELECTRICAL CONDUCTORS INCLUDING TELEPHONE, SIGNAL, CONTROL, AND OTHER SYSTEMS.

B. UNLESS OTHERWISE NOTED, INSTALL ALL RACEWAYS CONCEALED. WHERE IT IS NOT FEASIBLE TO CONCEAL RACEWAYS, INSTALL AS DIRECTED BY ARCHITECT.

C. INSTALL EXPOSED RACEWAYS TO RUN PARALLEL OR AT RIGHT ANGLES TO STRUCTURAL BUILDING LINES WITH NEAT BENDS AND NEATLY OFFSET INTO TERMINATIONS.

D. IN EMPTY RACEWAY PROVIDE AND INSTALL A NO. 14 NYLON DRAG LINE.

E. INSTALL RACEWAYS WITH APPROVED HEAVY DUTY SUPPORTS, STRAPS, HANGERS, CONNECTORS, AND COUPLINGS AS REQUIRED TO MAINTAIN AN APPROVED INSTALLATION.

F. DO NOT INSTALL CONDUIT RACEWAYS IN CONCRETE SLABS.

H. MINIMUM CONDUIT SIZE TO BE 3/4" U.N.O.

3.03 GALVANIZED RIGID CONDUIT (GRC) ALL RACEWAYS SHALL BE GRC EXCEPT AS NOTED OR SHOWN. CONDUIT, ELBOWS, STANDARD COUPLINGS SHALL BE HOT DIPPED GALVANIZED RIGID STEEL. IF PARTITIONS OR WALLS ARE SOLID CONCRETE OR ARE GROUTED SOLID WITH CONCRETE OR MORTAR, RIGID STEEL CONDUIT SHALL BE USED.

3.04 INTERMEDIATE METAL CONDUIT (IMC) RACEWAY AND APPROVED FITTINGS WHERE PERMITTED BY APPLICABLE CODES AND REGULATIONS MAY BE USED IN LIEU OF RIGID STEEL CONDUIT, WHERE INSTALLED ABOVE FINISH GRADE AND ABOVE CONCRETE SLABS ON GRADE.

3.05 ELECTRIC METALLIC TUBING (EMT) EMT MAY BE USED WHERE CONCEALED IN AREAS ABOVE CEILINGS, FURRED SPACES, PARTITIONS OR WALLS. ALSO MAY BE EXPOSED, WHEN NOT IN HAZARDOUS AREAS, AREAS SUBJECT TO PHYSICAL DAMAGE, OR WHEN DIRECTLY EXPOSED TO RAIN OR WASH-DOWN.

3.06 FLEXIBLE METAL CONDUIT (FLEX) USE FLEXIBLE CONDUITS FOR CONNECTIONS TO MOTORS, WHERE SUBJECT TO MOVEMENT OR VIBRATION, AND LIQUID TIGHT WHERE EXPOSED TO MOISTURE OR OIL.

3.07 RIGID NONMETALLIC CONDUIT (PVC) SCHEDULE 40 MAY BE INSTALLED FOR DIRECT BURIAL RACEWAYS WHERE INSTALLED WITH MINIMUM COVERAGE PER NEC TABLE 300-5.

3.08 OUTLET, PULL AND JUNCTION BOXES

A. UNLESS OTHERWISE SHOWN OR AS DIRECTED PRIOR TO INSTALLATION, OUTLET BOXES SHALL GENERALLY BE PLACED AT THE FOLLOWING HEIGHTS, CENTER OF BOX TO FINISHED FLOOR LEVEL.

B. WALL SWITCHES @ 44"

C. CONVENIENCE RECEPTACLES: 18" (OR 4" ABOVE COUNTERS) AND/OR AS NOTED. (SIMILAR TYPE OUTLETS SHALL BE MOUNTED AT SAME HEIGHT IN EACH AREA). GROUNDING PIN AT TOP.

3.09 CONDUCTORS (COPPER ONLY)

A. USE SPECIFIED COLOR SCHEDULE FOR ALL WIRING. WHERE LARGE CONDUCTORS ARE NOT AVAILABLE, IDENTIFY WITH PERMANENT COLORED TAPE AT ALL TERMINATIONS. JUNCTION BOXES, ETC. COLOR TAPE PER NEC.

B. MAKE TAPS, JOINTS, SPLICES, AND OTHER CONNECTIONS WITH FIXTURE CONNECTIONS.

C. DO NOT INSTALL WIRING OR PULL WIRES, IN RACEWAYS UNTIL RACEWAY SYSTEM IS COMPLETE. CLEAN AND DRY AND FREE FROM ALL FOREIGN MATERIALS. LUBRICATE AS REQUIRED WITH SPECIFIED LUBRICANT SYSTEMS.

D. MINIMUM CONDUCTOR SIZE TO BE #12 CU. THWN.

3.10 LIGHTING FIXTURES

A. LEAVE FIXTURES AND LAMPS CLEAN OF ALL DIRT, DUST, GREASE SPOTS AND DEBRIS AND ALL GLASS, PLASTIC AND OTHER COMPONENTS UNSCRATCHED AND UNBROKEN.

B. FIT AND ADJUST ALL FIXTURES WHERE STRUCTURAL CONDITIONS, PARTITION, FURNITURE, SHELVES, AND AIR CONDITIONING DIFFUSERS INTERFERE WITH THE LIGHTING FIXTURES AT LOCATIONS SHOWN. NOTIFY ARCHITECT IN WRITING AND RELOCATE AT NO ADDITIONAL COST AS DIRECTED.

C. FIXTURES WITH FINISH TRIM OR LENS FRAMES SHALL BE CHECKED AND BARRICADED TO PREVENT LIGHT LEAKS. INSTALL SO THAT NO LIGHT LEAKS EXIST. D. FIXTURES MOUNTED DIRECTLY ON COMBUSTIBLE LOW-HENSITY CEILINGS SHALL BE UL APPROVAL FOR THIS CONDITION AND BE PLAINLY MARKED SO.

3.11 GROUNDING

A. GROUNDING FOR DISTRIBUTION EQUIPMENT, EQUIPMENT AND MATERIALS WITH ELECTRICAL CONNECTIONS, ELECTRIC MOTOR FRAMES, ELECTRIC RAY AND RELATED EQUIPMENT SHALL BE EFFECTIVELY AND PERMANENTLY GROUNDING IN ACCORDANCE WITH PERMITTED SECTIONS OF ARTICLE 250 OF NEC. RESISTANCE TO GROUND SHALL NOT EXCEED 10 OHMS.

B. ALL RACEWAYS SHALL HAVE APPROVED SIZED, INSULATED STRANDED COPPER GROUNDING TYPE CONDUCTOR.

C. WHERE RACEWAYS CONDUIT TO A CENTRIC K.O. PROVIDE GROUNDING LOCKOUT OR BUSHING AND BOND WIRE EXTENDED AND BONDED TO ENCLOSURE STEEL PER MANUFACTURER'S INSTRUCTIONS.

3.12 DITCHING, EXCAVATION AND BACKFILLING: FORMWORK, BRACING, EXCAVATION AND BACKFILLING REQUIRED FOR THE ELECTRICAL WORK. PROVIDE AND MAINTAIN ALL BRACING, BRACING AND POWER GUARDS FOR PREVENTION OF ACCIDENTS.

3.13 UTILITY COMPANY SERVICE: CONTRACTOR TO BE RESPONSIBLE FOR COORDINATING AND PROVIDING REQUIRED WORK FOR SUPPLYING ELECTRICAL POWER TO COMMUNICATIONS UTILITIES TO THE PROJECT.

3.14 ELECTRICAL TESTS AND GROUNDING: FAULTY WIRING SHALL BE REMOVED AND REPLACED AFTER SYSTEM IS CONNECTED. COMPLETE TEST FOR INSULATION RESISTANCE. RESISTANCE LOWER THAN OUTLINED IN THE NEC, MANUFACTURER'S DATA, ETC. SHALL BE REPEATED AND RE-PLACED. ANY DEVICE, APPARATUS OR FIXTURE UNDER THIS CONTRACT SHOWING SUBSTANDARD READINGS SHALL BE REMOVED AND REPLACED AS DIRECTED BY THE ARCHITECT.

LABEL ALL RECEPTACLES WITH #16 HIGH BLACK LETTERING ON CLEAR TAPE. IF THE RECEPTACLE IS BLACK OR BROWN, PROVIDE WHITE LETTERING ON CLEAR TAPE. LABEL TO BE NEATLY CENTERED IN THE TOP SPACE OF THE COVERPLATE, AND INDICATE THE SERVING PANEL AND CIRCUIT OR.

1. THE ELECTRICAL DRAWINGS, SPECIFICATIONS AND GENERAL NOTES DESCRIBE THE RECOMMENDED SCOPE OF WORK AND THE DOCUMENTS SHALL BE USED FOR THE PURPOSE OF BIDDING, BUILDING DEPARTMENT REVIEW, AND TO SECURE THE NECESSARY CONSTRUCTION PERMIT ONLY.

2. BRANCH CONTROL CIRCUITING AND WIRE COUNT MAY NOT BE INDICATED ON THESE PLANS. CONTRACTOR IS RESPONSIBLE TO COMPLETE THE BRANCH CIRCUIT WIRING IN ACCORDANCE WITH PLAN NOTES AND AS PERMITTED BY AUTHORITY. CONTRACTOR SHALL SUBMIT AS-BUILT DRAWINGS AS A PART OF RECORD DRAWING SUBMITTAL TO ARCHITECT AND AUTHORITY HAVING JURISDICTION (A.N.J.).

3. ELECTRICAL INSTALLATION SHALL COMPLY WITH THE LOCALLY ADOPTED, AS NATIONAL ELECTRICAL CODE ADAPTED BY THE JURISDICTION AND ANY LOCAL SUPPLEMENTS.

4. ALL EQUIPMENT SHOWN IS NEW, CONTRACTOR FURNISHED AND INSTALLED, UNLESS OTHERWISE NOTED. IF CONTRACTOR PROPOSED TO SUBSTITUTE SPECIFIC EQUIPMENT SPECIFIED, HE SHALL SUBMIT HIS REQUEST FOR CONSIDERATION TO THE OWNER AND ENGINEER PRIOR TO THE BID IN WRITING. ALL SUBSTITUTIONS MUST BE REVIEWED BY THE ENGINEER. SUCH REVIEW SHALL NOT RELIEVE THE CONTRACTOR FROM COMPLYING WITH THE REQUIREMENTS OF THE DRAWINGS AND SPECIFICATIONS. THE CONTRACTOR SHALL BE RESPONSIBLE AT HIS OWN EXPENSE FOR ANY CHANGE RESULTING FROM HIS PROPOSED SUBSTITUTIONS WHICH AFFECT OTHER PARTS OF HIS OWN WORK, OR SUBSTITUTIONS WHICH AFFECT OTHER PARTS OF HIS OWN WORK OR THE WORK OF OTHER CONTRACTORS.

5. THE ELECTRICAL DRAWINGS, CONDUIT RUNS, WIRING AND ELECTRICAL INFORMATION ARE DIAGRAMMATIC ONLY. DO NOT SCALE THE ELECTRICAL DRAWINGS TO DETERMINE THE LOCATION OF EQUIPMENT OR OUTLETS.

6. REFER TO THE ARCHITECTURAL REFLECTED CEILING PLAN FOR EXACT LOCATIONS OF ALL LIGHTING FIXTURES, CEILING MOUNTED OUTLETS AND EQUIPMENT.

7. ALL DEVICE MOUNTING HEIGHTS AND EXACT LOCATIONS SHALL BE COORDINATED WITH ARCHITECTURAL DRAWINGS AND ELEVATIONS PRIOR TO ROUGH-IN.

8. IT SHALL BE THE CONTRACTOR'S RESPONSIBILITY TO VERIFY TYPES OF CEILING SYSTEMS. LIGHTING FIXTURES LOCATED IN DAMP OR WET LOCATIONS SHALL BE LISTED AND LABELED FOR USE IN SUCH LOCATIONS.

9. ALL RECESSED LIGHTING FIXTURES, PANELBOARDS, SWITCHES, ETC., MOUNTED IN FIRE RATED STRUCTURES SHALL BE ENCLOSED WITH AN APPROVED ENCLOSURE CARRYING THE SAME FIRE RATING AS THE STRUCTURE.

10. PORTIONS OF THE CEILING SYSTEMS MAY BE INACCESSIBLE. THEREFORE, THE CONTRACTOR SHALL STRATEGICALLY LOCATE ACCESS BOXES, ETC., WHICH SHALL BE READILY ACCESSIBLE. ALL LIGHTING FIXTURE WIRING, BALLASTS, J-BOXES, ETC. SHALL BE ACCESSIBLE FROM FIXTURE OPENING.

11. ALL WIRING AND ELECTRICAL EQUIPMENT INSTALLED FOR MECHANICAL AND PLUMBING EQUIPMENT SHALL BE IN ACCORDANCE WITH MECHANICAL AND PLUMBING SPECIFICATIONS AND ASSOCIATED DRAWINGS. CONTRACTOR SHOULD OBTAIN THE REQUIRED MECHANICAL AND PLUMBING DRAWINGS AND PROVIDE ALL EQUIPMENT, RACEWAYS, WIRING, ETC. AS INDICATED THEREON AS PROVIDED UNDER THE ELECTRICAL WORK.

12. ALL FINAL CONNECTIONS TO OWNER FURNISHED EQUIPMENT SHALL BE MADE BY THE CONTRACTOR, UNLESS OTHERWISE NOTED. VERIFY ELECTRICAL CHARACTERISTICS AND U.L. LISTING PRIOR TO CONNECTION.

13. THE CONTRACTOR SHALL VERIFY THE LOAD INPUT VOLTAGE OF ALL EQUIPMENT PRIOR TO INSTALLATION. ACCEPTING ANY EQUIPMENT RESULTING IN A LOAD INCREASE SHALL BE THE RESPONSIBILITY OF CONTRACTOR.

14. ELECTRICAL OUTLETS ON OPPOSITE SIDES OF FIRE RATED WALLS AND PARTITIONS MUST BE SEPARATED BY DISTANCE OF 24 IN. FROM PARTIAL IN ACCORDANCE WITH I.B.C. SEC. 711.3.2. OPENINGS IN FIRE RATED WALLS GREATER THAN 16 SQ. IN. MUST BE FIRE STOPPED.

15. PROVIDE AN ADDITIONAL JUNCTION BOX (SIZE AS REQUIRED) WHERE THE NUMBER OF CONDUCTORS EXCEEDS THE MAXIMUM ALLOWED FOR A GIVEN JUNCTION POINT OR POINTS.

16. CONDUCTORS SHALL BE COPPER THW/THWN 600 VOLT INSULATION UNLESS OTHERWISE NOTED. USE COPPER TEMPERATURE RATING OF CONDUCTORS BASED ON THE AMBIENT TEMPERATURE WHERE CONDUCTORS ARE BEING USED. HIGH AMPERAGE CONDUCTOR AND LARGER RACEWAY SHALL BE PROVIDED TO OFFSET THE TEMPERATURE CORRECTION FACTORS AS INDICATED IN NEC TABLE 310.15(B)(16) AND ELSEWHERE IN CODE.

17. ALL FLUORESCENT BALLASTS TO BE PROVIDED BY PX.

18. DO ALL DRIVING, CHANNELING AS REQUIRED FOR ELECTRICAL WORK AND INDICATED OR HEREIN SPECIFIED. ALL HOLES, CURBS, ETC. IN FLOORS, CEILINGS AND WALLS SHALL BE PATCHED, UNLESS INDICATED OTHERWISE. PATCHES EXPOSED ELECTRICAL RACEWAYS, CABINETS, ENCLOSURES AND FITTING TO MATCH IN COLOR TO ADJACENT SURFACES IN FINISHED AREAS. (PROTECT UL LISTINGS LABELS FROM PAINT).

19. SEAL ALL PENETRATIONS THROUGH FIRE RATED WALLS, CEILINGS, FLOORS, ETC., TO MAINTAIN THE FIRE RATING. FURNISH AND INSTALL FIRE RATED ENCLOSURE FOR ALL EQUIPMENT PENETRATING INTO FIRE RATED ENVELOPS, SPACES ETC.

20. EMERGENCY LIGHTING SHALL BE PROVIDED PER U.B.C. AND SHALL BE DESIGNED TO PROVIDE MINIMUM REQUIRED FOOTCANDLES AND LUMENS. PROVIDE ADDITIONAL EMERGENCY ILLUMINATION AS REQUIRED BY INSPECTION AUTHORITIES HAVING JURISDICTIONS.

21. ALL ELECTRICAL EQUIPMENT SHALL BE BRACED OR ANCHORED TO RESIST A HORIZONTAL FORCE ACTING IN ANY DIRECTION USING THE FOLLOWING CRITERIA (NON HEALTH CARE FACILITY INCLUDE OSHPD NOTES FOR HEALTH CARE FACILITY)

FIXED EQUIPMENT ON GRADE	33% OF OPERATING WEIGHT
FIXED EQUIPMENT ON STRUCTURE	50% OF OPERATING WEIGHT
EMERGENCY POWER AND COMMUNICATION & EQUIPMENT ON GRADE	50% OF OPERATING WEIGHT
EMERGENCY POWER AND COMMUNICATION ON STRUCTURE	75% OF OPERATING WEIGHT

FOR FLEXIBLE MOUNTED EQUIPMENT USE 2 X THE ABOVE VALUES. SIMULTANEOUS VERTICAL FORCE - USE 1/3 X HORIZONTAL FORCE.

CONDUIT, BUSDUOT, CABLE TRAY, WIREWAYS, ETC., SHALL BE BRACED IN ACCORDANCE WITH "GUIDELINES", PUBLISHED BY SMA/CNA AND PPIC.

**NOTICE**

THESE DRAWINGS ARE SUBJECT TO AN APPROVAL OF THE BUILDING DEPARTMENT, FIRE MARSHAL, UTILITY COMPANY AND OTHER AGENCIES AUTHORITY HAVING JURISDICTION (A.H.J.) BY THE ACT OF SUBMITTING A BID PROPOSAL FOR WORK. THE CONTRACTOR HAS REVIEWED THE PLANS THOROUGHLY AND ACCEPT FULL RESPONSIBILITY OF PLAN CORRECTIONS AND ASSOCIATED CONSTRUCTION COSTS REQUIRED BY A.H.J.

CONDUIT AND CONDUCTORS SCHEDULE																															
Mark No.	OCP Device (A/P)	Rating Amperes	Conductors				Raceway Size (nominal inches)				Mark No.	OCP Device (A/P)	Load in Amperes	Conductors				Raceway Size (nominal inches)													
			Phase Qty	Size	Type	Grd	No. Seta	EMT	IMC	RIGID				PVC	EMT	IMC	PVC	EMT	IMC	PVC	EMT	IMC	PVC								
1	20/1	20	2	12	THHN	1	12	One	0.75	0.75	0.75	0.75	0.75	0.75	0.75	25	90/3	85 - 72	4	2	THW	1	6	One	1.50	1.25	1.50	1.50	1.50	1.50	1.50
2	20/2	20	3	12	THHN	1	12	One	0.75	0.75	0.75	0.75	0.75	0.75	0.75	26	100/2	73 - 80	3	1	THW	1	6	One	1.50	1.50	1.50	1.50	1.50	1.50	1.50
3	20/3	20	4	12	THHN	1	12	One	0.75	0.75	0.75	0.75	0.75	0.75	0.75	27	100/3	73 - 80	4	1	THW	1	6	One	2	2	2	2	2	2	2
4	25/1	17 - 20	2	10	THHN	1	10	One	0.75	0.75	0.75	0.75	0.75	0.75	0.75	28	110/2	81 - 88	3	1	THW	1	6	One	1.50	1.50	1.50	1.50	1.50	1.50	1.50
5	25/2	17 - 20	3	10	THHN	1	10	One	0.75	0.75	0.75	0.75	0.75	0.75	0.75	29	110/3	81 - 88	4	1	THW	1	6	One	2	2	2	2	2	2	2
6	25/3	17 - 20	4	10	THHN	1	10	One	0.75	0.75	0.75	0.75	0.75	0.75	0.75	30	125/2	89 - 100	3	1	THW	1	6	One	1.50	1.50	1.50	1.50	1.50	1.50	1.50
7	30/1	21 - 24	2	10	THHN	1	10	One	0.75	0.75	0.75	0.75	0.75	0.75	0.75	31	125/3	89 - 100	4	1	THW	1	6	One	2	2	2	2	2	2	2
8	30/2	21 - 24	3	10	THHN	1	10	One	0.75	0.75	0.75	0.75	0.75	0.75	0.75	32	150/2	101 - 120	3	1/0	THW	1	6	One	1.50	1.50	1.50	1.50	1.50	1.50	1.50
9	30/3	21 - 24	4	10	THHN	1	10	One	0.75	0.75	0.75	0.75	0.75	0.75	0.75	33	150/3	101 - 120	4	1/0	THW	1	6	One	2	2	2	2	2	2	2
10	40/1	25 - 32	2	8	THHN	1	8	One	0.75	0.75	0.75	0.75	0.75	0.75	0.75	34	175/2	121 - 140	3	2/0	THW	1	6	One	1.50	1.50	1.50	1.50	1.50	1.50	1.50
11	40/2	25 - 32	3	8	THHN	1	8	One	0.75	0.75	0.75	0.75	0.75	0.75	0.75	35	175/3	121 - 140	4	2/0	THW	1	6	One	2	2	2	2	2	2	2
12	40/3	25 - 32	4	8	THHN	1	8	One	0.75	0.75	0.75	0.75	0.75	0.75	0.75	36	200/2	141 - 160	3	1/0	THW	1	6	One	2	2	2	2	2	2	2
13	50/1	33 - 40	2	6	THHN	1	6	One	0.75	0.75	0.75	1	1	1	1	37	200/3	141 - 160	4	3/0	THW	1	6	One	2.50	2.50	2.50	2.50	2.50	2.50	2.50
14	50/2	33 - 40	3	6	THHN	1	6	One	1	1	1	1	1	1	1	38	225/2	161 - 180	3	2/0	THW	1	4	One	2.50	2	2	2	2	2	2
15	50/3	33 - 40	4	6	THHN	1	6	One	1.25	1	1	1	1	1	1	39	225/3	161 - 180	4	4/0	THW	1	4	One	2.50	2.50	2.50	2.50	2.50	2.50	2.50
16	60/1	41 - 48	2	4	THW	1	8	One	1	1	1	1	1	1	1	40	250/3	181 - 200	4	250	THW	1	4	One	2.50	3	3	3	3	3	3
17	60/2	41 - 48	3	4	THW	1	8	One	1.25	1	1	1	1	1	1	41	300/3	210 - 240	4	350	THW	1	4	One	3	3	3	3	3	3	3
18	60/3	41 - 48	4	4	THW	1	8	One	1.25	1.25	1.25	1.25	1.25	1.25	1.25	42	350/3	241 - 280	4	500	THW	1	3	One	3.50	3.50	3.50	3.50	3.50	3.50	3.50
19	70/1	49 - 56	2	4	THW	1	8	One	1	1	1	1	1	1	1	43	400/3	281 - 320	4	3/0	THW	2	3	Two	2.50	2.50	2.50	2.50	2.50	2.50	
20	70/2	49 - 56	3	4	THW	1	8	One	1.25	1	1	1	1	1	1	44	600/3	321 - 480	4	350	THW	2	1	Two	3	3	3	3	3	3	3
21	70/3	49 - 56	4	4	THW	1	8	One	1.25	1.25	1.25	1.25	1.25	1.25	1.25	45	800/3	481 - 640	4	500	THW	2	1/0	Two	3.50	3.50	3.50	3.50	3.50	3.50	
22	80/2	57 - 64	3	3	THW	1	8	One	1.25	1.25	1.25	1.25	1.25	1.25	1.25	46	1000/3	641 - 840	4	400	THW	3	2/0	Three	3.50	3.50	3.50	3.50	3.50	3.50	
23	80/3	57 - 64	4	3	THW	1	8	One	1.25	1.25	1.25	1.25	1.25	1.25	1.25	47	1200/3	801 - 960	4	350	THW	4	3/0	Four	3	3	3	3	3	3	
24	90/2	65 - 72	3	2	THW	1	8	One	1.25	1.25	1.25	1.25																			