


INPUT	LOAD DESCRIPTION	PHASE	CT SIZE
1	MAIN	A	600
2	MAIN	B	600
3	MAIN	C	600
4	RTU	A	150
5	RTU	A	150
6	RTU	A	150
7	ADDITIONAL RTUs	A	150

CT INPUT LIST



2-WIRE HUB MODULE CONNECTIONS	
HOST	FROM MM1204-EX
CHAIN 1	TS101 THERMOSTATS
CHAIN 2	LCP-2
CHAIN 3	N/A
R1/C1	N/A
R2/C2	N/A
R3/C3	N/A

O'REILLY PREFERRED  
ONE LINE DIAGRAM

5305 VALLEY PARK DRIVE SUITE # 2  
ROANOKE, VA - 24019

GRIDPOINT CONTACT

PRINTS ARE FOR:

DESIGN

REVIEW

PERMIT

BIDDING

CONSTRUCTION

BY: \_\_\_\_\_

DATE: \_\_\_\_\_

REVISIONS:

DESCRIPTION:

SHEET TITLE:  
FULL SYSTEM MINUS LIGHTING/MOTION SENSORS

FILE NAME:  
O'REILLY PREFERRED ONE LINE DIAGRAM

DATE:  
9/27/2018

DRAWN BY:  
DAVID COLWELL

SHEET NO:

EM 1.0

DESIGN BY OTHERS FOR REFERENCE ONLY

CRAIG A. SCHNEIDER, AIA  
ARCHITECT  
1736 East Sunshine, Suite 417  
Springfield, Missouri 65804  
e-mail: architect@esterlyschneider.com  
417.862.0558  
Fax: 417.862.3265

PROJECT:  
NEW O'REILLY AUTO PARTS STORE  
1345 15TH STREET  
PANAMA CITY, FL #1  
GRIDPOINT EMS

O'Reilly AUTO PARTS  
CORPORATE OFFICES  
1345 15TH STREET  
PANAMA CITY, FL 32401  
(417) 862-2674 TELEPHONE

CONFIDENTIAL AND PROPRIETARY

C. COPYRIGHT 2018-2019 - DESIGNS, DRAWINGS AND SPECIFICATIONS ARE INSTRUMENTS OF SERVICE AND ARE THE PROPERTY OF THE DESIGN PROFESSIONAL. REPRODUCTION PROHIBITED WITHOUT THE EXPRESSED WRITTEN CONSENT OF THE DESIGN PROFESSIONAL.

EM1.0 of 3