

ELECTRICAL SYMBOL LEGEND	
	CIRCUIT CONDUCTORS CONCEALED IN FLOOR, WALL OR CEILING.
	ARROWHEAD INDICATES HOMERUN TO PANEL NOTED.
	INDICATES HOT LEG OF CIRCUIT TO BE CARRIED OVER TO NEXT DEVICE. SEE PLANS FOR CONTROL SCHEME.
	JUNCTION BOX.
	SINGLE POLE SWITCH, 20A, 120/277 VOLT, 40" A.F.F. TO CENTER. S ³ INDICATES 3-WAY SWITCH. S ⁴ INDICATES 4-WAY SWITCH. S ^D INDICATES DIMMER SWITCH OF TYPE TO SUIT LOAD. S ^K INDICATES KEY OPERATED SWITCH. S ^M INDICATES 120V, 20A MOTOR RATED TOGGLE SWITCH.
	INDICATES FLUORESCENT FIXTURES DUAL SWITCHED, INBOARD/OUTBOARD SWITCHED SEPARATELY.
	SINGLE RECESSED CLOCK RECEPTACLE FOR FLY LIGHT, 20 AMP, 120 VOLT.
	DUPLEX RECEPTACLE, 15 AMP, 120 VOLT, 18" A.F.F. TO CENTER. GFI INDICATES GROUND FAULT CIRCUIT INTERRUPTER TYPE WP INDICATES WEATHERPROOF EMC INDICATES MOUNT INSIDE ENCLOSURE OF ELECTRIC WATER COOLER.
	QUADRUPLEX RECEPTACLE, AS ABOVE, 18" A.F.F.
	SPECIAL EQUIPMENT CONNECTION. COORDINATE EXACT CONNECTION REQUIREMENTS WITH KITCHEN INSTALLER.
	COMMUNICATIONS SYSTEM J-BOX. CONDUIT SIZE AS INDICATED, INSIDE WALL, TO ABOVE ACCESSIBLE CEILING.
	DUPLEX RECEPTACLE, AS ABOVE, MOUNTED 6" ABOVE COUNTER TOP OR 4" ABOVE BACKSPLASH, AS APPROPRIATE, OR AT HEIGHT INDICATED.
	DUPLEX RECEPTACLE, AS ABOVE, MOUNTED 6" ABOVE COUNTER TOP OR 4" ABOVE BACKSPLASH, AS APPROPRIATE, OR AT HEIGHT INDICATED, WITH GFI PROTECTION.
	208V RECEPTACLE, SEE PLANS FOR NEMA CONFIGURATION.
	TELEPHONE OUTLET, 18" A.F.F. TO CENTER, UNLESS OTHERWISE NOTED. PROVIDE SINGLE GANG RECESSED J-BOX WITH 3/4" CONDUIT TO ACCESSIBLE CEILING. PROVIDE CAT 6, 4-PAIR CABLE FROM EACH TELEPHONE J-BOX BACK TO TELEPHONE BOARD DEMARCATION LOCATION. PROVIDE TELEPHONE JACK AND FACEPLATE AT OFFICE AND DRIVE THRU TELEPHONE LOCATIONS.
	DATA OUTLET, 18" A.F.F. TO CENTER, UNLESS OTHERWISE NOTED. PROVIDE SINGLE GANG RECESSED J-BOX WITH 3/4" CONDUIT TO ACCESSIBLE CEILING. PROVIDE CAT 6, 4-PAIR CABLE FROM EACH DATA J-BOX BACK TO A CENTRAL POINT IN OFFICE, COORDINATE EXACT TERMINATION POINT WITH OWNER.
	HEAVY DUTY FUSIBLE/NON-FUSIBLE DISCONNECT SWITCH, NUMBERS INDICATE FRAME SIZE, NUMBER OF POLES AND FUSING. PROVIDE NEMA 1 ENCLOSURE INSIDE. PROVIDE NEMA 3 ENCLOSURE FOR ALL SWITCHES LOCATED OUTSIDE. F ^{FM} INDICATES FUSE PER EQUIPMENT NAMEPLATE NF INDICATES NON-FUSED.
	208Y/120V PANEL, SURFACE OR RECESS MOUNTED, SEE SCHEDULE FOR DETAILS.
	FAN, PROVIDED AND INSTALLED BY MECHANICAL CONTRACTOR, WIRED BY ELECTRICAL CONTRACTOR. PROVIDE DISCONNECTING MEANS AS REQUIRED.
	WATER HEATER, PROVIDED AND INSTALLED BY PLUMBING CONTRACTOR, WIRED BY ELECTRICAL CONTRACTOR. PROVIDE DISCONNECTING MEANS AS REQUIRED.
	RECESSED MOUNTED 2x4 FLUORESCENT TROFFER, SEE FIXTURE SCHEDULE FOR DETAILS. SHADING AND/OR NL INDICATES NIGHT AND EMERGENCY LIGHT.
	SURFACE MOUNTED FLUORESCENT STRIP, SEE FIXTURE SCHEDULE FOR DETAILS.
	WALL MOUNTED LIGHTING FIXTURE, SEE FIXTURE SCHEDULE FOR DETAILS.
	SURFACE, RECESSED OR GROUND MOUNTED LIGHTING FIXTURE, SEE FIXTURE SCHEDULE FOR DETAILS. NL INDICATES NIGHT LIGHT FIXTURE
	ELECTRIC UTILITY METER LOCATION.
	COMBINATION EMERGENCY/EXIT LIGHT, CEILING AND WALL MOUNTED RESPECTIVELY, SHADING INDICATES FACE. PROVIDE RED LETTERS WITH WHITE HOUSING AND EMERGENCY BATTERY PACK RATED FOR 90 MINUTE DURATION. WIRE TO HOT LEG OF LOCAL LIGHTING CIRCUIT.
	REMOTE MOUNTED LAMP HEAD, WALL MOUNTED WITH EMERGENCY BATTERY PACK RATED FOR 90 MINUTE DURATION. WIRE TO HOT LEG OF LOCAL LIGHTING CIRCUIT.
	CABLE TV OUTLET, 18" A.F.F. TO CENTER, UNLESS OTHERWISE NOTED. PROVIDE EMPTY 3/4" C TO ABOVE ACCESSIBLE CEILING.
	SPEAKER LOCATION.
	120V DOORBELL PUSHBUTTON AND BELL CHIME.
	DUCT MOUNTED SMOKE DETECTOR, CONNECT TO 120V CIRCUIT INDICATED. DETECTOR SHALL BE SUPPLIED BY E.C. AND INSTALLED BY M.C., 120V WIRING, E.C.
	DUCT DETECTOR AUDIO/VISUAL DEVICE WITH REMOTE TEST SWITCH. SEE WIRING DIAGRAM ON SHEET E-6 FOR DETAILS. SEE FLOOR PLAN FOR MOUNTING HEIGHTS.
	120V CEILING MOUNTED DUAL TECHNOLOGY OCCUPANCY SENSOR SET FOR 30 MINUTES. COORDINATE ALL WIRING REQUIREMENTS WITH MANUFACTURER.
	WALL MOUNTED OCCUPANCY SENSOR AT 46" AFF SET FOR 15 MINUTES.
	DUPLEX RECEPTACLE, 15A, 120 VOLT, WITH (2) USB PORTS. MOUNT AT 46" AFF TO CENTER.

- NOTES:
- SEE DETAIL FOR STANDARD MOUNTING HEIGHTS OF ALL DEVICES, UNLESS OTHERWISE NOTED.
 - ALL DEVICES (SWITCHES AND RECEPTACLES) SHALL BE GREY WITH #2 STAINLESS STEEL COVER PLATES, UNLESS OTHERWISE NOTED.
 - ALL FIRE ALARM WIRING SHALL BE IN CONDUIT.

GENERAL ELECTRICAL NOTES	
1.	ALL ELECTRICAL WORK SHALL BE IN ACCORDANCE WITH THE LATEST EDITION OF THE NATIONAL ELECTRICAL CODE AND ALL LOCAL AND STATE CODES.
2.	ALL MATERIAL, DEVICES, APPLIANCES, AND EQUIPMENT SHALL BE NEW AND SHALL CONFORM TO THE STANDARDS OF THE UNDERWRITERS LABORATORIES, INC., AND THE NATIONAL ELECTRICAL MANUFACTURERS ASSOCIATION.
3.	ALL ELECTRICAL PERMITS AND INSPECTION FEES SHALL BE OBTAINED AND PAID FOR BY THE ELECTRICAL CONTRACTOR. DRAWINGS ARE DIAGRAMMATIC ONLY AND INDICATE ONLY THE GENERAL ARRANGEMENT. SEE ARCHITECTURAL DRAWINGS FOR EXACT DIMENSIONS.
4.	ELECTRICAL CONTRACTOR SHALL GUARANTEE ALL WORK AND MATERIALS FOR ONE YEAR EFFECTIVE THE DAY THE PROJECT IS ACCEPTED BY THE OWNER.
5.	ELECTRICAL CONTRACTOR SHALL MAKE ALL ELECTRICAL POWER CONNECTIONS TO HVAC, PLUMBING AND OTHER EQUIPMENT AS REQUIRED.
6.	A COMPLETE GROUNDING SYSTEM SHALL BE PROVIDED AND INSTALLED IN ACCORDANCE WITH ARTICLE 250 OF THE NEC, AND AS SHOWN ON THE DRAWINGS.
7.	ALL CUTTING AND PATCHING OF WALLS AND FLOORS FOR ELECTRICAL EQUIPMENT SHALL BE THE RESPONSIBILITY OF THE ELECTRICAL CONTRACTOR.
8.	CONDUCTORS SHALL BE COPPER RATED AT NOT LESS THAN 600 VOLTS. MINIMUM SIZE SHALL BE #12 AWG UNLESS OTHERWISE NOTED ON THE DRAWINGS. ALL WIRE #8 AWG AND LARGER SHALL BE STRANDED. ALL CONDUCTORS #10 AND SMALLER SHALL BE SOLID, UNLESS OTHERWISE NOTED. BRANCH CIRCUIT CONDUCTORS SHALL BE TYPE THIN OR THIN AS REQ'D.
9.	ALL WIRING SHALL BE INSTALLED IN GALVANIZED RIGID CONDUIT, INTERMEDIATE METAL CONDUIT, OR EMT UNLESS OTHERWISE NOTED. EMT SHALL NOT BE USED IN OR UNDER CONCRETE SLABS, OR IN MASONRY WALLS. USE SCHEDULE 40 PVC OUTDOORS WHERE NOT SUBJECT TO PHYSICAL DAMAGE OR BELOW FLOOR SLAB. MINIMUM CONDUIT SIZE TO BE 1/2". TYPE MC AND AC CABLE MAY BE USED WHERE PERMISSIBLE BY NEC.
10.	PROVIDE A PULLWIRE IN ALL EMPTY CONDUITS.
11.	PROVIDE A TYPED DIRECTORY IN ALL PANELBOARDS CLEARLY DESCRIBING THE LOCATION OF AND TYPE OF LOAD BEING SERVED FOR ALL CIRCUITS. PROVIDE ENGRAVED PHENOLIC NAMEPLATES FOR ALL PANELBOARDS AND DISCONNECT SWITCHES, WHITE LETTERS ON BLACK BACKGROUND.
12.	FUSES 0 - 600 AMPS SHALL BE UL CLASS "RK-1" LOW PEAK DUAL ELEMENT TIME DELAY WITH 200,000 AMPERE INTERRUPTING RATING AS MANUFACTURED BY BUSHMANN, UNLESS NOTED OTHERWISE.
13.	ALL TERMINALS/LUGS SHALL BE 60/75 RATED. ALL TERMINALS, SPLICING CONNECTORS, LUGS ETC SHALL BE IDENTIFIED FOR USE WITH THE MATERIAL (CU/AL) OF THE CONDUCTOR AND SHALL BE PROPERLY INSTALLED.
14.	VERIFY ALL REQUIREMENTS AND COORDINATE EXACT LOCATION OF INCOMING ELECTRICAL SERVICE WITH LOCAL POWER COMPANY PRIOR TO PROJECT START-UP. NOTIFY ENGINEER OF ANY CHANGES AS MAY BE REQUIRED.
15.	E.C. TO VERIFY DEVICE PLATE COLOR AND MATERIAL WITH ARCHITECT PRIOR TO PURCHASE.
16.	THE ELECTRICAL CONTRACTOR SHALL BE RESPONSIBLE FOR PROTECTING ALL ELECTRICAL EQUIPMENT FROM FOREIGN MATERIAL DURING CONSTRUCTION (PAINT, SPACKLE, ETC.).
17.	PENETRATIONS OF REQUIRED SMOKE PARTITIONS SHALL BE SEALED USING METHODS APPROVED UNDER THE STATE BUILDING CODE. COORDINATION WITH THE GENERAL CONTRACTOR SHALL BE MAINTAINED TO INSURE THAT THIS SMOKE STOPPING IS ACCOMPLISHED.
18.	WHERE PENETRATIONS ARE MADE THROUGH A REQUIRED FIRE-RESISTIVE WALL, FLOOR, OR PARTITION FOR THE PURPOSE OF RUNNING RACEWAY CARRYING ELECTRICAL, TELEPHONE, TELEVISION, OR LOCAL COMMUNICATION AND/OR SIGNALING CIRCUITS, THE OPENING AROUND THE RACEWAY SHALL BE FIRE STOPPED PER THE STATE BUILDING CODE. COORDINATION WITH THE GENERAL CONTRACTOR SHALL BE MAINTAINED TO INSURE THAT THIS FIRE STOPPING IS ACCOMPLISHED. USE APPROVED U.L. OR EQUIVALENT ASSEMBLIES.
19.	IN REQUIRED FIRE RATED WALLS AND PARTITIONS, OPENINGS FOR INSTALLATION OF BOXES THAT ARE GREATER THAN 16 SQUARE INCHES SHALL BE PROTECTED AS REQUIRED BY U.L. COORDINATE CLOSELY WITH THE GENERAL CONTRACTOR TO INSURE THAT THE INTEGRITY OF THE U.L. RATING IS MAINTAINED.
20.	WHERE A HOME RUN IS SHOWN THE CIRCUIT SHALL BE INSTALLED IN A DEDICATED CONDUIT, DO NOT COMBINE WITH OTHER CIRCUITS. WHERE A CIRCUIT HOMERUN IS NOT SHOWN, THE CONTRACTOR SHALL COMBINE CIRCUITS TO FOLLOW A MAXIMUM OF THREE 20A BRANCH CIRCUITS MAY BE COMBINED IN A COMMON HOMERUN SHARING A COMMON NEUTRAL OR WITH SEPARATE NEUTRALS FOR A MAXIMUM TOTAL OF SIX CURRENT CARRYING CONDUCTORS. ALL BRANCH CIRCUITS LARGER THAN 20A SHALL BE SEPARATELY HOMERUN TO THE PANEL.
21.	COORDINATE WITH THE CABLE TV AND TELEPHONE UTILITIES AS REQUIRED FOR SERVICE ENTRANCE REQUIREMENTS. INSTALLATION MUST COMPLY WITH THEIR RESPECTIVE REGULATIONS.
22.	RECEPTACLES SHALL BE SPECIFICATION GRADE EQUAL TO HUBBELL 5300 SERIES. GROUND RECEPTACLES SHALL BE HUBBELL GF-5362. LIGHTING SWITCHES SHALL BE SPECIFICATION GRADE EQUAL TO HUBBELL 1200 SERIES.
23.	ALL EXTERIOR FIXTURES AND DEVICES SHALL BE RATED FOR OPERATION AT 0' F AND SHALL BE WET OR WET Labeled AS REQUIRED.
24.	THE ELECTRICAL CONTRACTOR SHALL BE RESPONSIBLE FOR INSTALLING ALL ELECTRICAL EQUIPMENT, DEVICES, ETC. IN ACCORDANCE WITH LOCAL SEISMIC CODE REQUIREMENTS. PROVIDE SEISMIC RESTRAINTS, ACCESSORIES AND INSTALLATION DETAIL AS REQUIRED.
25.	VERIFY THAT ALL CONDUIT PENETRATIONS OF THE WALK-IN REFRIGERATOR AND FREEZER ARE SEALED PER 300.7(A).
26.	ELECTRICAL CONTRACTOR TO COORDINATE THE EXACT MCA/MOCP REQUIREMENTS OF ALL EQUIPMENT WITH ALL OTHER TRADES PRIOR TO PRICING, ORDERING, OR INSTALLING ANY ELECTRICAL GEAR. THIS SHALL INCLUDE BUT NOT LIMITED TO ALL HVAC, PLUMBING, KITCHEN, OWNER PROVIDED EQUIPMENT, ETC.

ELECTRICAL ABBREVIATIONS	
18"	DIMENSION INDICATES HEIGHT ABOVE FINISHED FLOOR AT WHICH CENTER OF DEVICE IS TO BE MOUNTED.
AFF	ABOVE FINISHED FLOOR.
AFG	ABOVE FINISHED GRADE.
EC	ELECTRICAL CONTRACTOR.
FPN	FUSE PER EQUIPMENT NAMEPLATE REQUIREMENTS.
GC	GENERAL CONTRACTOR.
MC	MECHANICAL CONTRACTOR.
PC	PLUMBING CONTRACTOR.
WP	INDICATES DEVICE TO HAVE WEATHERPROOF COVER.
UN	UNLESS OTHERWISE NOTED.
FACP	FIRE ALARM CONTROL PANEL.

LIGHTING FIXTURE SCHEDULE											
MARK	MANUF.	CATALOG NUMBER	LAMP DATA		VOLTS	BALLAST DATA		MOUNTING	DESCRIPTION	DETAILS	
			NO.	TYPE		NO.	TYPE				
A	LSI INDUSTRIES	QLS-LPEC24-LED-40L-UNV-40	-	LED	120	1	ELECTRONIC DRIVER	RECESSED	2x4 LED LAY-IN FIXTURE WITH STEEL HOUSING, ACRYLIC LENS, WHITE BAKED ENAMEL FINISH.	PROVIDE 'EM10' OPTION FOR ALL 'NL' FIXTURES, 90MIN. 1100 LUMEN BATTERY PACK.	
B	LSI INDUSTRIES	QLS-PDL6K-LED-08-40-120-WH	-	LED	120	-	ELECTRONIC DRIVER	13	RECESSED	6" RECESSED LED DOWNLIGHT WITH WHITE TRIM, NON-IC RATED HOUSING.	PROVIDE 6" NEW CONSTRUCTION HOUSING PDL6K HSG NC.
BS	LSI INDUSTRIES	QLS-PDL6K-LED-08-120-SILVER	-	LED	120	1	ELECTRONIC DRIVER	13	RECESSED	6" RECESSED LED DOWNLIGHT WITH SILVER TRIM, NON-IC RATED HOUSING.	PROVIDE 6" NEW CONSTRUCTION HOUSING PDL6K HSG NC.
C	LSI INDUSTRIES	QLS-XL62-5-LED-60-55-CW-5PC	-	LED	120	1	ELECTRONIC DRIVER	60	RECESSED	18x18 RECESSED LED DOWNLIGHT IN CANOPY.	LED SOFFIT LIGHT.
F	LSI INDUSTRIES	QLS-ES-4-5-LED-HO-120-WH-RM-5PC	-	LED	120	1	ELECTRONIC DRIVER	61	SURFACE	4' LED STRIP LIGHT. UL WET LOCATION LISTED.	SURFACE MOUNT IN STORAGE SHED AS REQUIRED.
G	LSI INDUSTRIES	QLS-PDL6K-LED-07-NH-120-AD-R1-5PC	-	LED	120	1	ELECTRONIC DRIVER	14	RECESSED	6" RECESSED LED DOWNLIGHT WITH ADJUSTABLE EYEBLL WHITE TRIM.	PROVIDE SEPARATE HOUSING AS REQUIRED.
LL-01	BRUCKER	SIEMENS LED PENDANT W/ SILVER CANOPY	-	LED	120	1	ELECTRONIC DRIVER	6	PENDANT	CUSTOM PENDANT LIGHT IN FRONT DINING ROOM WITH SILVER HOUSING AND SILVER CORD.	COORDINATE HANGING HEIGHT WITH ARCHITECTURAL PLANS.
LL-02A	LSI INDUSTRIES	SPL-CHT-300-INC-120-RPY-A14-ENCA120	1	INC 100W	120	1	-	100	PENDANT	PENDANT LIGHT IN FRONT DINING ROOM WITH YELLOW FINISH AND SILVER CANOPY.	COORDINATE HANGING HEIGHT WITH ARCHITECTURAL PLANS.
LL-03	RAB LTG	LFPI6A/ARM-18"	1	E26 BASE LED PAR16 FLD 4000K	120	1	ELECTRONIC DRIVER	7	WALL	LED SIGN LIGHT WITH 18" STEM.	
LL-07	QUALITY LTG SUPPLY	WSN1-2LL-UP/DN LIGHT	2	E26 BASE LED PAR20 SPOT 4000K	120	2	ELECTRONIC DRIVER	22	WALL	BRONZE UP/DOWN CYLINDER LIGHT.	ALUMINUM BRONZE CYLINDER.
LL-08	QUALITY LTG SUPPLY	WSN1-2LL-DN LIGHT ONLY	1	E26 BASE LED PAR20 SPOT 4000K	120	1	ELECTRONIC DRIVER	11	WALL	BRONZE DOWN LED CYLINDER LIGHT.	ALUMINUM BRONZE CYLINDER.
LL-09	LSI INDUSTRIES	B0200-10-WH-LED-120-240-LD5%+GB-K-3-RAL 1021-5PC	-	LED	120	1	ELECTRONIC DRIVER	11	WALL	ABOLITE SERIES GOOSENECK LIGHT.	BRONZE FINISH.
OAI	LSI INDUSTRIES	QLS-XGBMNB-FT-LED-48-450-CW-UE-R11-5PC	-	LED	120	1	ELECTRONIC DRIVER	72	WALL	FULL CUTOFF LED WALL SCONCE. FACTORY PAINTED TO MATCH EIFS.	DIE-CAST ALUMINUM HOUSING. CLEAR TEMPERED GLASS LENS. WET LOCATION LABEL.
OC1	LSI INDUSTRIES	QLS-XLCH-FT-LED-HO-CW-D180 ON 24' POLE, 24" BASE	2	LED	208	1	ELECTRONIC DRIVER	276W/HEAD	POLE	LED POLE MOUNTED FIXTURES AT 180'.	DARK BRONZE FINISH. MOUNT ON 24" SQUARE STEEL POLE. SEE CIVIL DRAWINGS FOR POLE LOCATIONS, QUANTITY, AND CONFIGURATION OF FIXTURES ON POLES.
OC2	LSI INDUSTRIES	QLS-XLCH-(1)-FT-L1 (1)-FT-R-LED-HO-CW-D180 ON 24' POLE, 24" BASE	2	LED	208	1	ELECTRONIC DRIVER	276W/HEAD	POLE	LED POLE MOUNTED FIXTURES AT 180', ROTATED OPTICS.	DARK BRONZE FINISH. MOUNT ON 24" SQUARE STEEL POLE. SEE CIVIL DRAWINGS FOR POLE LOCATIONS, QUANTITY, AND CONFIGURATION OF FIXTURES ON POLES.
X	LSI INDUSTRIES	QLS-2PRLED-SD2-WI	-	LED	120	-	NONE	5	WALL/CEILING	EXTERIOR EMERGENCY LIGHT.	WET LOCATION LABEL. SUPPLY WITH REMOTE MOUNTED EMERGENCY BATTERY PACK FOR 90MIN. OPERATION.
LA	LSI INDUSTRIES	QLS-LPRX-U-W-HB-LD-II-R-R1-5PC	-	LED	120	-	NONE	2.5	UNIVERSAL	COMBINATION EMERGENCY/LED EXIT SIGN.	POLYCARBONATE HOUSING WITH SELF-CONTAINED POWER PACK FOR 90MIN. OPERATION. NICAD BATTERY. WHITE HOUSING. RED LETTERS.
LA	LSI INDUSTRIES	QLS-LTEM-WH-R1-5PC	-	LED	120	-	NONE	2.5	WALL	INTERIOR EMERGENCY WALL PACK.	POLYCARBONATE HOUSING WITH SELF-CONTAINED POWER PACK FOR 90MIN. OPERATION. WHITE HOUSING.

- NOTES:
- ALL LED LAMPS SHALL BE 4100K AS SPECIFIED. ALL LED DRIVERS SHALL BE AS SPECIFIED. SUBMITTAL SHEETS SHALL BE SUBMITTED WITH FIXTURE SUBMITTALS. LED LAMP AND DRIVER WARRANTY SHALL BE COMPLETED BY CONTRACTOR AND TURNED OVER TO OWNER AT END OF PROJECT.
 - SEE ARCHITECTURAL REFLECTED CEILING PLAN FOR EXACT FIXTURE LOCATIONS.
 - ALL LED DRIVERS SHALL HAVE END OF LIFE SHUTDOWN PROTECTION.
 - SUSPEND TWO OPPOSITE CORNERS WITH WIRE TO STRUCTURE. DO NOT ALLOW GRID ALONE TO SUPPORT FIXTURES.
 - ALL EMERGENCY LIGHTS TO BE EQUIPPED WITH A LOCAL MEANS OF TESTING LIGHT FUNCTION WITHOUT DISASSEMBLY OF LIGHTING FIXTURES OR SWITCHING OFF ENTIRE LIGHTING CIRCUITS.
 - CONTACT RONNIE MANGUM/MARK HARRIS WITH QUALITY LIGHTING SUPPLY TO ORDER THE LIGHT FIXTURES, 704-663-0574.

SABER ENGINEERING
2823 South Tryon Street, Suite 280
Charlotte, North Carolina 28203
Tel: 704.373.0068 Fax: 704.373.0260
MECHANICAL ELECTRICAL PLUMBING

architecture + interior design
421 Penman Street, Suite 200, Charlotte, NC 28203
Email: esd@esdarch.com • Phone: 704-373-1900

NOT FOR CONSTRUCTION
PRELIM-BUDGET

BOJANGLES' 14 RESTAURANT
HUDSON BRIDGE ROAD
AT WILLIS DRIVE
STOCKBRIDGE, GEORGIA

NOT FOR CONSTRUCTION
PRELIM-BUDGET

ISSUE DATE: 02-08-2019
REVISION 1: _____
REVISION 2: _____
REVISION 3: _____
REVISION 4: _____

PROJECT #: 18-164-000
CONTENT: ELECTRICAL SYMBOLS AND SCHEDULES

PROJECT ENGINEER: SABER

DRAWN BY: RPL

CADD FILE NAME: ESD-1901-14-E01.dwg

THIS DRAWING AND THE DESIGN SHOWN ARE THE PROPERTY OF BOJANGLES RESTAURANTS, INC. THE REPRODUCTION OR USE OF THIS DRAWING WITHOUT THE WRITTEN CONSENT IS PROHIBITED. ANY INFRINGEMENT IS SUBJECT TO LEGAL ACTION.

Sheet
E-1

THE ARCHITECT/ENGINEER DOES NOT DEFINE THE SCOPE OF INDIVIDUAL TRADES, SUBCONTRACTORS, MATERIAL SUPPLIERS, OR VENDORS. ANY SHEET NUMBERING SYSTEM USED WHICH IDENTIFIES DISCIPLINES IS SOLELY TO SEPARATE ARCHITECTS AND ENGINEERS SCOPE. IT DOES NOT DEFINE A SUBCONTRACTOR'S SCOPE OF WORK. ANY DISCREPANCIES BETWEEN DRAWINGS, SPECIFICATIONS, CODES OR CONSTRUCTION SEQUENCING SHALL BE BROUGHT TO THE ATTENTION OF THE ARCHITECT PRIOR TO PROCEEDING. NO CONSIDERATION WILL BE GIVEN TO REQUESTS FOR CHANGE ORDERS FOR FAILURE TO OBTAIN AND REVIEW THE COMPLETE SET OF CONSTRUCTION DOCUMENTS, OR FOR FAILURE TO SEEK INTERPRETATION FROM ARCHITECT FOR DISCREPANCIES.

Order