




BOJANGLES
 architecture + interior design
 421 Penman Street, Suite 200, Charlotte, NC 28203
 Email: esd@esdarch.com • Phone: 704-373-1900

WIRE LEGEND:
 DASHED ----- FIELD
 SOLID ----- 14AWG
 DASHED-DOT ----- 18AWG

IMPORTANT NOTE:
 JUMPER FROM TOP OF C-32
 TERMINAL BLOCK TO TOP OF FTB
 TERMINAL BLOCK INSTALLED AT
 CHECKOUT

IMPORTANT NOTE:
 A 10.7K OHM RESISTOR TO BE
 FACTORY INSTALLED BETWEEN
 TERMINALS 24V AND PS2



CPI-400 PROGRAMMING

OUTPUT NUMBER	OUTPUT DESIGNATION	DAYS OF WEEK							OUTPUT SETPOINTS
		SUNDAY	MONDAY	TUESDAY	WEDNESDAY	THURSDAY	FRIDAY	SATURDAY	
1	SIGN LIGHTS TOP & LIGHT LEVEL	4:55 AM					4:55 AM	4:55 AM	EN 81
		12:00 AM					12:00 AM	12:00 AM	OFF
								EN 82	
								OFF	
								LGT. LEVEL	
								LO TEMP	
								HI TEMP	
2	PARKING LITG. TOP & LIGHT LEVEL	4:15 AM					4:15 AM	4:15 AM	EN 81
		1:00 AM					1:00 AM	1:00 AM	OFF
								EN 82	
								OFF	
								LGT. LEVEL	
								LO TEMP	
								HI TEMP	

1 CONTROLS WIRING SCHEMATIC
 DIAGRAMMATIC

Order Plans @

NOT FOR CONSTRUCTION
 PRELIM-BUDGET

BOJANGLES' 14 RESTAURANT
 HUDSON BRIDGE ROAD
 AT WILLIS DRIVE
 STOCKBRIDGE, GEORGIA

NOT FOR CONSTRUCTION
 PRELIM-BUDGET

ISSUE DATE: 02-08-2019
 REVISION 1: ---
 REVISION 2: ---
 REVISION 3: ---
 REVISION 4: ---

PROJECT #: 18-164-000
 CONTENT: ELECTRICAL
 DETAILS

PROJECT ENGINEER: SABER
 DRAWN BY: RPL

CADD FILE NAME:
 ESD-1901-14-E08.dwg

THIS DRAWING AND THE DESIGN SHOWN ARE THE PROPERTY OF BOJANGLES RESTAURANTS, INC. THE REPRODUCTION OR USE OF THIS DRAWING WITHOUT THEIR WRITTEN CONSENT IS PROHIBITED. ANY INFRINGEMENT IS SUBJECT TO LEGAL ACTION.

Sheet
E-8

THE ARCHITECT/ENGINEER DOES NOT DEFINE THE SCOPE OF INDIVIDUAL TRADES, SUBCONTRACTORS, MATERIAL SUPPLIERS, OR VENDORS. ANY SHEET NUMBERING SYSTEM USED WHICH IDENTIFIES DISCIPLINES IS SOLELY TO SEPARATE ARCHITECTS AND ENGINEERS SCOPE. IT DOES NOT DEFINE A SUBCONTRACTOR'S SCOPE OF WORK. ANY DISCREPANCIES BETWEEN DRAWINGS, SPECIFICATIONS, CODES OR CONSTRUCTION SEQUENCING SHALL BE BROUGHT TO THE ATTENTION OF THE ARCHITECT PRIOR TO PROCEEDING. NO CONSIDERATION WILL BE GIVEN TO REQUESTS FOR CHANGE ORDERS FOR FAILURE TO OBTAIN AND REVIEW THE COMPLETE SET OF CONSTRUCTION DOCUMENTS, OR FOR FAILURE TO SEEK INTERPRETATION FROM ARCHITECT FOR DISCREPANCIES.