



DEPTH OF BURY FEET	B+ DIM. FEET	APPROX WT. LBS.
2	4 1/2	57
3	5 1/2	62
4	6 1/2	67
5	7 1/2	72
6	8 1/2	77
7	9 1/2	82
8	10 1/2	87
9	11 1/2	92
10	12 1/2	97

NOTES:

1. 'B' DIM. BASED ON OUTLET CONNECTION 30" ABOVE GRADE.
2. IMPORTANT: HYDRANT MUST BE OPENED ONE TURN MINIMUM TO SEAL DRAIN PORT DURING USE.

1 NONE FREEZE HOSE AND BIB
 C-502 SCALE: NONE

2/11/2019 1:57:35 PM - O:\PROJECTS\ATLANTA\TAI\ER01297\200-01297-19012\CADD\SHEETFILES\C-502 CONSTRUCTION DETAILS.DWG - GULMIRE, CALEB

Order Plans @ www.LDILine.com



GSWCC LEVEL 1
 CERT. # 0000060744

www.tetra.tech.com
 1889 POWERS FERRY RD SE STE 400
 ATLANTA, GA 30339
 TEL: (770) 850-0949 FAX: (770) 850-0950

MARK	DATE	DESCRIPTION	BY
01	01/14/19	60% SUBMITTAL	CG
02	02/11/19	ISSUED FOR BID	MS

CITY OF ALPHARETTA
 OLD ROSWELL ST PARKING LOT
 IMPROVEMENTS PROJECT
 CONSTRUCTION DETAILS

PROJ: 200-01297-19012
 DESN: CG
 DRWN: HA
 CHKD: DL

C-502