

GENERAL NOTES: (THIS SHEET ONLY, EXCEPT AS NOTED)

1. NO WORK IN HATCHED AREAS, UNLESS NOTED OTHERWISE.
2. MATERIALS EXPOSED WITHIN PLENUMS ARE REQUIRED TO BE NONCOMBUSTIBLE OR SHALL HAVE A FLAME SPREAD INDEX OF NOT MORE THAN 25 AND A SMOKE-DEVELOPED INDEX OF NOT MORE THAN 50 AS DETERMINED IN ACCORDANCE WITH ASTM E 84 EXCEPT FOR TESTED AND LABELED WIRING, FIRE SPRINKLER PIPING, PNEUMATIC TUBING, AND ELECTRICAL EQUIPMENT. (IBC SECTIONS 716.5 AND 1017.4.1; IMC SECTION 602.2.1)
3. REFER TO MECHANICAL DRAWINGS FOR EXACT DUCT DETECTOR MOUNTING LOCATION AND QUANTITIES. (TYPICAL)

© 2019
 PRECISION PLANNING, INC.
 400 PINE BOULEVARD, LAWRENCEVILLE, GA 30046
 770.339.8000 • www.ppi.us

STAMP

TRU T. GEORGE, REGISTERED PROFESSIONAL ENGINEER
 No. 025846
 WILLIAM W. HILLIS

PRECISION Planning Inc.
 planners • engineers • architects • surveyors

400 Pine Boulevard, Lawrenceville, GA 30046
 770.339.8000 • www.ppi.us

**GWINNETT COUNTY
 VOTER REG. AND
 ELEC. RENOVATION**

455 Grayson Highway Suite 200
 Lawrenceville, GA 30046

PROJECT

SPECIAL SYSTEMS PLAN	
DESIGN	CHECKED
RVG	PCE
DRAWN	PCE
CAD	

DATE	NO. DESCRIPTION	RELEASED FOR
02/04/19		BD

DATE	PROJ. NUMBER	FILE NAME	FILE NUMBER
02-04-19	A16-87AGSB		

E4.1



Phillips Consulting Engineers, LLC
 260 Beckenham Walk Drive
 Dacula, GA 30019
 Office (434)573-0502 Mobile (770)825-6159
 www.phece.com

1 SPECIAL SYSTEMS PLAN
 E4.1 SCALE: 1/8" = 1'-0"