



FOOTING SCHEDULE			
MARK	SIZE W x L x D	REINFORCING	REMARK
(A)	6'-0" X CONT. X 12"d	# 5 @ 12" O.C. EA WAY	CONT. WALL FOOTING
(B)	4'-0" X 4'-0" X 12"d	4 # 5 E.W. BOT.	
(C)	2'-0" X CONT. X 12"d	2 # 5 / BOT. CONT.	CONT. WALL FOOTING

NOTES:
1. PROVIDE CORNER BARS AT INTERSECTIONS.

- FOUNDATION AND GROUND FLOOR PLAN NOTES:**
1. VERIFY ALL DIMENSIONS AND ELEVATIONS WITH ARCHITECTURAL DRAWINGS. SEE ARCHITECTURAL AND MEP FOR ADDITIONAL INFORMATION.
 2. SEE ARCHITECTURAL DRAWINGS FOR ALL SLOPES, DROPS AND DRAIN LOCATIONS IN FLOOR SLAB. MAINTAIN 30" MINIMUM SLAB DEPTH. REINFORCE SLAB WITH #6 BARS AT 8" O.C. EACH WAY TOP AND BOTTOM OF SLAB.
 3. ELEVATIONS SHOWN ARE RELATIVE TO THE GROUND FLOOR SLAB SURFACE SET AT 0'-0" (REF.).
 4. CENTERLINES OF WALLS AND COLUMNS SHALL COINCIDE WITH CENTERLINES OF FOOTINGS AT ALL INTERIOR LOCATIONS.
 5. TOP INDICATES TOP OF FOOTING ELEVATION. TOP OF FOOTING ELEVATION SET AT (-)1'-4" UNLESS NOTED OTHERWISE. PROVIDE A MINIMUM COVER OF SOIL OVER FOOTINGS.
 6. [Pattern] INDICATES AN 8" LOAD BEARING MASONRY WALL. PROVIDE (1)#5 BAR AT CORNERS, ENDS, INTERSECTIONS OF WALLS, UNDER POINT LOADS AND AT 32" O.C. MAX. GROUT ALL CELLS WITH HOOK BARS IN BOND BEAM AT TOP OF WALL.
 7. [Pattern] INDICATES AN 8" KNEE WALL. PROVIDE #5 BAR IN GROUT FILLED CELLS AT CORNERS, ENDS, INTERSECTIONS OF WALLS UNDER POINT LOADS AND AT 32" O.C. MAX. SEE ARCH FOR DETAILS AND WALL ELEVATIONS. PROVIDE AN 8" GROUT SOLID W/(1)#5 BAR CONTINUOUS.
 8. [Pattern] INDICATES AN 8" MASONRY PARTY WALL. PROVIDE (1)#7 IN GROUT FILLED CELLS AT CORNERS, ENDS, INTERSECTIONS OF WALLS, UNDER POINT LOADS AND AT 24" O.C. MAX. SEE ARCH FOR DETAILS AND WALL ELEVATIONS.
 9. [Pattern] INDICATES AN 8" MASONRY PRIVACY WALL. PROVIDE (1)#7 IN GROUT FILLED CELLS AT CORNERS, ENDS, INTERSECTIONS OF WALLS, UNDER POINT LOADS AND AT 16" O.C. MAX. SEE ARCH FOR DETAILS AND WALL ELEVATIONS.
 10. (MC) INDICATES 16x16 MASONRY COLUMN WITH (1) #5 VERTICAL BAR IN EACH CELL.

Amenity 2 Foundation Plan
SCALE 1/4" = 1'-0"

DESIGNED BY:
DEVELOPED BY:
COLONIAL ISLAND, LLC
333 3RD AVENUE NORTH
SUITE 400
ST. PETERSBURG, FL 33701

SUNSET POINTE AMENITY BUILDING
AT COLLANY KEY

To the best of the Architect's knowledge, he gives the applicable minimum building code requirements for the building as determined by the local authority having jurisdiction in accordance with the applicable Florida Statutes Chapter 633, Florida Statutes



CURTIS GAINES HALL JONES
ARCHITECTS
1213 E. 6TH AVE
YBOR CITY
TAMPA FLORIDA 33605
PHONE 813 228-8000
FAX 813 228-0770
FL CERT. #AACC01590

JOB NO. 1311B
DATE JULY 16, 2018
DRAWN BY
REV. 1 12-12-2018
REV. 2 02-11-2019
REV. 3
REV. 4
REV. 5
REV. 6
REV. 7
REV. 8
REV. 9
REV. 10
REV. 11
REV. 12

PERMIT DOCUMENTS

Wilson Structural Consultants, Inc.
101 PROFESSIONAL PARKWAY
SUITE 100
TAMPA, FLORIDA 33606
TEL: 813.228.1100
FAX: 813.228.1101
WWW.WILSONSTRUCTURAL.COM
Cert. of Authorization #9099

07/16/2018
ENGINEER OF RECORD
ANTHONY R. WILSON
FL P.E. # 79451
AMENITY FOUNDATION
PLAN