

GENERAL ELECTRICAL NOTES:

- "A 1/E-501" INDICATES DETAIL NUMBER/SHEET NUMBER.
- "(DP/1)" INDICATES MATERIAL LIST ITEM IN HEX SYMBOL.
- (X) INDICATES KEY NOTE USED TO DESCRIBE ADDITIONAL INFORMATION OF WORK REQUIRED, SPECIFIC TO THE SHEET IT IS SHOWN ON.
- "NL" INDICATES FIXTURE IS UNSWITCHED FOR NIGHT LIGHT.
- ALL ELECTRICAL CONDUCTORS SHALL BE COPPER, U.O.N.
- INDICATES NUMBER OF WIRES IN CONDUIT.
 ISOLATED GROUND
 GROUND WIRE
 NEUTRAL WIRE
 PHASE WIRE
- ABBREVIATION KEY:
 EC ELECTRICAL CONTRACTOR
 GC GENERAL CONTRACTOR
 MC MECHANICAL CONTRACTOR
 C CONDUIT
 TYP TYPICAL
 UG UNDERGROUND
 +8" MOUNTING HEIGHT FROM FINISHED FLOOR TO CENTERLINE

ELECTRICAL INSTALLATION NOTES:

- THE COMPLETE INSTALLATION SHALL BE IN ACCORDANCE WITH THE A.D.A.A.G. (AMERICANS WITH DISABILITIES ACT ACCESSIBILITY GUIDELINES)
- CIRCUIT NUMBERS ARE SHOWN FOR CIRCUIT IDENTIFICATION. CIRCUITING SHALL AGREE WITH NUMBERING ON THE PANEL PROVIDED. WHERE COMMON NEUTRAL IS USED FOR TWO OR THREE CIRCUITS, EACH SHALL ORIGINATE FROM DIFFERENT PHASE LEGS OF THE PANEL BUS. COMMON NEUTRALS SHALL NOT BE USED FOR COMPUTER OR OFFICE RECEPTACLES. BALANCE THE LOAD ON PANEL AS EVENLY AS POSSIBLE BETWEEN EACH PHASE.
- CIRCUIT SERVING EXIT FIXTURES IN SALES AREA SHALL BE RUN IN SEPARATE CONDUIT FROM ALL OTHER CIRCUITS. INSTALL A MANUFACTURER'S LOCK-ON DEVICE ON CIRCUIT BREAKER FEEDING EMERGENCY EQUIPMENT.
- A #12 GREEN INSULATED GROUND CONDUCTOR SHALL BE INSTALLED WITH CIRCUIT CONDUCTORS TO ALL RECEPTACLES.
- FLUSH MOUNT ALL TOGGLE SWITCHES AT +48" FROM FINISHED FLOOR (CENTERLINE DIMENSION), EXCEPT WHERE OTHERWISE NOTED.
- FLUSH MOUNT ALL DUPLEX RECEPTACLES AND TELECOMMUNICATION OUTLETS AT HEIGHT FROM FINISHED FLOOR TO CENTERLINE AS NOTED ON PLANS.
- CONTRACTOR SHALL VERIFY ALL FURNITURE, MODULAR FURNITURE AND EQUIPMENT LOCATIONS WITH ARCHITECTURAL PLANS, ELEVATIONS AND REVIEWED SHOP DRAWINGS PRIOR TO ROUGH-IN. PRIOR TO MAKING THE ACTUAL ELECTRICAL INSTALLATION THIS CONTRACTOR SHALL ADJUST RECEPTACLES, OUTLETS OR CONNECTION LOCATIONS TO ACCOMMODATE FURNITURE AND/OR EQUIPMENT.
- BOXES LOCATED ON OPPOSITE SIDES OF NON-FIRE RATED WALLS SHALL BE OFFSET A MINIMUM OF 6" HORIZONTALLY. BOXES ON OPPOSITE SIDES OF FIRE RATED WALLS SHALL BE OFFSET A MINIMUM OF 24" HORIZONTALLY (IN DIFFERENT STUD SPACES). "THRU-THE-WALL" BOXES SHALL NOT BE ALLOWED WITHOUT PRIOR WRITTEN APPROVAL OF THE ARCHITECT/ENGINEER.
- ELECTRICAL EQUIPMENT SHALL BE INSTALLED TO AVOID INTERFERENCE WITH THE OPERATION OF AND/OR ACCESS TO OTHER EQUIPMENT. ALL MOUNTING OF ELECTRICAL ITEMS ON EQUIPMENT SUPPLIED BY ANOTHER CONTRACTOR SHALL BE APPROVED IN ADVANCE BY THE OTHER CONTRACTOR AND OWNER.
- ALL FINAL ELECTRICAL CONNECTIONS TO MOTORS AND EQUIPMENT SUBJECT TO VIBRATION SHALL BE MADE WITH FLEXIBLE METAL CONDUIT. USE LIQUIDTIGHT CONDUIT AND FITTINGS WHERE SUBJECT TO MOISTURE. ROUTE GROUND WIRE FROM CIRCUIT GROUND TO MOTOR GROUND THROUGH FLEXIBLE CONDUIT.
- CONTRACTOR SHALL BE RESPONSIBLE FOR ALL OPENINGS REQUIRED IN WALLS. ALL OPENINGS SHALL BE REPAIRED TO MATCH EXISTING BY A QUALIFIED CONTRACTOR AT THE EXPENSE OF THIS CONTRACTOR. ALL CONDUIT PENETRATIONS THROUGH BUILDING WALLS SHALL BE GROUTED OR SEALED CLOSED. WHERE CONDUIT PENETRATES WALLS AND FLOORS SEAL WITH A U.L. LISTED SEALANT. SEAL PENETRATIONS WITH INTUMESCENT CAULK, PUTTY, OR SHEET INSTALLED PER MANUFACTURER'S RECOMMENDATIONS. ALL MATERIALS USED TO SEAL PENETRATIONS OF FIRE WALLS AND FLOORS SHALL BE TESTED AND CERTIFIED AS A SYSTEM PER ASTM E814 STANDARDS FOR FIRE TESTS OR THROUGH-PENETRATION FIRE TOPS AS MANUFACTURED BY 3M, THOMAS & BETTS, OR DUPONT.
- ALL CONDUIT SHALL BE CONCEALED IN WALLS, PARTITIONS OR ABOVE CEILING, ETC., UNLESS OTHERWISE INDICATED ON THE PLANS OR IN THE SPECIFICATIONS. CONDUIT MAY BE EXPOSED IN BACKROOM TO DISTRIBUTION PANEL ONLY IN VERTICAL RUNS. IF NO CEILING IS INSTALLED, CONDUIT SHALL BE RUN JUST BELOW ROOF DECK AT BOTTOM OF UPPER CHORD OF ROOF JOISTS TO PREVENT POSSIBLE DAMAGE FROM ROOFING SCREWS AND NAILS. COORDINATE LOCATIONS IN SALES AREA WITH MECHANICAL SYSTEM LOCATIONS. ALL CONDUIT SHALL BE PARALLEL AND/OR PERPENDICULAR TO THE BUILDING STRUCTURE AND WALLS. CONDUIT SHALL NOT BE INSTALLED IN OR UNDER THE SLAB UNLESS SPECIFICALLY NOTED OR APPROVED BY ALDI REPRESENTATIVE.
- CONTRACTOR SHALL INSTALL AT EACH SERVICE ENTRANCE PERMANENT DISCONNECTING ACCORDING TO ARTICLE 230.2(E), OF THE NATIONAL ELECTRICAL CODE.
- ALL UPS POWERED RECEPTACLES SHALL BE LABELED WITH DEVICE FACEPLATE "UPS-#1" WHERE # = CIRCUIT NUMBER.
- ELECTRICAL CONTRACTOR SHALL PROVIDE ARC FLASH WARNING LABELS FOR ALL DISCONNECTS PER NFPA 70E/OSHA STANDARDS.
- ALL HEIGHT DIMENSIONS (+102") ARE FROM THE FINISHED FLOOR TO THE CENTERLINE OF THE DEVICE.
- REFER TO 1/E-101 FOR ONE-LINE DIAGRAM.
- REFER TO WETE-401 FOR SCHEDULE OF CIRCUITS FOR PANEL 'L1' & 'L2'.
- IN AREAS WHERE CEILING IS INSTALLED, CONDUIT SHALL BE RUN JUST BELOW ROOF DECK AT BOTTOM OF UPPER CHORD OF ROOF JOISTS.
 REFER TO 601 FOR DOOR HARDWARE REQUIRING LINE VOLTAGE, LOW VOLTAGE AND COMPONENT LOCATIONS.
- IF REQUIRED BY ANY LOCAL JURISDICTION FIRE ALARM SYSTEM CONTRACTOR SHALL BE RESPONSIBLE TO PROVIDE A COMPLETE FIRE ALARM SYSTEM OR AUTOMATIC HEAT/SMOKE DETECTION SYSTEM AS REQUIRED AND IN ACCORDANCE WITH LOCAL AND STATE CODES. CONTRACTOR SHALL SUBMIT DRAWINGS TO THE LOCAL GOVERNING AUTHORITY FOR REVIEW AND APPROVAL PRIOR TO INSTALLATION.

MATERIAL LIST			
ITEM	SYMBOL	DESCRIPTION	APPR'D MFG
THE SYMBOLS AND THE MATERIAL LIST ARE FOR THE CONVENIENCE OF THE CONTRACTOR. EACH CONTRACTOR SHALL BE RESPONSIBLE FOR VERIFICATION OF QUANTITIES AND SHALL FURNISH ALL MATERIAL REQUIRED, WHETHER SPECIFIED OR NOT, TO PRODUCE A COMPLETE AND SATISFACTORY WORKING SYSTEM.			
CATALOG NUMBERS SHALL NOT BE CONSIDERED COMPLETE BUT ARE GIVEN ONLY TO AID THE CONTRACTOR IN THE SEARCH FOR MATERIAL. NO MATERIAL SHALL BE ORDERED BY MANUFACTURER AND CATALOG NUMBER ONLY. EACH CONTRACTOR SHALL FIRST READ THE COMPLETE DESCRIPTION OF THE MATERIAL ON THESE DRAWINGS AND SPECIFICATIONS. THE FIRST MANUFACTURER LISTED IS THE BASIS OF DESIGN. "STANDARD COLOR" INDICATES FACTORY FINISH COLORS AVAILABLE AT NO ADDITIONAL CHARGE.			
WHERE DEVICES ARE GANGED TOGETHER, THE PLATE SHALL BE OF THE GANGED STYLE FOR THE NUMBER AND TYPE OF DEVICES USED.			
ITEM	SYMBOL	DESCRIPTION	APPR'D MFG
1	DP	ALL SWITCH, RECEPTACLE AND OUTLET COLORS SHALL BE GRAY, UNLESS INDICATED OTHERWISE.	PASS & SEYMOUR OR APPROVED EQUAL
2	DP	ALL SWITCHES, RECEPTACLES, AND OUTLETS SHALL BE COMPLETE WITH COVERPLATES, COVERPLATES IN ALL SPACES SHALL BE STAINLESS STEEL UNLESS INDICATED OTHERWISE.	PASS & SEYMOUR HUBBELL BRYANT EAGLE LEVITON
3	DP	SWITCH - TOGGLE HANDLE, MAINTAINED CONTACT, SINGLE POLE, SINGLE THROW, SPECIFICATION GRADE, SIDE AND BACK WIRED, 20 AMP, 120/277 VOLT, U.L. LISTED.	PASS & SEYMOUR 521 OR APPROVED EQUAL
4	DP	SWITCH - TOGGLE HANDLE, THREE WAY, SPECIFICATION GRADE, SIDE AND BACK WIRED, 20 AMP, 120/277 VOLT, U.L. LISTED.	PASS & SEYMOUR 523 OR APPROVED EQUAL
5	DP	SWITCH - PUSHBUTTON, DIGITAL TIMER, TIME OUT SETTING FROM 5 MIN-12 HOUR (SET TO 30 MIN WITH AUDIBLE ALERT ONLY), 120/277 VOLT, U.L. LISTED.	WATSTOPPER #S-400 OR APPROVED EQUAL
6a	DP	CEILING MOUNTED 360° ULTRASONIC OCCUPANCY SENSOR, LINE VOLTAGE 120/277, 500 SQ FT COVERAGE	WATSTOPPER #UT-355-1 HUBBELL #C8001500P120
6b	DP	CEILING MOUNTED 360° PASSIVE INFRARED OCCUPANCY SENSOR, LOW VOLTAGE, PROVIDE POWER PACK, 500 SQ FT COVERAGE	WATSTOPPER #C205-1 HUBBELL #DMNRIL/UVPP
6c	DP	WALL MOUNTED - PASSIVE INFRARED OCCUPANCY SENSOR, 120/277 VOLT, U.L. LISTED, 35SEC-30MIN TIME DELAY	WATSTOPPER #WS-250-W HUBBELL #LHRS1W OR APPROVED EQUALS
7a	DP	RECEPTACLE, DUPLEX - N.E.M.A. 5-20R 125 VOLT, 20 AMP, SPECIFICATION GRADE, 3 WIRE GROUNDING TYPE, NYLON OR POLYCARBONATE FACE, STRAIGHT BLADE, U.L. LISTED.	PASS & SEYMOUR 5362 OR APPROVED EQUAL
7b	DP	RECEPTACLE, DUPLEX - N.E.M.A. 5-20R 125 VOLT, 20 AMP, SPECIFICATION GRADE, TAMPER RESISTANT, 3 WIRE GROUNDING TYPE, NYLON OR POLYCARBONATE FACE, STRAIGHT BLADE, U.L. LISTED.	PASS & SEYMOUR 885TR OR APPROVED EQUAL
8	DP	RECEPTACLE, DOUBLE DUPLEX (QUAD) - [2] N.E.M.A. 5-20R, 125 VOLT, 20 AMP, SPECIFICATION GRADE, WEATHER RESISTANT, 3 WIRE GROUNDING TYPE, NYLON OR POLYCARBONATE FACE, STRAIGHT BLADE, U.L. LISTED. 'Y' INDICATES ISOLATED GROUND TYPE WITH ORANGE NYLON OR POLYCARBONATE FACE, STRAIGHT BLADE, ORANGE COVERPLATE WITH 'ISO, GND.' STENCILED IN BLACK, U.L. LISTED.	PASS & SEYMOUR 5362 OR APPROVED EQUAL
9a	DP	RECEPTACLE, GROUND FAULT DUPLEX - N.E.M.A. TYPE S-15R, 125 VOLT, 15 AMP, SPECIFICATION GRADE, 3 WIRE GROUNDING TYPE, NYLON OR POLYCARBONATE FACE, STRAIGHT BLADE, TEST AND RESET BUTTONS IN FACE, U.L. LISTED.	PASS & SEYMOUR 1591 OR APPROVED EQUAL
9b	DP	RECEPTACLE, GROUND FAULT DUPLEX - N.E.M.A. TYPE S-15R, 125 VOLT, 15 AMP, SPECIFICATION GRADE, TAMPER RESISTANT, 3 WIRE GROUNDING TYPE, NYLON OR POLYCARBONATE FACE, STRAIGHT BLADE, TEST AND RESET BUTTONS IN FACE, U.L. LISTED.	PASS & SEYMOUR 1591TR OR APPROVED EQUAL
10	DP	RECEPTACLE, GROUND FAULT DUPLEX - N.E.M.A. TYPE S-15R, 125 VOLT, 15 AMP, SPECIFICATION GRADE, WEATHER RESISTANT, 3 WIRE GROUNDING TYPE, NYLON OR POLYCARBONATE FACE, STRAIGHT BLADE, TEST AND RESET BUTTONS IN FACE, U.L. LISTED. MOUNTED IN RECESSED BOX WITH GASKET AND EXTRA DUTY WEATHERPROOF WHILE-IN-USE COVER.	PASS & SEYMOUR #1597TR OR APPROVED EQUAL HUBBELL-TAYLOR #M15100Q
11	DP	RECEPTACLE, GROUND FAULT DUPLEX - N.E.M.A. TYPE S-15R, 125 VOLT, 15 AMP, SPECIFICATION GRADE, 3 WIRE GROUNDING TYPE, NYLON OR POLYCARBONATE FACE, STRAIGHT BLADE, TEST AND RESET BUTTONS IN FACE, U.L. LISTED. N.E.M.A. 3R RATED WHILE IN USE, CLEAR NON-LOCKING COVER, STANDARD VERTICAL MOUNT, U.L. LISTED.	PASS & SEYMOUR 1591-3703 OR APPROVED EQUAL
12	DP	RECEPTACLE, GROUND FAULT DUPLEX - N.E.M.A. 5-20R, 125 VOLT, 20 AMP, SPECIFICATION GRADE, 3 WIRE GROUNDING TYPE, ORANGE NYLON OR POLYCARBONATE FACE, STRAIGHT BLADE, TEST AND RESET BUTTONS IN FACE, U.L. LISTED. COVERAGE PLATE WITH 'ISO, GND.' STENCILED IN BLACK, U.L. LISTED.	PASS & SEYMOUR 104300 OR APPROVED EQUAL
13a	DP	RECEPTACLE, SIMPLEX - N.E.M.A. 5-15R, 125 VOLT, 15 AMP, 3 WIRE GROUNDING, SPECIFICATION GRADE, MOUNT IN GASKETED RECEPTACLE SHALL BE WATER TIGHT WITH THREADED CAP OVER THE FACE, FURNISH MATCHING PLUG AND INSTALL ON SUMP PUMP.	CROUSE-HINDS D596 WP820
13b	DP	RECEPTACLE, SIMPLEX - N.E.M.A. 5-20R 125 VOLT, 20 AMP, SPECIFICATION GRADE, 3 WIRE GROUNDING TYPE, NYLON OR POLYCARBONATE FACE, STRAIGHT BLADE, U.L. LISTED.	PASS & SEYMOUR 5361 OR APPROVED EQUAL
14	DP	JUNCTION BOX - 4 SQUARE GALVANIZED STEEL WITH METAL COVER, MOUNTED AS HIGH AS POSSIBLE.	STEEL CITY OR APPROVED EQUAL
15	DP	LOCKING RECEPTACLE, N.E.M.A. TYPE L15-20, 250 VOLT, 25 AMP, 3 PHASE GROUNDING, TWIST LOCK, FLUSH MOUNT.	HUBBELL 420A OR APPROVED EQUAL
16	DP	JUNCTION BOX - 4"x4" SQUARE GALVANIZED STEEL WITH METAL COVER.	STEEL CITY OR APPROVED EQUAL
17	DP	TELEPHONE/VOICE ONLY OUTLET - SINGLE GANG RECESSED BOX WITH COVER AND 3/4" CONDUIT TO ABOVE CEILING OR TO JOIST WEB, VERIFY LOCATION.	STEEL CITY OR APPROVED EQUAL
18	DP	DUPLEX VOICE/DATA OUTLET - SINGLE GANG RECESSED BOX WITH COVER AND 3/4" CONDUIT TO ABOVE CEILING (UNLESS OTHERWISE NOTED), VERIFY LOCATION.	STEEL CITY OR APPROVED EQUAL
19	DP	POWER WALL - FURNISHED BY ALDI INSTALLED BY E.C.	FURNISHED BY ALDI INSTALLED BY E.C.
20	DP	DISCONNECT SWITCH, GENERAL DUTY 3 POLE, NON-FUSIBLE, 3 WIRE, 240 VOLT, 60 AMP, NEMA 1 ENCLOSURE.	SQUARE "D" DU320 GENERAL ELECTRIC CUTLER HAMMER SIEMENS
21	DP	DISCONNECT SWITCH, GENERAL DUTY 3 POLE, NON-FUSIBLE, 3 WIRE, 240 VOLT, 30 AMP, NEMA 1 ENCLOSURE.	SQUARE "D" DU321RB GENERAL ELECTRIC CUTLER HAMMER SIEMENS
22	DP	DISCONNECT SWITCH, GENERAL DUTY 3 POLE, FUSIBLE, 3 WIRE, 240 VOLT, 30 AMP, NEMA 1 ENCLOSURE.	SQUARE "D" DU321 GENERAL ELECTRIC CUTLER HAMMER SIEMENS
23	DP	DISCONNECT SWITCH, GENERAL DUTY 3 POLE, NON-FUSIBLE, 3 WIRE, 240 VOLT, 100 AMP, NEMA 3R ENCLOSURE.	SQUARE "D" DU323RB GENERAL ELECTRIC CUTLER HAMMER SIEMENS
24	DP	DISCONNECT SWITCH, GENERAL DUTY 3 POLE, FUSIBLE, 3 WIRE, 240 VOLT, 400 AMP, NEMA 3R ENCLOSURE.	SQUARE "D" H325NR GENERAL ELECTRIC CUTLER HAMMER SIEMENS
25	DP	DISCONNECT SWITCH, GENERAL DUTY 3 POLE, NON-FUSIBLE, 3 WIRE, 240 VOLT, 100 AMP, NEMA 1 ENCLOSURE.	SQUARE "D" DU323 GENERAL ELECTRIC CUTLER HAMMER SIEMENS

ITEM	SYMBOL	DESCRIPTION	APPR'D MFG
26	DP	MANUAL SWITCH, 120 VOLT, 30 AMP, 2 POLE, SURFACE MOUNT, NO OVERLOADS, NEMA 1 ENCLOSURE.	SQUARE "D" CLASS 2510 KG1 GENERAL ELECTRIC CUTLER HAMMER SIEMENS
27	DP	VIBRATING BELL - 24 VOLT AC, 92 DB AT 10' FEET, 6" DIAMETER GONG, REFER TO DIAGRAM ON E-501.	EDWARDS #340-605 OR APPROVED EQUAL
28	DP	BUIZZER - 24 VOLT AC, 70 DB AT 10' FEET, MOUNT ON OUTSIDE OF SINGLE GANG STAINLESS STEEL BOX PER MANUFACTURER, REFER TO DIAGRAM ON E-501.	EDWARDS #340A-G5 OR APPROVED EQUAL
29	DP	BUIZZER - 24 VOLT AC, 86 DB AT 10' FEET, MOUNT ON OUTSIDE OF SINGLE GANG STAINLESS STEEL BOX PER MANUFACTURER, REFER TO DIAGRAM ON E-501.	EDWARDS #123A-G5 OR APPROVED EQUAL
30	DP	CHIME - 24 VOLT AC, 81 DB AT 10' FEET, SURFACE MOUNT PER MANUFACTURERS INSTRUCTIONS TO STAINLESS STEEL BOX. REFER TO DIAGRAM ON E-501.	EDWARDS #336-G5 OR APPROVED EQUAL
31	DP	TRANSFORMER - 120 VOLT PRIMARY, 24 VOLT AC SECONDARY, 100 VA, MOUNT ON PANEL 'L2'. REFER TO DIAGRAM ON E-301 & E-501.	EDWARDS #80-100 OR APPROVED EQUAL
32			
33	DP	PUSHBUTTON - SURFACE MOUNT, WEATHERPROOF, 24 VOLT AC, NORMALLY OPEN CONTACT, REFER TO DIAGRAM E-501.	TORX #1786C-B OR APPROVED EQUAL
34	DP	PUSHBUTTON - SURFACE MOUNT, RECTANGULAR, BROWN HOUSING WITH IV CONTACT, 24 VOLT AC NORMALLY OPEN CONTACT, REFER TO DIAGRAM E-501.	EDWARDS #1786C-B OR APPROVED EQUAL
35	DP	PUSHBUTTON - SNAP FIT IN 5/8" HOLE, BLACK PUSHBUTTON BASED 1/8" DIA. 1.0 CONTACT, REFER TO DIAGRAM E-501.	TORX #1786ZD OR APPROVED EQUAL
36	DP	PANIC ALARM PUSHBUTTON MOUNTED ON ALL 6" AC OVER DESK IN OFFICE PROVIDE 2"x4" BOX WITH 1/2" CONDUIT TO ALARM PANEL, VERIFY WITH ARCHITECTURAL DRAWINGS AND OWNERS REPRESENTATIVE.	REFER TO OWNERS REPRESENTATIVE
37			
38	DP	RECESSED BOX WITH 3/4" CONDUIT TO ABOVE CEILING, OR BOTTOM OF RECESSED BOX (IF NO CEILING).	STEEL CITY OR APPROVED EQUAL
39	DP	JUNCTION BOX SNIP END, GALVANIZED STEEL WITH METAL COVER, RECESSED MOUNT, 3/4" CONDUIT EXTENDING ABOVE CEILING, UNLESS OTHERWISE NOTED.	STEEL CITY OR APPROVED EQUAL
40	DP	RECESSED BOX WITH 3/4" CONDUIT TO ABOVE CEILING, OR BOTTOM OF ROOF DECK (IF NO CEILING).	STEEL CITY OR APPROVED EQUAL
41	DP	JUNCTION BOX - 4"x4" SQUARE GALVANIZED STEEL, PROVIDE METAL RING IF NECESSARY TO HOUSE REMOTE DETEX DOOR ALARM SOUNDER.	STEEL CITY OR APPROVED EQUAL
42	DP	SURFACE MOUNTED 4 SQ. DEEP JUNCTION BOX, GALVANIZED STEEL WITH METAL COVER	STEEL CITY OR APPROVED EQUAL
43	DP	OVERHEAD DOOR CONTACT LOCATION - PROVIDE 3/4" CONDUIT FROM 6" ABOVE DOOR HEAD TO BOTTOM OF ROOF DECK.	
44	DP	TEMPERATURE SENSOR - PROVIDE SINGLE GANG BOX WITH MINIMUM 3/4" CONDUIT TO ABOVE CEILING.	STEEL CITY OR APPROVED EQUAL
45	DP	FACILITY STATUS DISPLAY - PROVIDE MINIMUM 3/4" CONDUIT TO ABOVE CEILING.	
46	DP	SMOKE DETECTOR - DUCT TYPE, IONIZATION, 120 VOLT OPERATION, 4 WIRE, CLASS "B" WIRING, SAMPLING TUBES AND HOUSING FOR MOUNTING IN AIR DUCT PER MANUFACTURER'S INSTRUCTIONS, 2 FOR "C" CONTACTS RATED FOR 10 AMPS, COMPLETE WITH BACK BOX, BASE AND MOUNTING HARDWARE, REMOTE TEST STATION WITH POWER AND ALARM INDICATORS. REFER TO MECHANICAL DRAWINGS FOR MODEL # AND STYLE.	FURNISHED AND INSTALLED BY M.C., WIRED BY E.C.
47	DP	ELECTRIC HAND DRYER - ADA COMPLIANT UNIVERSAL VOLTAGE, 950WATT TOTAL, STAINLESS STEEL COVER, SURFACE MOUNT, 35 SECOND TIME CYCLE, 16,000 LFM FAN.	EXCEL DRYER THINAIR #TA-SB
48	DP	UNINTERRUPTIBLE POWER SUPPLY UNIT AND BYPASS SWITCH, 3 KVA, 120 VOLT U.P.S. CONNECTED TO CHECKPLANE BOLTED GROUND CIRCUITS VIA BYPASS SWITCH LOCATED ADJACENT TO U.P.S. ON SHELF, REFER TO DIAGRAM A1/E-501 FOR WIRING DIAGRAM. U.P.S. AND SYSTEM BYPASS FURNISHED BY ALDI, INSTALLED AND WIRED BY E.C.	POWERWARE PW9130L-3000T-XL FURNISHED BY ALDI
49	DP	RECEPTACLE, SIMPLEX, WITH MATCHING PLUG - N.E.M.A. L5-30R AND L5-30P, 125 VOLT, 30 AMP, SPECIFICATION GRADE, 3 WIRE GROUNDING TYPE, NYLON OR POLYCARBONATE FACE, TWIST LOCK, U.L. LISTED	PASS & SEYMOUR L5-30P OR APPROVED EQUAL
50	DP	RECEPTACLE, SIMPLEX, WITH MATCHING PLUG - N.E.M.A. L14-20R AND L14-20P, 125/250 VOLT, 20 AMP, SPECIFICATION GRADE, 4 WIRE GROUNDING TYPE, NYLON OR POLYCARBONATE FACE, STRAIGHT BLADE, U.L. LISTED	PASS & SEYMOUR L14-20P OR APPROVED EQUAL

Issued:	Date:
A Client Review Set	02/15/19
B Bid Set	03/08/19
C	
D	
Revisions:	Date:
1	
2	
3	
4	
5	
6	
7	
8	

DO NOT SCALE PLANS
 Copying, Printing, Software and other processes required to produce these prints can stretch or shrink the actual paper or layout. Therefore, scaling of this drawing may be inaccurate. Contact us consultants with any need for additional dimensions or clarifications.


ms consultants, inc.
 engineers, architects, planners
 920 Main Campus Drive
 Suite 430
 Raleigh, NC 27606-5213
 (919)-772-5565
 fax: (919)-779-2308

DRAWN BY: JMM

REVIEWED BY: KFF

Seal

ENGINEER FIRM LICENSE #C-3239
 PROFESSIONAL OF RECORD:
 DANIEL E. DOWLER NO. 042448
 EXP. DATE: 12/31/2019



ALDI Inc. Store #: 59
 Cary, NC
 1315 Kildaire Farm Rd
 Cary, NC 27511
 Wake County
 Project Name & Location:

Material List & Notes	
Drawing Name:	
Prototype Rls.	Project No.
	40452-25
Type: v7.1	
	E-001
Scale: As Noted	Drawing No.

Order Plans