




REVISION DATE

ELLSWORTH ARCHITECTS  
3136 LANIER DRIVE  
ATLANTA, GEORGIA 30319  
PHONE: 404.949.9361



PRO BUILDING SYSTEMS  
DESIGN BUILD CONTRACTORS

3678 North Peachtree Road  
Atlanta, Georgia 30341  
(770) 455-1791 / Fax 455-4123  
www.probdgsystems.com

GINN CHRYSLER - DODGE - RAM AND JEEP  
I-20 ACCESS ROAD  
COVINGTON GEORGIA 30040

DATE: 11.06.2018

SCALE: AS SHOWN

BY: GD

JOB ID:

SITE POWER PLAN

DRAWING TITLE

E1.1

SHEET 3 OF 14

PROMUS  
SCOTT MERIWETHER, P.E.  
GEORGIA LICENSE #30780  
518 BLACK CANYON PARK  
CANTON, GA 30114  
PROJECT MANAGER: GEORGE DAVIDOV  
PHONE 678.246.5146

- KEY NOTES**
- PROPOSED LOCATION OF UTILITY TRANSFORMER AND CT METER. COORDINATE EXACT LOCATION WITH UTILITY PRIOR TO ROUGH IN.
  - PROPOSED LOCATION OF BUILDING MAIN, REFER TO SHEET E5.1 FOR REQUIREMENTS.
  - APPROXIMATE LOCATION OF ELECTRICAL PANEL(S), REFER TO SHEET E5.1 FOR REQUIREMENTS.
  - PROPOSED ROUTING OF UNDERGROUND SERVICE LATERAL, COORDINATE EXACT ROUTING AS REQUIRED, REFER TO SHEET E5.1 FOR REQUIREMENTS.
  - PROPOSED ROUTING OF UNDERGROUND UTILITY PRIMARY. CONTRACTOR TO COORDINATE EXACT LOCATION AND REQUIREMENTS WITH UTILITY PRIOR TO STARTING ANY WORK.
  - APPROXIMATE LOCATION OF BUILDING COMMUNICATION BACKBOARD IN IT/COMM ROOM ON SECOND FLOOR, REFER TO SHEET E5.1 FOR REQUIREMENTS.
  - PROPOSED ROUTING OF COMMUNICATION CONDUITS, COORDINATE EXACT ROUTING AS REQUIRED, REFER TO SHEET E5.1 FOR REQUIREMENTS.
  - WIRE CIRCUIT INDICATED THRU LIGHTING CONTROL RELAY PANEL "RPSA". CIRCUIT CONTROLLED SEPARATELY FOR DUSK TO DAWN OPERATION.
  - WIRE CIRCUIT INDICATED, FOR SINGLE FIXTURE, THRU LIGHTING CONTROL RELAY PANEL "RPSA". CIRCUIT CONTROLLED SEPARATELY FOR DUSK TO DAWN OPERATION.
  - WIRE CIRCUIT THRU LIGHTING CONTROL RELAY PANEL "RPSA".
  - DISCONNECTING MEANS MOUNTED AT ROAD SIGNAGE. COORDINATE EXACT LOCATION AND REQUIREMENTS WITH SIGN INSTALLER PRIOR TO ROUGH IN AND CONNECT SIGN FOR OPERATION.
  - PROPOSED LOCATION OF CUSTOMER CAR CHARGING PEDESTAL PROVIDE ELECTRICAL AND COMMUNICATION CONDUIT STUB UPS FROM UNDER SLAB. COORDINATE FINAL LOCATION WITH SYSTEM INSTALLER PRIOR TO ROUGH IN. PROVIDE 1" COMMUNICATION CONDUIT WITH CABLING AND CONNECT CHARGER FOR OPERATION.
  - WALL PACK SHALL BE POWERED FROM CAR WASH BUILDING, UNDER SEPARATE PERMIT.
  - WIRE CIRCUIT INDICATED THRU LIGHTING CONTROL RELAY PANEL "RPOA". CIRCUIT CONTROLLED SEPARATELY FOR DUSK TO DAWN OPERATION.

1 SITE POWER PLAN  
1"=40'-0"

Order Plans @

WWW.DILine.com