

Order Plans

PLUMBING NOTES

- ALL WORKMANSHIP AND MATERIALS SHALL BE IN STRICT ACCORDANCE WITH THE INTERNATIONAL PLUMBING CODE (IPC) 2012 AS AMENDED BY THE STATE OF GEORGIA, APPLICABLE LOCAL CODES, RULES AND ORDINANCES.
- PLUMBING CONTRACTOR SHALL VISIT THE JOB SITE AND THOROUGHLY FAMILIARIZE HIMSELF WITH ALL EXISTING CONDITIONS.
- ALL MATERIALS SHALL BE NEW.
- ALL WORK SHALL BE PERFORMED BY A LICENSED PLUMBING CONTRACTOR IN A FIRST CLASS WORKMANLIKE MANNER. THE COMPLETED SYSTEM SHALL BE FULLY OPERATIVE. ALL EXCAVATION AND BACKFILL AS REQUIRED FOR THIS PHASE OF CONSTRUCTION SHALL BE A PART OF THIS CONTRACT.
- REQUIRED INSURANCE SHALL BE PROVIDED BY THE PLUMBING CONTRACTOR FOR PROTECTION AGAINST PUBLIC LIABILITY AND PROPERTY DAMAGE FOR THE DURATION OF THE WORK.
- PLUMBING CONTRACTOR SHALL SECURE AND PAY FOR ALL PERMITS, FEES, INSPECTION AND TESTS. PLUMBING CONTRACTOR TO OBTAIN PERMIT AND APPROVED SUBMITTALS PRIOR TO BEGINNING WORK OR ORDERING EQUIPMENT. PLUMBING CONTRACTOR MUST BE PRESENT FOR ALL INSPECTIONS OF HIS WORK BY REGULATORY AUTHORITIES.
- DRAWINGS ARE DIAGRAMMATIC. DO NOT SCALE FOR THE EXACT LOCATION OF FIXTURES, PIPING, EQUIPMENT, ETC.
- ALL WORK SHALL BE COORDINATED WITH OTHER TRADES TO AVOID INTERFERENCE WITH THE PROGRESS OF CONSTRUCTION. REPORT ANY DISCREPANCY TO ENGINEER/ARCHITECT PRIOR TO BEGINNING CONSTRUCTION.
- VERIFY LOCATION, SIZE, DIRECTION OF FLOW AND INVERTS OF ALL EXISTING UTILITIES PRIOR TO BEGINNING OF CONSTRUCTION. ADVISE ENGINEER OF ANY DISCREPANCIES.
- COORDINATE LOCATION OF ALL PIPING CONNECTIONS TO BUILDING WITH LOCAL UTILITY AND CIVIL ENGINEER. PROVIDE APPROVED BACKFLOW PREVENTION DEVICE, MAIN SHUT-OFF VALVE AND PRESSURE REDUCING VALVE AT WATER SERVICE.
- WATER DISTRIBUTION PIPING ABOVE AND BELOW GROUND SHALL BE TYPE "L" COPPER. COORDINATE WITH LOCAL JURISDICTION FOR ADDITIONAL REQUIREMENTS. PROVIDE ALTERNATE FOR CPVC PIPING EQUAL TO BFGOODRICH "FLOWGUARD GOLD."
- SANITARY, VENT, WATER AND CONDENSATE PIPING SHALL BE INSTALLED WITHIN WALL SYSTEM. NO EXPOSED VISIBLE PIPE SHALL BE ALLOWED. FOR CONCRETE MASONRY UNIT WALLS (CMU) THE PIPE SHALL BE INSTALLED WITHIN VERTICAL CELLS OF BLOCKS AND FOR PRE-ENGINEERED METAL BUILDING WALLS (PEMB) THE PIPE SHALL BE INSTALLED BEHIND WALL PANEL. PROVIDE PVC CONDUIT FOR WATER PIPING INSIDE WALL.
- SOIL, WASTE, VENT AND RAINWATER PIPING SHALL BE CAST IRON OR PVC, WHERE CODE ALLOWS. PVC MAY NOT BE USED THRU RATED ASSEMBLIES OR IN PLENUMS.
- ALL GAS PIPING SHALL BE SCHEDULE 40 BLACK STEEL, SCREW TYPE FOR PIPING 2 INCH AND SMALLER PER ASTM A-120, WELD TYPE FOR PIPING 2-1/2 INCH AND LARGER PER ASTM A-53. BURIED STEEL PIPE IN CONTACT WITH THE EARTH SHALL BE METALLIC ARC WELDED AND COATED WITH HIGH DENSITY "X-TRU-COAT" POLYETHYLENE AND WITH POLYETHYLENE TAPE COAT JOINTS. PROVIDE IDENTIFICATION ON GAS PIPING SYSTEM.
- ALL FIXTURES MUST BE PROVIDED WITH READILY ACCESSIBLE STOPS AND APPROPRIATELY MARKED ACCESS PANELS. COORDINATE LOCATIONS WITH GENERAL CONTRACTOR PRIOR TO INSTALLATION.
- FURNISH AND INSTALL APPROVED WATER HAMMER ARRESTORS FOR ALL (GROUP) PLUMBING FIXTURES, SIZED AND LOCATED PER MANUFACTURER'S INSTALLATION INSTRUCTIONS AND PDI-WH 201.
- DIELECTRIC COUPLINGS ARE REQUIRED BETWEEN ALL DISSIMILAR METAL IN PIPING AND EQUIPMENT CONNECTIONS.
- ISOLATE COPPER PIPING FROM HANGER OR SUPPORTS WITH ISOLATOR PADS OR MATERIAL.
- ALL FIRE RATED FLOOR AND WALL PENETRATIONS SHALL BE PROPERLY PROTECTED FROM FIRE, SMOKE AND WATER PENETRATION BY FILLING VOIDS BETWEEN PIPE AND WALL/FLOORS AS PART OF THE PLUMBER'S WORK.
- PLUMBING CONTRACTOR SHALL GUARANTEE ALL MATERIALS AND WORKMANSHIP FREE FROM DEFECTS FOR A PERIOD OF NOT LESS THAN ONE (1) YEAR FROM DATE OF ACCEPTANCE BY OWNER. CORRECTION OF ANY DEFECTS SHALL BE COMPLETED WITHOUT ADDITIONAL CHARGE AND SHALL INCLUDE REPLACEMENT OR REPAIR OF ANY OTHER PHASE OF THE INSTALLATION WHICH MAY HAVE BEEN DAMAGED.
- PROVIDE ACCESS PANELS FOR ALL CONCEALED VALVES AND ALL WATER HAMMER ARRESTORS. ACCESS PANELS IN RATED WALL MUST MAINTAIN THE SAME RATING AND MUST MATCH THE FINISH OF THE WALL IN WHICH IT IS INSTALLED.
- PROVIDE COMBINATION COVER PLATE AND CLEANOUT PLUG OR ACCESS PANEL FOR ALL WALL CLEANOUTS FINISH TO MATCH FIXTURE TRIM.
- NO COMBUSTIBLE MATERIAL TO BE USED IN MECHANICAL ROOMS OR IN CEILING SPACES WHERE USED AS RETURN AIR PLENUMS.
- NO WATER, SANITARY OR DRAINAGE PIPING PERMITTED IN ELECTRICAL OR ELEVATOR EQUIPMENT ROOMS.
- ALL CONTROL VALVES SHALL BE TAGGED AND MARKED. REPRODUCIBLE DIAGRAM LOCATING ALL VALVES SHALL BE PROVIDED FOR OPERATOR.
- ALL CONDENSATE DRAIN PIPES SHALL BE TYPE "L" COPPER WITH 1" ARMAFLEX INSULATION WHERE USED IN A RETURN AIR PLENUM. PVC PIPING WITH 1" ARMAFLEX INSULATION MAY BE USED IN LOCATIONS WHERE ALLOWED BY LOCAL CODES. SEE PLUMBING DRAWINGS FOR SIZE AND LOCATION OF PIPING.
- CONDENSATE LINES SHALL NOT DRAIN ON TO ROOFING SYSTEM OR ANY OF ITS COMPONENTS AND CONDENSATE LINES NEED NOT COMPLY WITH MIN. CLEARANCE REQUIREMENTS.
- PROVIDE ACCESS STOPS ON ALL WATER SERVICE LINES TO FIXTURES FOR INDIVIDUAL SHUT-OFF.
- WATER PIPING INSULATION SHALL BE ARMAFLEX OR EQUAL INSTALLED IN ACCORDANCE WITH MANUFACTURER'S INSTRUCTIONS FOR ALL HOT WATER PIPING. WHERE DOMESTIC WATER TEMPERATURES DO NOT CAUSE SWEATING ALL COLD WATER PIPING SHALL BE INSULATED WITH ARMAFLEX INSULATION, THICKNESS AS PER IECC 2012.
- FOR AUTOMATIC-CIRCULATING HOT WATER SYSTEM, HOT WATER PIPING SHALL BE INSULATED WITH 1" OF INSULATION PER IECC 2012.
- STUDOR MINI/MAXI AIR ADMITTANCE VALVES MAY BE USED AS AN ALTERNATE TO VENT PIPING THRU ROOF WHERE ACCEPTABLE BY THE PLUMBING OFFICIAL AND LOCAL CODES. INSTALLATION SHALL BE AS PER MANUFACTURER'S RECOMMENDATIONS.
- ALL HORIZONTAL RAINWATER PIPING THAT RECEIVES CONDENSATE DISCHARGE FROM AIR CONDITIONING EQUIPMENT SHALL BE INSULATED WITH 1" THICK INSULATION.

PLUMBING FIXTURE SCHEDULE

WC-1	WATER CLOSET - KOHLER #K-4408 "WELLWORTH" ELONGATED WITH TOP SPUD FAUCET - AMERICAN STANDARD #6065.121.002, EXPOSED BATTERY OPERATED, SENSOR OPERATED G2.
WC-2	WATER CLOSET - KOHLER #K-3998 "WELLWORTH" ELONGATED FLOOR MOUNTED, WHITE, 1.28 GPF. OPEN FRONT SEAT. 15" HEIGHT. FLUSH LEVER SHALL BE LOCATED ON SIDE OF TANK AWAY FROM ADJACENT WALL.
HWC-1	WATER CLOSET - KOHLER #K-4405 "HIGHLINE" ELONGATED WITH TOP SPUD FAUCET - AMERICAN STANDARD #6065.121.002, EXPOSED BATTERY OPERATED, SENSOR OPERATED G2. MUST MEET A.D.A. CODE. LOWER WATER SUPPLY ROUGH-IN TO 10" (254 MM) AND MOUNT GRAB BAR AT THE 36" (914MM) MAXIMUM ALLOWED HEIGHT.
HWC-2	WATER CLOSET - KOHLER #K-4405 "HIGHLINE" ELONGATED WITH TOP SPUD FAUCET - AMERICAN STANDARD #6065.121.002, EXPOSED BATTERY OPERATED, SENSOR OPERATED G2. MUST MEET A.D.A. CODE. LOWER WATER SUPPLY ROUGH-IN TO 10" (254 MM) AND MOUNT GRAB BAR AT THE 36" (914MM) MAXIMUM ALLOWED HEIGHT.
UR	URINAL - KOHLER #K-5016-ET "DEXTER" ELONGATED WITH 3/4" TOP SPUD FAUCET - AMERICAN STANDARD #6063.051.002, EXPOSED BATTERY OPERATED, SENSOR OPERATED G2
LAV	LAVATORY - KOHLER #K-2608-SU "BACHATA", UNDERMOUNT OVAL STAINLESS STEEL FAUCET - SLOAN EBF-85, 0.5 GPM, BATTERY POWERED SENSORY OPERATED FAUCET. PROVIDE WITH BELOW DECK MIXING VALVE.
HLAV-1	LAVATORY - KOHLER #K-2608-SU "BACHATA", UNDERMOUNT OVAL STAINLESS STEEL FAUCET - SLOAN EBF-85, 0.5 GPM, BATTERY POWERED SENSORY OPERATED FAUCET. PROVIDE WITH BELOW DECK MIXING VALVE.
HLAV-2	LAVATORY - KOHLER #K-2608-SU "BACHATA", UNDERMOUNT OVAL STAINLESS STEEL FAUCET - SLOAN EBF-85, 0.5 GPM, BATTERY POWERED SENSORY OPERATED FAUCET. PROVIDE WITH BELOW DECK MIXING VALVE.
MS	MOP SINK - FIAT #MSB2424, 24x24x10 MOLDED STONE MOP SINK FAUCET - T&S B-0655-BSTR, SERVICE SINK FAUCET
SK-1	BAR SINK, STAINLESS STEEL, 18 x 16 JUST MANUFACTURING USN-ADA-1816-A. FAUCET, DELTA 1158LF, SINGLE HOLE KITCHEN FAUCET WITH LEVER HANDLE, 1.8 GPM. MUST MEET ADA
SK-2	SINK - ELKAY B0R15-2, CELEBRITY SINGLE BOWL SINK 15x15x6 DEEP FAUCET - ZURN Z812B4, CENTERSET FAUCET WITH 5-3/8" GOOSENECK SPOUT AND 4" WRIST BL.
SK-3	SINK - ELKAY B0R15-2, CELEBRITY SINGLE BOWL SINK 15x15x6 DEEP FAUCET - ZURN Z812B4, CENTERSET FAUCET WITH 5-3/8" GOOSENECK SPOUT AND 4" WRIST BL.
SK-4	SINGLE STAINLESS STEEL SINK, 23 X 19 ELKAY MODEL ESSW2319 FAUCET ELKAY LK940C, BUCKET HOOK FAUCET, 4 GPM, ROUGH CHROME FINISH, 1/2" NPT
FD-1	5"x5" SQUARE GRATE FLOOR DRAIN, WADE MODEL #110305-TY. FINAL FINISH TO BE COORDINATED WITH ARCHITECT.
FD-2	8"x8" SQUARE GRATE FLOOR DRAIN, WADE MODEL #110468. PROVIDE WITH SEDIMENT BUCKET AND TRAP PRIMER. FINAL FINISH TO BE COORDINATED WITH ARCHITECT.
FD-3	AREA DRAIN - ZURN Z862, 16" SQUARE TOP DRAIN, CAST IRON BODY. FINAL FINISH TO BE COORDINATED WITH ARCHITECT.
FD-4	8" ROUND GRATE FLOOR DRAIN, WADE MODEL #110305-TY. PROVIDE WITH TRAP PRIMER. FINAL FINISH TO BE COORDINATED WITH ARCHITECT.
THLAV	LAVATORY - KOHLER #K-2005 "KINGSTON" WALL MOUNTED FAUCET - DELTA 1158LF, SINGLE LEVER FAUCET. PROVIDE WITH BELOW DECK MIXING VALVE.
THWC	WATER CLOSET - KOHLER #K-9507-0 "HIGHCLIFF" ELONGATED WITH TOP SPUD FAUCET - SLOAN #111-1.28 XL, REGAL FLUSH VALVE
TWC	WATER CLOSET - KOHLER #K-9883-0 "WELLCOMM" ELONGATED WITH TOP SPUD FAUCET - SLOAN #111-1.28 XL, REGAL FLUSH VALVE
TUR	URINAL - KOHLER #K-5016-ET "DEXTER" ELONGATED WITH TOP SPUD FAUCET - SLOAN #186-1-XL, REGAL FLUSH VALVE
HYD	WALL MOUNTED TO BE HANGERS MODEL B85 WITH BOX, 3/4" STRAIGHT INLET CONNECTION, ANGLE SIFON, FREEZELESS.
HB	THREE BIBB TO BE HANGERS MODEL B85 WITH BOX, 3/4" STRAIGHT INLET CONNECTION, ANGLE SIFON.
WF	WALL FOUNTAIN - BRADLEY #W2803, 36" SEMI-CIRCULAR BRADSTONE, 3 USERS. INFRARED ACTIVATION, 120V. PROVIDE WITH THERMOSTATIC MIXING VALVE.
EYE	PEDestal MOUNTED EYE WASH BRADLEY MODEL S19-214CW. PROVIDE FLOW CONTROL. (SET TO 1.0 GPM) AND MIXING VALVE BRADLEY S19-2000.
HD	HAND SOAP DRINKING FOUNTAIN, SUNROC MODEL ADAAC, WALL MOUNTED BARRIER FREE. WALL #20AM11-M36 CARRIER AS REQUIRED. MUST MEET A.D.A. CODE.
HD	HAND SOAP DRINKING FOUNTAIN, OASIS MODEL MMRSL BI-LEVEL, WALL MOUNTED, BARRIER FREE. INSTALL REMOTE CHILLER ABOVE CEILING OASIS MODEL RB, 115V, 4.6A. CARRIER AS REQUIRED. MUST MEET A.D.A. CODE.
RD-1	ROOF DRAIN: WADE 3000-SD-52-53. AE EXTENSION AS REQUIRED.
RD-2	LOW PROFILE ROOF DRAIN: WADE 3240-48
ORD-1	OVERFLOW ROOF DRAIN: WADE 3000-SD-52-53. 2" AE EXTENSION AS REQUIRED.
ORD-2	LOW PROFILE OVERFLOW ROOF DRAIN: WADE 33240-48
EW-1	WATER HEATER - AOSMITH EUCS-20. 20 GALLON, 120v, 1#, 2.5 KW.
EW-2,3	WATER HEATER - AOSMITH EUC-10. 10 GALLON, 120v, 1#, 1.65 KW.
IWH-1	TANKLESS WATER HEATER SHALL BE EEMAX LAVADVANTAGE. POINT-OF-USE MICROPROCESSOR TEMPERATURE CONTROL. NO MIXING VALVE REQUIRED. MODEL SPEX607, 277V, 1#, 22A, 6.0KW, 0.2 GPM ACTIVATION.
IWH-2	TANKLESS WATER HEATER SHALL BE EEMAX LAVADVANTAGE. POINT-OF-USE MICROPROCESSOR TEMPERATURE CONTROL. NO MIXING VALVE REQUIRED. MODEL SPEX4208T ML, 208V, 1#, 20A, 4.1KW, 0.2 GPM ACTIVATION.
IWH-3	TANKLESS WATER HEATER SHALL BE EEMAX LAVADVANTAGE. POINT-OF-USE MICROPROCESSOR TEMPERATURE CONTROL. NO MIXING VALVE REQUIRED. MODEL SPEX3208T, 208V, 1#, 15A, 3.0KW, 0.2 GPM ACTIVATION.
RP-1,2	TACO RECIRC. PUMP. MODEL 0011 BRONZE CASTING 3/4" , 115V, 1/7 HP, 16AMP WITH "00" TIMER AQUSTAT.
P-1	ELEVATOR SUMP PUMP - ZOELLER 940-0007, OIL GUARD SUMP PUMP, 0.5HP/1N153

GENERAL NOTES:

- FIXTURES SHALL BE AS SHOWN OR EQUAL.
 - ALL FIXTURES SHALL COMPLY WITH TABLE 604.3, 604.4 AND 604.5 OF IPC 2012.
 - ALL FIXTURE TRIM PACKAGES INCLUDING BUT NOT LIMITED TO TRAP, ANGLE STOP, FLUSH VALVE, SUPPLY TUBES, AND CLEANOUT COVER PLATES SHALL BE OF THE SAME FINISH AS THE ABOVE SPECIFIED FAUCET AND PER ARCHITECTURAL FINISH SCHEDULE.
 - ALL FIXTURES SHALL BE ROUGHED IN PER MANUFACTURER CUT SHEET TO MAINTAIN UNIFORMITY.
 - THERMOSTATIC MIXING VALVE SHALL BE PROVIDED FOR ALL LAVATORIES WITH HOT WATER DELIVERY SET TO 110F. A SINGLE MIXING VALVE SHALL BE ACCEPTABLE FOR INSTALLATIONS WITH MULTIPLE LAVATORIES IN SAME LOCATION. MIXING VALVE SHALL COMPLY WITH ASSE 1070.
- WATER HEATER NOTES:
- PROVIDE WITH VACUUM RELIEF VALVE
 - PROVIDE WITH EXPANSION TANK (MINIMUM ACCEPTANCE VOLUME OF 2 GALLONS)
 - PROVIDE WITH DRAIN PAN.
 - ROUTE DRAIN TO NEAREST FLOOR DRAIN
 - SET TANK STORAGE TEMPERATURE TO 130F
 - PROVIDE WITH MIXING VALVE TO REDUCE TEMPERATURE TO 120F
 - PROVIDE WITH HOT WATER RE-CIRCULATOR PUMP FOR INSTALLATIONS WHERE THE HOT WATER PIPING EXCEEDS 50 FEET.

PLUMBING SHEET INDEX

SHEET#	DESCRIPTION
P0.1	PLUMBING NOTES
P0.2	PLUMBING DETAILS
P2.1	FIRST FLOOR SANITARY PLAN
P2.2	SECOND FLOOR PLUMBING PLANS
P2.3	ROOF PLUMBING PLAN
P3.1	FIRST FLOOR DOMESTIC WATER PLAN
P5.1	PLUMBING ISOMETRICS
P8.1	DOMESTIC WATER RISER

PLUMBING LEGEND

SYMBOL	DESCRIPTION	SYMBOL	DESCRIPTION
AAV	AIR ADMITTANCE VALVE	—S—S	SANITARY SEWER PIPING
AFV	ABOVE FINISH VALVE	—V—V	VENT PIPING
CO	CLEAN OUT	—C—C	DOMESTIC COLD WATER PIPING
CW	DOMESTIC COLD WATER	—C—C	HOT WATER PIPING (110°)
HW	DOMESTIC HOT WATER	—H—H	HOT WATER RECIRCULATING PIPING
HW	DOMESTIC HOT WATER	—CD—CD	CONDENSATE PIPING
HW	DOMESTIC HOT WATER	—SD—SD	STORM DRAIN PIPING
HW	DOMESTIC HOT WATER	—OD—OD	OVERFLOW STORM DRAIN LINE
TR	TRAP	—G—G	GAS PIPING
DR	DRAIN	—	CLEAN OUT
CV	CHECK VALVE	—	P-TRAP
GV	GATE VALVE	—	CAPPED END OF PIPE
GC	GAS COCK	—	PIPE RISE UP
PC	POINT OF CONNECTION	—	PIPE DOWN OR DROP
GR	GAS PRESSURE REGULATOR	—	DOWNSPOUT COVER

SLOPE OF HORIZ. DRAINAGE PIPE

SIZE (inches)	MINIMUM SLOPE (Inch per foot)
2-1/2 or less	1/4
3 to 6	1/8
8 or larger	1/16

SHOCK ARRESTOR SCHEDULE

PDI DESIGNATION	SHOCK ARRESTOR MODEL	FIXTURE UNITS	CONNECTION
A	852-A	1-11	1/2"
B	653-B	12-32	3/4"
C	654-C	33-60	1"

TABLE 704.1 OF THE IPC 2012

SHOCK ARRESTOR APPROVED FOR INSTALLATION WITH NO ACCESS DOOR REQUIRED. CONFORMS TO ANSI/ASSE 1010 STANDARDS.

PLUMBING SYSTEMS MATERIAL SCHEDULE


SYSTEM	LINE TYPE	LOCATION	MATERIAL	INSULATION
SANITARY	—	ABOVE AND UNDERGROUND	PVC	NONE
SAN. VENT	—V—	ABOVE GROUND	PVC	NONE
COLD WATER	—C—	ABOVE AND UNDERGROUND	TYPE "L" COPPER	—
HOT WATER	—H—	ABOVE AND UNDERGROUND	TYPE "L" COPPER	1" ARMAFLEX
STORM	—SD—	ABOVE AND UNDERGROUND	PVC	NONE
OVER. STORM	—OD—	ABOVE AND UNDERGROUND	PVC	NONE
GAS	—G—	ABOVE AND UNDERGROUND	BLACK STEEL SCH.40	NONE
CONDENSATE	—CD—	ABOVE AND UNDERGROUND	PVC	1" ARMAFLEX

SUBMITTALS AND SHOP DRAWINGS REQUIREMENTS

- THE CONTRACTOR SHALL PROVIDE SUBMITTALS AND SHOP DRAWINGS FOR APPROVAL AND ASSEMBLE INTO ELECTRONIC (PDF) PACKAGES PER SCHEDULE BELOW. INDIVIDUAL SUBMITTALS NOT ORGANIZED PER PACKAGES SHALL RESULT IN REJECTION OF SUBMITTAL.
- COORDINATE WITH GENERAL PROJECT TERMS AND CONDITIONS FOR SUBMITTING PROCEDURES AND PROCESS.
- CONTRACTOR SHALL REVIEW EACH SUBMITTAL AND CHECK FOR COORDINATION WITH OTHER WORK OF THE CONTRACT AND FOR COMPLIANCE WITH THE CONTRACT DOCUMENTS. MARK WITH APPROVAL STAMP BEFORE SUBMITTING TO ARCHITECT. FAILURE TO COMPLY WITH REQUIREMENTS IDENTIFIED HEREIN SHALL RESULT IN REJECTION OF SUBMITTAL.
- SUBMITTAL PACKAGES
 - PACKAGE 1 - PLUMBING FIXTURES
 - PACKAGE 2 - PLUMBING EQUIPMENT
 - PACKAGE 3 - PLUMBING PIPING AND ACCESSORIES
- ALL FIXTURES AND EQUIPMENT SHALL BE ORGANIZED AND CLEARLY MARKED WITH TAGS MATCHING CONSTRUCTION DOCUMENTS.
- MARK EACH SUBMITTAL TO SHOW WHICH PRODUCTS AND OPTIONS ARE APPLICABLE AND INCLUDE THE FOLLOWING INFORMATION AS APPLICABLE: MANUFACTURER'S CATALOG CUTS AND MANUFACTURER'S PRODUCT SPECIFICATIONS. GENERIC PRODUCT DATA SHALL NOT BE ACCEPTABLE.
- IDENTIFY DEVIATIONS FROM THE CONTRACT DOCUMENTS ON SUBMITTALS. ANY COSTS INCURRED BY THE ENGINEER FOR DEVIATIONS REQUIRING REDESIGN OR EXTENSIVE REVIEW SHALL BE PAID BY CONTRACTOR.



ELLSWORTH ARCHITECTS
3136 LANIER DRIVE
ATLANTA, GEORGIA 303419
PHONE: 404.949.9351



PRO BUILDING SYSTEMS
DESIGN BUILD CONTRACTORS

3878 North Peachtree Road
Atlanta, Georgia 30341
(770) 455-1791 / Fax 455-4123
www.probdgsystems.com

GINN CHRYSLER - DODGE - RAM AND JEEP
1-20 ACCESS ROAD
COVINGTON GEORGIA 30040

DATE: 11.06.2018
SCALE: AS SHOWN
BY: GD
JOB ID:

PLUMBING NOTES
DRAWING TITLE

P0.1

SHEET 1 OF 8

PROMUS
SCOTT MERIWETHER, P.E.
GEORGIA LICENSE #30780
518 BLACK CANYON PARK
CANTON, GA 30114
PROJECT MANAGER: GEORGE DAVIDOV
PHONE 678.246.5146