Store No.: GA483
KMA: ATLANTA

DESIGN AMBIENT: 95 **ALTITUDE:** 968'
VOLTAGE: 460V / 3PH

	DATE	F1 DATE
BY: KDG	12/14/18	11/8/18
REV. 1: KDG	2/20/19	2/14/18

RACK	CKT	L	W	H	CASE/COIL MODEL	DESCRIPTION	DEPT	STAT	ePRO ITEM	EVAP TEMP	LOAD (MBH)	CON-TROL	DEFROST #/DAY	DEFROST TYPE	REFRIG	TOTAL LOAD	PARALLEL RACK INFORMATION COMPRESSOR	HP	SUCT TEMP	CAPACITY	THR	PERCENT LOADED
A	1	32	20	10	EXIST COIL(S)	FREEZER	GROC.	EX.		-22	42.7				R404A		EXISTING PARALLEL RACK					
	2	13	18	10	EXIST COIL(S)	FREEZER	BAK.	EX.		-22	20.0						Reclaim: Water					
	3	8	8	10	EXIST COIL(S)	FREEZER	SEAF.	EX.		-22	8.2						Controller: CPC Einstein II RX-400					
	4	26	DRS		RL(IC)	G.D.(ICE CREAM)	GROC.	EX.		-19	42.9		1	EL/TEMP			Control Voltage: Unknown					
	5	16	DRS		RLN(IC)	G.D.(ICE CREAM)	GROC.	EX.		-19	21.9		1	EL/TEMP			Control Valve Voltage: Unknown					
		4	DRS		RLN(IC)	G.D.(ICE CREAM)	BAK.	EX.		-19	5.5		1	EL/TEMP			Compressor Voltage: 460V					
	6	**2**	**QTY**		**RLN(IC-E-LED2)-3**	**3 DOOR G.D., ICE CREAM TEMP, NARROW**	**DELI.**	**NEW**		**-19**	**6.4**	**(S)ORIT**	**1**	**EL/TEMP**			Modify existing parallel rack electric as required to accomplish remodel					
	7	**2**	**QTY**		**FN(LT-E)-12**	**12' NARROW ISLAND, LOW TEMP**	**GROC.**	**NEW**		**-20**	**9.1**	**EVR**	**1**	**EL/TEMP**								
		1	**QTY**		**FN(LT-E)-8**	**8' NARROW ISLAND, LOW TEMP**	**GROC.**	**NEW**		**-20**	**3.0**		**1**	**EL/TEMP**								
	8	**2**	**QTY**		**FN(LT-E)-12**	**12' NARROW ISLAND, LOW TEMP**	**GROC.**	**NEW**		**-20**	**9.1**	**EVR**	**1**	**EL/TEMP**								
		1	**QTY**		**FN(LT-E)-8**	**8' NARROW ISLAND, LOW TEMP**	**GROC.**	**NEW**		**-20**	**3.0**		**1**	**EL/TEMP**								
	9	**2**	**QTY**		**FN(LT-E)-12**	**12' NARROW ISLAND, LOW TEMP**	**GROC.**	**NEW**		**-20**	**9.1**	**EVR**	**1**	**EL/TEMP**			3DS		-25		78.2	
		1	**QTY**		**FN(LT-E)-8**	**8' NARROW ISLAND, LOW TEMP**	**GROC.**	**NEW**		**-20**	**3.0**		**1**	**EL/TEMP**			3DS		-25		78.2	
	41	12	FT		C3BFSS	SELF SERVICE FROZEN	BAK.	EX.		-20	7.8		2	EL/TIME			4DL		-25		69.1	
	42	4	QTY		FWG(DT-E)-8	8' WIDE ISLAND, DUAL TEMP, W/G	MEAT	EX.		-20	19.1		1	EL/TEMP			4DT				83.9	130.0
		2	QTY		FWEG(DT-E)	WIDE ISLAND END, DUAL TEMP, W/G	MEAT	EX.		-20	5.0		1	EL/TEMP								
																216.2					394.4	85.5%
																	EXISTING Air Cooled Condenser					
																	BOHN BRH-0[illegible] 9.04 mbh/deg td capac[illegible]42 circu[illegible]9.7 TD					
B	10	2	QTY		RL(LT-E)-5	5 DOOR G.D., LOW TEMP	GROC.	EX.		-11	11.9		1	EL/TEMP	R404A		EXISTING PARALLEL RACK					
		1	QTY		RL(LT-E)-3	3 DOOR G.D., LOW TEMP	GROC.	EX.		-11	3.6		1	EL/TEMP			Reclaim: Water					
	11	3	QTY		RL(LT-E)-5	5 DOOR G.D., LOW TEMP	GROC.	EX.		-11	17.9		1	EL/TEMP			Controller: CPC Einstein II RX-400					
	12	2	QTY		RL(LT-E)-5	5 DOOR G.D., LOW TEMP	GROC.	EX.		-11	11.9		1	EL/TEMP			Control Voltage: Unknown					
	13	3	QTY		RL(LT-E)-5	5 DOOR G.D., LOW TEMP	GROC.	EX.		-11	17.9		1	EL/TEMP			Control Valve Voltage: Unknown					
	14	3	QTY		RL(LT-E)-5	5 DOOR G.D., LOW TEMP	GROC.	EX.		-11	17.9		1	EL/TEMP			Compressor Voltage: 460V					
	15				SPARE												Modify existing parallel rack electric as required to accomplish remodel					
	43	1	QTY		RL(LT-E)-4	4 DOOR G.D., LOW TEMP	GROC.	EX.		-11	4.8		1	EL/TEMP								
		1	QTY		RL(LT-E)-3	3 DOOR G.D., LOW TEMP	GROC.	EX.		-11	3.6		1	EL/TEMP			2D		-14	37.1	54.8	
		1	QTY		DAF3R	THREE DR. FREEZER	DELI.	EX.		-10	5.6						3D		-14	48.4	72.0	
	44	2	QTY		RLN(LT-E-LED2)-5	5 DOOR G.D., LOW TEMP, NARROW	GROC.	EX.		-11	9.6		1	EL/TEMP			5DB		-14	59.2	88.0	
		2	QTY		RLN(LT-E-LED2)-2	2 DOOR G.D., LOW TEMP, NARROW	GROC.	EX.		-11	3.8		1	EL/TEMP								
																100.3				144.7	214.8	74.9%
																	EXISTING Air Cooled Condenser					
																	BOHN BRH-054, 26.04 mbh/deg td capacity, 28 circuits, 8.0 TD					
C	16	2	QTY		M5XEP(LED)-12	12' FIVE DECK	MEAT	EX.		-26	3[illegible]		4	OT/TIME	R404A		EXISTING PARALLEL RACK					
		1	QTY		M5XEP(LED)-8	8' FIVE DECK	MEAT	EX.		-26	1[illegible]		4	OT/TIME			Reclaim: Air					
	17	2	QTY		M5XEP(LED)-12	12' FIVE DECK	MEAT	EX.		-26	3[illegible]		4	OT/TIME			Controller: CPC Einstein II RX-400					
		1	QTY		M5XEP(LED)-6	6' FIVE DECK	SEAF.	EX.		-26			4	OT/TIME			Control Voltage: Unknown					
	18	3	QTY		ORB(MEAT-LED)-6	12 FT, 6 DR GLASS DOOR MEAT, 24" FRENCH DOOR	MEAT	EX.		-28			4	OT/TEMP			Control Valve Voltage: Unknown					
		2	QTY		ORB(MEAT-LED)-4	8 FT, 4 DR GLASS DOOR MEAT, 24" FRENCH DOOR	MEAT	EX.		-28	4.1		4	OT/TEMP			Compressor Voltage: 460V					
	19	2	QTY		D5XEP-8	8' FIVE DECK	DELI.	EX.		-26	19.3		3	OT/TIME			Modify existing parallel rack electric as required to accomplish remodel					
	20	**1**	**QTY**		**ESBDS-12**	**12' SERVICE**	**DELI.**	**REL.**		**-20**	**4.3**		**2**	**OT/TEMP**								
		1	**QTY**		**ESBDS-8**	**8' SERVICE**	**DELI.**	**REL.**		**-20**	**2.8**		**2**	**OT/TEMP**			2DA		17	85.3	111.1	
	21	**5**	**FT**		**C3BRFS**	**SERVICE**	**BAK.**	**EX.**		**-20**	**2.3**		**4**	**OT/TIME**			3DA		17	85.3	111.1	
		5	**FT**		**C3BRSS**	**SELF SERVICE**	**BAK.**	**EX.**		**-20**	**3.3**		**4**	**OT/TIME**			3DB		17	101.2	132.4	
	22	2	QTY		FWG(MT-E)-8	8' WIDE ISLAND, MED TEMP, W/G	MEAT	EX.		-19	6.6		1	EL/TEMP			3DF		17	125.6	165.1	
		2	QTY		FWEG(MT-E)	WIDE ISLAND END , MED TEMP, W/G	MEAT	EX.		-19	3.1		1	EL/TEMP			3DF		17	125.6	165.1	
	23	1	QTY		DSFM-12	12' SERVICE	SEAF.	EX.		-24	3.6		3	OT/TIME			3DS		17	139.1	182.8	
	24	18	30	10	EXIST COIL(S)	COOLER	MEAT	EX.		-20	30.6						3DS		17	139.1	182.8	
	25	**3**	**QTY**		**O5DMM-12**	**12' MULTIDECK W/ SYNERG-E COIL - 84" HIGH**	**PROD.**	**REL.**		**-28**	**49.5**		**6**	**OT/TEMP**								
	26	3	QTY		ORBH(PROD-LED)-6	12 FT, 6 DR GLASS DOOR PRODUCE, 24" FRENCH DOOR	PROD.	EX.		-32	7.7		4	OT/TEMP		527.4					801.2	954.7	65.8%
	27	**3**	**QTY**		**D5LE-12**	**12' FIVE DECK, LOW FRONT**	**BEV.**	**EX.**		**-24**	**51.2**		**4**	**OT/TEMP**								
		3	**QTY**		**D5LE-12**	**12' FIVE DECK, LOW FRONT**	**BEV.**	**REL.**		**-24**	**51.2**		**4**	**OT/TEMP**								
	28	46	18	10	EXIST COIL(S)	COOLER W/(20) DOORS	DAIRY	EX.		-26	62.7						EXISTING Air Cooled Condenser					
	29	16	32	10	EXIST COIL(S)	COOLER	PROD.	EX.		-26	30.8						BOHN BRH-132, 64.65 mbh/deg td capacity, 56 circuits, 14.8 TD					
	45	1	QTY		S2SGC-12	SERVICE SINGLE DECK GLYCOL CHILLER	MEAT	EX.		-20	4.7		1	OT/TEMP								
	46	2	QTY		D5NXLEP-8	8' FIVE DECK, LOW FRONT, NARROW	DELI.	EX.		-26	21.8		3	OT/TIME								
	47	**2**	**QTY**		**FW(MT-E)-12**	**12' WIDE ISLAND, MED TEMP**	**DAIRY**	**NEW**		**-19**	**9.7**	**EVR**	**1**	**EL/TEMP**								
		4	**QTY**		**FWE(MT-E)**	**WIDE ISLAND END , MED TEMP**	**DAIRY**	**NEW**		**-19**	**5.3**		**1**	**EL/TEMP**								
NEW	**49**	**1**	**QTY**		**IM-04-C8-R(DELI)**	**8' UNITIZED MULTI DECK ISLAND**	**DELI.**	**NEW**		**-28**	**11.0**	**(S)ORIT**	**6**	**OT/TIME**								
		2	**QTY**		**IM-04-E5(DELI)**	**MULTI-DECK SELF SERVICE END**	**DELI.**	**NEW**		**-28**	**6.9**		**6**	**OT/TIME**								
NEW	**50**	**1**	**QTY**		**IM-04-R-4 (MT)**	**4 FT. MULTI DECK ISLAND**	**DELI.**	**NEW**		**-25**	**3.2**	**EVR**	**6**	**OT/TIME**								
		1	**QTY**		**Q3-SS-6**	**6' SELF SERVICE MEAL SOLUTIONS**	**DELI**	**NEW**		**-20**	**5.4**	**EVR**	**4**	**OT/TIME**								
		1	**QTY**		**Q3-SS-4**	**4' SELF SERVICE MULTI DECK**	**DELI**	**NEW**		**-20**	**3.4**		**4**	**OT/TIME**								
NEW	**51**	**2**	**QTY**		**D5XLP-12**	**12' FIVE DECK WITH DOORS**	**BEV.**	**NEW**		**-32**	**4.3**	**(S)ORIT**	**1**	**OT/TIME**								
NEW	**52**	**5**	**QTY**		**D5XLP-12**	**12' FIVE DECK WITH DOORS**	**DAIRY**	**NEW**		**-32**	**16.3**	**(S)ORIT**	**1**	**OT/TIME**								
NEW	**53**	**2**	**QTY**		**DD5XLP-12**	**12' FIVE DECK WITH DOORS**	**DAIRY**	**NEW**		**-32**	**6.5**	**(S)ORIT**	**1**	**OT/TIME**								
		1	**QTY**		**DD5XLP-8**	**8' FIVE DECK WITH DOORS**	**DAIRY**	**NEW**		**-32**	**2.2**		**1**	**OT/TIME**								
PREP	1	417	14	FT	EXIST COIL(S)	PREP	MEAT	EX.		35	20.9				R404A		EXISTING PARALLEL RACK					
	31	454	14	FT	EXIST COIL(S)	PREP	PROD	EX.		35	16.2						Reclaim: Air					
	32	1	QTY		D5LE-12	12' FIVE DECK, LOW FRONT	DAIRY	EX.		24	68.2		4	OT/TEMP			Controller: CPC Einstein II RX-400					
	33	1	QTY		D5LE-12	12' FIVE DECK, LOW FRONT	DAIRY	EX.		24	51.2		4	OT/TEMP			Control Voltage: Unknown					
	34	3	QTY		D5LE-12	12' FIVE DECK, LOW FRONT	DAIRY	EX.		24	51.2		4	OT/TEMP			Control Valve Voltage: Unknown					
	35	8	8	10	EXIST COIL(S)	COOLER	SEAF.	EX.		23	6.9						Compressor Voltage: 460V					
	36	**1**	**QTY**		**ORBH(PROD-LED)-6**	**12 FT, 6 DR GLASS DOOR PRODUCE, 24" FRENCH DOOR**	**PROD.**	**EX.**		**32**	**2.6**		**4**	**OT/TEMP**								
		2	**QTY**		**ORBH(PROD-LED)-4**	**8 FT, 4 DR GLASS DOOR PRODUCE, 24" FRENCH DOOR**	**PROD.**	**EX.**		**32**	**3.4**		**4**	**OT/TEMP**								
		1	**QTY**		**ORBH(PROD-LED)-4**	**8 FT, 4 DR GLASS DOOR PRODUCE, 24" FRENCH DOOR**	**PROD.**	**REL.**		**32**	**1.7**		**4**	**OT/TEMP**			3DB		21	110.3	142.3	
	37	**1**	**QTY**		**D5LE-8**	**8' FIVE DECK, LOW FRONT**	**BEV.**	**REL.**		**24**	**11.4**		**4**	**OT/TEMP**			3DS		21	137.1	177.6	
		1	**QTY**		**D5LE-8**	**8' FIVE DECK, LOW FRONT**	**BEV.**	**EX.**		**24**	**11.4**		**4**	**OT/TEMP**			3DF		21	151.8	196.6	
	38	3	QTY		FL5NX-LEP-8	8' MULTI DECK, LOW FRONT, NARROW	FLOR.	EX.		28	31.8		3	OT/TIME			4DH (ABANDON)					
	39	8	16	10	EXIST COIL(S)	COOLER	FLOR.	EX.		29	11.4											
	40	8	10	10	EXIST COIL(S)	RETARDER	BAK.	EX.		26	8.1											
		8	10	10	EXIST COIL(S)	COOLER	DELI.	EX.		26	8.1											
	48	26	9	10	EXIST COIL(S)	COOLER	DELI.	EX.		26	18.1					322.4				399.2	516.5	80.7%
																	EXISTING Air Cooled Condenser					
																	BOHN BRH-096, 48.48 mbh/deg td capacity, 56 circuits, 10.0 TD Setpoint					

SYS	L	W	H	CASE/COIL MODEL	DESCRIPTION	DEPT	STAT	ePRO ITEM	EVAP TEMP	LOAD (MBH)	CON-TROL	DEFROST #/DAY	DEFROST TYPE	REFRIG	TOTAL LOAD	CONDENSING UNIT INFORMATION COND UNIT MODEL	COMP BODY	HP	SUCT TEMP	CAPACITY	PERCENT LOADED	RECLAIM CIRCUIT
RT-5	2	QTY		FWG(LT-E)-8	8' WIDE ISLAND, LOW TEMP, W/G	MEAT	EX.		-20	10.0		1	EL/TEMP	HP80	30.4	HOCA0934PL	3DF3-0900-TFC		-23	42.3	71.9%	
	2	QTY		FWEG(LT-E)	WIDE ISLAND END, LOW TEMP, W/G	MEAT	EX.		-20	5.2		1	EL/TEMP			EXISTING CONDENSING UNIT REAPPLIED						
	2	QTY		FWG(LT-E)-8	8' WIDE ISLAND, LOW TEMP, W/G	SEAF.	EX.		-20	10.0		1	EL/TEMP									
	2	QTY		FWEG(LT-E)	WIDE ISLAND END, LOW TEMP, W/G	SEAF.	EX.		-20	5.2		1	EL/TEMP									

Order Plans @ WWW.LDLine.com

D&E DOLLAR & EWERS ARCHITECTURE, INC.
[illegible] Avenue ♦ [illegible] 37915
[illegible] 865.546[illegible] ♦ fax: 865.673.9028
e[illegible] dollar-ewers.com

STATE OF GEORGIA — DAVID KENT EWERS — REGISTERED ARCHITECT

NO	REVISIONS

A With-in-the-Walls Remodel for:
KROGER STORE #GA-483 SNELLVILLE
1670 STATE HWY 124, SUITE 'F', SNELLVILLE, GEORGIA 30078

REFRIGERATION EQUIPMENT SCHEDULES

COPYRIGHT
ALL DRAWINGS, SPECIFICATIONS AND COPIES THEREOF FURNISHED BY DOLLAR & EWERS ARCHITECTURE, INC. ARE AND SHALL REMAIN THE PROPERTY OF THE ARCHITECT AND TO BE USED ONLY WITH RESPECT TO THE PROJECT. THEY ARE TO BE USED ONLY WITH RESPECT TO THE PROJECT AND ARE NOT TO BE USED WITH ANY OTHER PROJECT AND WITH THE EXCEPTION OF ONE CONTRACT SET FOR EACH PARTY TO THE CONSTRUCTION CONTRACT ARE TO BE RETURNED OR SUITABLY ACCOUNTED FOR TO DEA, INC. ON REQUEST AT THE COMPLETION OF THE PROJECT. ELECTRONIC DISTRIBUTION TO MEET LOCAL AHJ SUBMITTAL REQUIREMENTS OR FOR OTHER PURPOSES IN CONNECTION WITH THE PROJECT DOES NOT CONSTITUTE PUBLICATION IN DEROGATION OF DEA'S COMMON LAW COPYRIGHT OR OTHER RESERVED RIGHTS.
COPYRIGHT

ISSUE DATE: MARCH 04, 2019
PROJECT NO.: 219206
SHEET NUMBER: **R6.1**