

PARTIAL FEEDER DIAGRAM
NO SCALE:



PARTIAL FEEDER DIAGRAM
NO SCALE:

PANEL "LD" — DELI/BAKERY — 225 MAIN BREAKER

120/208 VOLTS, 3-PHASE, 4-WIRE, WYE CONNECTED. ___ LUG / WIRE. DRAWG NO

POLE NO.	BKR NO.	TRIP AMP.	POLE	HARE AMPS.	COND SIZE	SERVES	A-PH.	LOAD V. A. B-PH.	C-PH.	POLE NO.	BKR NO.	TRIP AMP.	POLE	HARE AMPS.	COND SIZE	SERVES
1	1	20	1	#0	3/4"	SUSH CASES	1200			2	2	20	1	#0	3/4"	SUSH PLUGS
3	3	20	1	#0	3/4"	SUSH CASES		1200		4	4	20	1	#0	3/4"	SUSH PLUGS
5	5	20	1	#0	3/4"	SUSH CASES			1200	6	6	20	1	#0	3/4"	SUSH PLUGS
7	7	20	1	#0	3/4"	SUSH CASES	1200			8	8	20	1	#0	3/4"	SUSH PLUGS
9	9	20	1	#0	3/4"	SUSH CASES		1200		10	10	20	1	#0	3/4"	PLUG - GP-2
11	11	20	1	—	—	SPARE			1200	12	12	20	1	#0	3/4"	SUSH PLUGS
13	13	20	1	—	—	SPARE				14	14	20	1	#0	3/4"	PLUGS - DROP CORD
15	15	30	2	#8	3/4"	SUSH CASE	1200			16	16	20	1	#0	3/4"	PLUGS - DROP CORD
17	17					"GFCI" BREAKER		1200		18	18	20	1	#0	3/4"	FLY GRID
19	19	30	2	#8	3/4"	SUSH CASE	1200			20	20	20	1	#0	3/4"	VEAPOOD EP-1 OR ROOF
21	21		2			"GFCI" BREAKER		1200		22	22	20	1	#0	3/4"	FLY GRID
23	23	30	2	#8	3/4"	SUSH CASE	1200			24	24	20	1	#0	3/4"	MRAD
25	25		2			"GFCI" BREAKER		1200		26	26	20	1	#0	3/4"	SPARE
27	27	30	2	#8	3/4"	BERRY CASE	1200			28	28	20	1	#0	3/4"	SPARE
29	29		2			"GFCI" BREAKER		1200		30	30	20	1	#0	3/4"	SPARE
31	31	30	2	#8	3/4"	BERRY CASE	1200			32	32	20	1	#0	3/4"	SPARE
33	33		2			"GFCI" BREAKER		1200		34	34	20	1	#0	3/4"	SPARE
35	35	50	2	#6	3/4"	BERRY CASE			1200	36	36	20	1	#0	3/4"	HAND DRYER - MEN
37	37		2			"GFCI" BREAKER	1200			38	38		2			
39	39	50	2	#6	3/4"	BERRY CASE		1200		40	40	20	1	#0	3/4"	HAND DRYER - WOMEN
41	41		2			"GFCI" BREAKER			1200	42	42		2			
FLUSH MTD. ___ SURFACE MTD. ___ YES						CONNECTED V. A. / PHASE	11,200	11,200	11,200							
						CONNECTED AMP. / PHASE	93.3	93.3	93.3							

PANEL SCHEDULE NOTES
1. ALL SUB-PANELS SHALL BE EQUIPPED WITH SEPARATE EQUIPMENT FACTORY GROUND BUS BAR SIZED AS PER NEC ARTICLE 250.
2. DO NOT SHARE NEUTRAL CONDUCTORS BETWEEN SINGLE POLE BREAKERS AS PER 2017 NATIONAL ELECTRICAL CODE 210.4(D) & (E).
3. ALL BREAKERS WITH IN THIS PANEL SHALL BE "GFCI" TYPE.

PANEL "HD" — DELI/BAKERY — 225 M.L.O.

277/480 VOLTS, 3-PHASE, 4-WIRE, WYE CONNECTED. ___ LUG / WIRE. DRAWG NO

POLE NO.	BKR NO.	TRIP AMP.	POLE	HARE AMPS.	COND SIZE	SERVES	A-PH.	LOAD V. A. B-PH.	C-PH.	POLE NO.	BKR NO.	TRIP AMP.	POLE	HARE AMPS.	COND SIZE	SERVES
1	1	40	2	#8	3/4"	COMBI CIRCUITS	1500			2	2	40	2	#8	3/4"	COMBI CIRCUITS
3	3					DOUBLE OVEN		1500		4	4					DOUBLE OVEN
5	5					DISCO-480			1500	6	6					DISCO-480
7	7	—	—	—	—	SHUNT TRIP COILS	—	—	—	8	8	—	—	—	—	SHUNT TRIP COILS
9	9	20	1	—	—	SPACE	—	—	—	10	10	20	1	—	—	SPACE
11	11	20	1	—	—	SPACE	—	—	—	12	12	20	1	—	—	SPACE
13	13	20	1	—	—	SPACE	—	—	—	14	14	20	1	—	—	SPACE
15	15	20	1	—	—	SPACE	—	—	—	16	16	20	1	—	—	SPACE
17	17	20	1	—	—	SPACE	—	—	—	18	18	20	1	—	—	SPACE
19	19	20	1	—	—	SPACE	—	—	—	20	20	20	1	—	—	SPACE
21	21	20	1	—	—	SPACE	—	—	—	22	22	20	1	—	—	SPACE
23	23	20	1	—	—	SPACE	—	—	—	24	24	20	1	—	—	SPACE
25	25	20	1	—	—	SPACE	—	—	—	26	26	20	1	—	—	SPACE
27	27	20	1	—	—	SPACE	—	—	—	28	28	20	1	—	—	SPACE
29	29	20	1	—	—	SPACE	—	—	—	30	30	20	1	—	—	SPACE
31	31	20	1	—	—	SPACE	—	—	—	32	32	20	1	—	—	SPACE
33	33	20	1	—	—	SPACE	—	—	—	34	34	20	1	—	—	SPACE
35	35	20	1	—	—	SPACE	—	—	—	36	36	20	1	—	—	SPACE
37	37	20	1	—	—	SPACE	—	—	—	38	38	20	1	—	—	SPACE
39	39	20	1	—	—	SPACE	—	—	—	40	40	20	1	—	—	SPACE
41	41	20	1	—	—	SPACE	—	—	—	42	42	20	1	—	—	SPACE
FLUSH MTD. ___ SURFACE MTD. ___						CONNECTED V. A. / PHASE	21,900	21,900	21,900							
						CONNECTED AMP. / PHASE	79.1	79.1	79.1							

PANEL SCHEDULE NOTES
1. ALL SUB-PANELS SHALL BE EQUIPPED WITH SEPARATE EQUIPMENT FACTORY GROUND BUS BAR SIZED AS PER NEC ARTICLE 250.
2. DO NOT SHARE NEUTRAL CONDUCTORS BETWEEN SINGLE POLE BREAKERS AS PER 2017 NATIONAL ELECTRICAL CODE 210.4(D) & (E).

PANEL "LE" — 225 M.L.O.

120/208 VOLTS, 3-PHASE, 4-WIRE, WYE CONNECTED. DRAWING NO

POLE NO.	BKR NO.	TRIP AMP.	POLE	HARE AMPS.	COND SIZE	SERVES	A-PH.	LOAD V. A. B-PH.	C-PH.	POLE NO.	BKR NO.	TRIP AMP.	POLE	HARE AMPS.	COND SIZE	SERVES
1	1									2	2	20	1	#0	3/4"	PLUGS
3	3	20	1	#0	3/4"	CORD DROPS	1200			4	4	20	1	#0	3/4"	PLUGS
5	5	20	1	#0	3/4"	CORD DROPS		1200		6	6	20	1	#0	3/4"	PLUGS
7	7	20	1	#0	3/4"	CORD DROPS			1200	8	8	20	1	#0	3/4"	PLUGS
9	9	20	1	#0	3/4"	PET FOOD	1200			10	10	20	1	#0	3/4"	PLUGS
11	11	20	1	#0	3/4"	PET FOOD		1200		12	12	20	1	#0	3/4"	PLUGS
13	13	20	1	#0	3/4"	SHELVING			1200	14	14	20	1	#0	3/4"	PLUGS
15	15	20	1	#0	3/4"	SHELVING	1200			16	16	20	1	#0	3/4"	COSM. SHELVING
17	17	20	1	#0	3/4"	SHELVING		1200		18	18	20	1	#0	3/4"	COSM. SHELVING
19	19	20	1	#0	3/4"	SHELVING			1200	20	20	20	1	#0	3/4"	COSM. SHELVING
21	21	20	1	#0	3/4"	SHELVING	1200			22	22	20	1	#0	3/4"	COSM. SHELVING
23	23	20	1	#0	3/4"	SHELVING		1200		24	24	20	1	#0	3/4"	COSM. SHELVING
25	25	20	1	#0	3/4"	SHELVING			1200	26	26	20	1	#0	3/4"	COSM. SHELVING
27	27	20	1	#0	3/4"	SHELVING	1200			28	28	20	1	#0	3/4"	COSM. SHELVING
29	29	20	1	#0	3/4"	SHELVING		1200		30	30	20	1	#0	3/4"	COSM. SHELVING
31	31	20	1	#0	3/4"	SHELVING			1200	32	32	20	1	#0	3/4"	COSM. SHELVING
33	33	20	1	#0	3/4"	SHELVING	1200			34	34	20	1	#0	3/4"	COSM. SHELVING
35	35	20	1	#0	3/4"	SHELVING		1200		36	36	20	1	#0	3/4"	COSM. SHELVING
37	37	20	1	#0	3/4"	SHELVING			1200	38	38	20	1	#0	3/4"	COSM. SHELVING
39	39	20	1	#0	3/4"	COSM. SHELVING	1200			40	40	20	1	#0	3/4"	COSM. SHELVING
41	41	20	1	#0	3/4"	COSM. SHELVING		1200		42	42	20	1	#0	3/4"	COSM. SHELVING
FLUSH MTD. ___ SURFACE MTD. ___ YES						CONNECTED V. A. / PHASE	11,200	11,200	11,200							
						CONNECTED AMP. / PHASE	128.7	128.7	128.7							

PANEL SCHEDULE NOTES
1. ALL SUB-PANELS SHALL BE EQUIPPED WITH SEPARATE EQUIPMENT FACTORY GROUND BUS BAR SIZED AS PER NEC ARTICLE 250.
2. DO NOT SHARE NEUTRAL CONDUCTORS BETWEEN SINGLE POLE BREAKERS AS PER 2017 NATIONAL ELECTRICAL CODE 210.4(D) & (E).

NOTE:
ELECTRICAL CONTRACTOR SHALL PROVIDE A DEFROST PANEL PER REFRIGERATION SYSTEM WITH ELECTRIC DEFROST. VERIFY EXACT NUMBER REQUIRED WITH REFRIGERATION DRAWINGS.



DEFROST POWER PANEL DETAIL
NTS (KR101k)

Order Plans @ WWW.DILine.com

D&E DOLLAR & EWERS ARCHITECTURE, INC.
[illegible] Avenue ♦ [illegible] 37915
[illegible] ♦ [illegible] ♦ fax: 865-673-9028
[illegible] dollar-ewers.com

GEORGIA REGISTERED PROFESSIONAL No. 026529 ENGINEER KEVIN E. NORRIS 03/04/19

NO.	REVISIONS

A With-in-the-Walls Remodel for:
KROGER STORE #GA-483 SNELLVILLE
1670 STATE HWY 124, SUITE 'F', SNELLVILLE, GEORGIA 30078

FEEDER DIAGRAMS

COPYRIGHT
ALL DRAWINGS, SPECIFICATIONS AND COPIES THEREOF FURNISHED BY DOLLAR & EWERS ARCHITECTURE, INC. ARE AND SHALL REMAIN THE PROPERTY OF DE SEAL, INC.; THEY ARE TO BE USED ONLY WITH RESPECT TO THIS PROJECT AND SHALL NOT BE USED ON ANY OTHER WORK EXCEPT BY AGREEMENT WITH THE ARCHITECT. ALL RIGHTS RESERVED. THIS DRAWING IS PUBLISHED FOR LIMITED DISTRIBUTION TO MEET CITY/COUNTY REGULATORY REQUIREMENTS FOR CONSTRUCTION WITHIN THEIR JURISDICTIONAL AUTHORITY AND IS NOT TO BE CONSTRUED AS PUBLICATION IN DEROGATION OF ARCHITECT'S COMMON LAW COPYRIGHT OR OTHER RESERVED RIGHTS.
COPYRIGHT

KEVIN E. NORRIS
ELECTRICAL ENGINEER
3518 WALLWOOD ROAD
KNOXVILLE, TN 37912
PHONE: (865) 584-3063

THIS DRAWING AND ITS DESIGN CONCEPT ARE THE PROPERTY OF KEVIN E. NORRIS - ELECTRICAL ENGINEER, KNOXVILLE, TN. THIS DRAWING SHALL BE DEEMED NOT VALID UNLESS IT BEARS THE ORIGINAL STATE SEAL AND AN ORIGINAL SIGNATURE AND DATE AND APPLIED TO THE DRAWING BY THE ENGINEER. ANY UNLAWFUL CHANGES TO AND EXCEPT WHERE SPECIFICALLY DIMENSIONED OR DETAILED, INDICATES THE GENERAL ARRANGEMENT OF THE WORK. THE CONTRACTOR SHALL ADJUST THE WORK TO CONFORM AS NEARLY AS POSSIBLE TO THE LOCATIONS AND ARRANGEMENTS SHOWN. COORDINATE THE WORK WITH ALL TRADES TO AVOID INTERFERENCES.

ISSUE DATE: March 04, 2019
PROJECT NO.: 219206 / 19001
SHEET NUMBER: E6.1