

**PLUMBING GENERAL NOTES:**

**GENERAL:**  
THESE GENERAL NOTES PRESENT AND/OR SUMMARIZE KEY PRODUCT INFORMATION FOR THE PLAN READER'S CONVENIENCE. SEE PLANS AND SPECIFICATIONS FOR FURTHER REQUIREMENTS.

WORK COVERED BY THIS DOCUMENT SHALL INCLUDE ALL LABOR, MATERIAL, PRODUCTS, AND SERVICES FOR, AND INCIDENTAL TO, INSTALLATION OF COMPLETE AND OPERATING PLUMBING SYSTEMS DRAWN OR SPECIFIED.

ALL WORK SHALL CONFORM TO ALL APPLICABLE FEDERAL, STATE, AND LOCAL CODES INCLUDING, BUT NOT LIMITED TO, 2012 INTERNATIONAL PLUMBING CODE w/ AMENDMENTS, 2010 ADA STANDARDS FOR ACCESSIBLE DESIGN AND ALL ADA AMENDMENTS.

ALL EQUIPMENT AND MATERIALS SHALL BE AS SPECIFIED OR "APPROVED EQUAL" BY THE ARCHITECT OR ENGINEER.

INSTALL ALL PLUMBING FIXTURES PER MANUFACTURER'S INSTRUCTIONS.

EXACT LOCATIONS AND ROUGHING REQUIREMENTS FOR ALL FIXTURES AND EQUIPMENT SHALL BE DETERMINED FROM ARCHITECTURAL DRAWINGS, LARGE SCALE ARCHITECTURAL DETAILS, AND APPROVED MANUFACTURER'S SHOP DRAWINGS. PARTICULAR ATTENTION SHALL BE DIRECTED TO FIXTURES OR EQUIPMENT FURNISHED UNDER OTHER DIVISIONS.

PIPING IS SHOWN IN ITS GENERAL LOCATION (UNLESS DIMENSIONED). EXACT LOCATION SHALL BE DETERMINED BY JOB CONDITIONS. CONTRACTOR SHALL COORDINATE THE INSTALLATION OF HIS WORK WITH THAT OF OTHER TRADES AND ARRANGE PIPING TO CLEAR STRUCTURAL MEMBERS AND DUCTWORK. EXACT LOCATIONS SHALL BE PROVIDED ON "AS-BUILT" DRAWINGS.

MINIMUM SIZE WATER LINE FOR THREE OR MORE FIXTURES SHALL BE 3/4". REFER TO PLUMBING FIXTURE SCHEDULE FOR INDIVIDUAL RUNOUT SIZES.

ALL PIPING TO BE CONCEALED IN A WALL, CEILING, OR A CHASE UNLESS OTHERWISE NOTED. PIPING SHOWN OUT OF CHASES FOR CLARITY.

PROVIDE SLEEVES FOR PIPES PASSING THRU FLOORS, MASONRY WALLS AND FIRE OR SMOKE PARTITIONS. PACK MINERAL WOOL IN ANNULAR SPACE BETWEEN PIPE SLEEVE.

REFER TO ARCHITECTURAL DRAWINGS FOR EXACT FIXTURE MOUNTING HEIGHTS. ALL ACCESSIBLE FIXTURES SHALL COMPLY WITH STATE BUILDING CODE AND 2010 ADA STANDARDS FOR ACCESSIBLE DESIGN.

ARRANGEMENTS OF WORK SHALL BE AS SHOWN. DRAWINGS ARE NOT INTENDED TO INDICATE ALL OFFSETS AND FITTINGS. EXAMINE ALL DRAWINGS, INVESTIGATE CONDITIONS TO BE ENCOUNTERED AND ARRANGE WORK ACCORDINGLY; FURNISH ALL FITTINGS AND OFFSETS.

MEASUREMENT OF DRAWINGS BY SCALE SHALL NOT BE USED AS DIMENSIONS FOR FABRICATION. MEASUREMENTS FOR LOCATING FIXTURES, EQUIPMENT, DUCTWORK, PIPING AND ACCESSORIES SHALL BE MADE ON THE SITE AND SHALL BE BASED ON ACTUAL JOB CONDITIONS. THE CONTRACTOR SHALL BE RESPONSIBLE FOR ALL MEASUREMENTS WHERE THE CONTRACTOR PREFABRICATES ANY WORK BASED ON THE DRAWINGS WITHOUT VERIFYING ACTUAL JOB CONDITIONS. THEN THE CONTRACTOR SHALL BE RESPONSIBLE FOR ANY AND ALL COST INVOLVED IN MAKING CHANGES TO PREFABRICATED WORK WHERE CONFLICTS OCCUR.

ARRANGE FOR CHASES, SLOTS, AND OPENINGS IN OTHER BUILDING COMPONENTS DURING PROGRESS OF CONSTRUCTION TO ALLOW FOR INSTALLATIONS.

INSTALL SYSTEMS, MATERIALS, AND EQUIPMENT LEVEL, PLUMB, PARALLEL, AND PERPENDICULAR TO OTHER BUILDING SYSTEMS AND COMPONENTS.

COPPER PIPING SHALL NOT BE INSTALLED IN DIRECT CONTACT WITH MASONRY, CEMENT MORTAR, CONCRETE, OR DISSIMILAR METALS. PLUMBING CONTRACTOR TO PROVIDE SLEEVES AND COORDINATE w/ GENERAL CONTRACTOR DURING SLAB INSTALLATION.

CUTTING AND REPAIRING: THE PLUMBING CONTRACTOR SHALL DO ALL CUTTING AND REPAIRING OF WALLS, FLOORS, CEILINGS, ETC. NECESSARY FOR THE INSTALLATION OF THE WORK BUT HE SHALL NOT CUT INTO ANY STRUCTURAL MEMBER WITHOUT THE PERMISSION OF THE ARCHITECT.

PROVIDE SHOCK ABSORBERS AS INDICATED ON PLANS.

PLUMBING CONTRACTOR TO PROVIDE PROPER SEPARATION BETWEEN WATER SUPPLY AND WASTE/SANITARY PIPING PER INTERNATIONAL PLUMBING CODE.

PLUMBING CONTRACTOR TO PROVIDE PREPRINTED 1/2" HIGH LETTERED LABELS FOR THE FOLLOWING: INTERIOR MAIN SHUT-OFF VALVE, POTABLE WATER SUPPLY PIPING, & HOT WATER PIPING. LABELS SHOULD BE MOUNTED EVERY 20'-0" ON HORIZONTAL RUNS.

GENERAL CONTRACTOR TO PROVIDE ACCESS PANELS TO ALL ACCESSIBLE, ABOVE CEILING VALVES AND EQUIPMENT. COORDINATE LOCATIONS WITH ARCHITECT PRIOR TO INSTALLATION.

**DOMESTIC WATER PIPING:**  
UNDER-BUILDING SLAB, DOMESTIC WATER, BUILDING SERVICE PIPING SHALL BE SOFT COPPER TUBING, ASTM B 88, TYPE K, WITH WROUGHT-COPPER, SOLDER-JOINT FITTINGS, AND BRAZED JOINTS. AVOID JOINTS UNDER BUILDING SLAB WHERE POSSIBLE.

ALL OTHER UNDER-BUILDING SLAB, DOMESTIC WATER PIPING SHALL BE SOFT COPPER TUBING, ASTM B 88, TYPE L, WITH WROUGHT-COPPER, SOLDER-JOINT FITTINGS, AND BRAZED JOINTS. AVOID JOINTS UNDER BUILDING SLAB WHERE POSSIBLE.

ALL ABOVEGROUND DOMESTIC WATER PIPING SHALL BE HARD COPPER TUBING, ASTM B 88, TYPE L, WITH CAST-OR WROUGHT-COPPER, SOLDER-JOINT FITTINGS, AND SOLDERED JOINTS.

ALL INDOOR DOMESTIC COLD, HOT, AND RECIRCULATED HOT WATER PIPING SHALL BE INSULATED WITH 1 INCH THICK FLEXIBLE CLOSED-CELL ELASTOMERIC INSULATION, COMPLYING WITH ASTM C 534, TYPE 1 FOR TUBULAR MATERIALS, EQUAL TO ARMACELL "AP ARMAFLEX".

**SANITARY WASTE AND VENT PIPING:**  
ALL SOIL, DRAIN, WASTE AND VENT PIPING SHALL BE SCHEDULE 40 PVC-DWV WITH SOLVENT WELD JOINTS, CONFORMING TO ASTM D 2665 AND ASTM D 2564. IN AREAS WITH RETURN AIR PLENUM ABOVE THE CEILING, TRANSITION PIPING BELOW CEILING FROM PVC TO HUBLESS CAST-IRON, EXTEND CAST IRON VENT THROUGH ROOF. PVC PIPING IS NOT ALLOWED IN RETURN AIR PLENUM SPACES.

ALL SOIL, DRAIN, WASTE AND VENT PIPING LOCATED IN RETURN AIR PLENUMS SHALL BE HUBLESS CAST-IRON SOIL PIPE AND FITTINGS, CONFORMING TO ASTM A 888 OR CISPI 301, WITH CISPI HUBLESS PIPING COUPLINGS, CONFORMING TO ASTM C 1277 AND CISPI 310, AND COUPLED JOINTS.


ALL PIPING PASSING THROUGH THE ROOF SHALL BE FLASHED WITH ROOF FLASHING ASSEMBLY COMPATIBLE WITH THE ROOFING SYSTEM.

**FIELD QUALITY CONTROL:**  
ALL DOMESTIC WATER PIPING SHALL BE TESTED FOR LEAKS AND DEFECTS. FILL DOMESTIC WATER PIPING, CAP, AND SUBJECT PIPING TO STATIC WATER PRESSURE OF 50 PSIG ABOVE OPERATING PRESSURE, WITHOUT EXCEEDING PRESSURE RATING OF PIPING SYSTEM MATERIALS. ISOLATE TEST SOURCE AND ALLOW IT TO STAND FOR FOUR HOURS.

LEAKS AND LOSS IN TEST PRESSURE CONSTITUTE DEFECTS THAT MUST BE REPAIRED. LEAVE DOMESTIC WATER PIPING UNCOVERED AND UNCONCEALED UNTIL IT HAS BEEN TESTED AND APPROVED.

ALL SANITARY WASTE AND VENT PIPING SHALL BE TESTED FOR LEAKS AND DEFECTS AT COMPLETION OF ROUGH-IN. CLOSE OPENINGS IN PIPING SYSTEM AND FILL WITH WATER TO POINT OF OVERFLOW, BUT NOT LESS THAN 10-FOOT HEAD OF WATER. FROM 15 MINUTES BEFORE INSPECTION STARTS TO COMPLETION OF INSPECTION, WATER LEVEL MUST NOT DROP. INSPECT JOINTS FOR LEAKS. REPAIR LEAKS AND DEFECTS WITH NEW MATERIALS AND RETEST PIPING, OR PORTIONS THEREOF, UNTIL SATISFACTORY RESULTS ARE OBTAINED. INSTALL TEST TEES WHEN THE SYSTEM IS TO BE TESTED IN SECTIONS. LEAVE SANITARY WASTE AND VENT PIPING UNCOVERED AND UNCONCEALED UNTIL IT HAS BEEN TESTED AND APPROVED.

PLUMBING LEGEND	
SYMBOL	DESCRIPTION
---	UNDERGROUND SOIL & WASTE PIPING
- - - -	VENT PIPING
FD	FLOOR DRAIN (SEE SCHEDULE)
SD	SHOWER DRAIN (SEE SCHEDULE)
HD	HUB DRAIN
WCO	WALL CLEANOUT (SEE SCHEDULE)
FCO	FLOOR CLEANOUT (SEE SCHEDULE)
CCO	GROUNDER CLEANOUT (SEE SCHEDULE)
TR	VENT THROUGH ROOF
W	WASTE PIPING
CI	CAST IRON
S	SANITARY PIPING
CW	COLD WATER PIPING
HW	HOT WATER PIPING
P.R.V.	PRESSURE REDUCING VALVE
DWN.	DOWN
TYP.	TYPICAL
U.N.O.	UNLESS NOTED OTHERWISE
▶	FLOW ARROW
---	POTABLE WATER PIPING
- - - -	POTABLE WATER UNDERGROUND PIPING
-----	110°F HOT WATER UNDERGROUND PIPING
-----	110°F HOT WATER PIPING
HWR	HOT WATER RECIRCULATION PIPING
⊕	FULL PORT BALL VALVE
WH	WALL HYDRANT (SEE PLUMBING SCHEDULE)
HB	HOSE BIBB (SEE PLUMBING SCHEDULE)
○	PIPE DOWN
○	PIPE UP
○○	P-TRAP



**JOHNSON, LASCOBBER & ASSOCIATES, P.C.**  
 1001 W. MOUNTAIN VIEW BLVD., SUITE 100  
 AUGUSTA, GA 30901 • TEL: (843) 619-4656  
 TEL: (706) 724-5756 • TEL: (843) 619-4656  
 FAX: (706) 724-3935  
 WWW.THEJLAGROUP.COM

CLIENT: AUGUSTA, GA  
 535 TELFAIR STREET, AUGUSTA, GA 30901

PROJECT NAME: **FIRE STATION #3**

PROJECT LOCATION: 2649 GORDON HWY., AUGUSTA, GA 30909

REV.	DATE	BY	DESCRIPTION
0	12/27/18	MNB	ISSUED FOR BID

PROJECT NO. 3042.1604  
 DRAWN BY: WBR  
 CHECKED BY: MNB  
 DATE: 10/18/17

SHEET TITLE:  
**PLUMBING GENERAL NOTES AND LEGEND**

SCALE: AS NOTED

DRAWING NO. **P-001** REV. **0**

Order Plans @

WWW.LDOnline.com

This document is the property of Johnson, Lascobber & Associates, P.C. The unauthorized reproduction, copying or otherwise use of this document is strictly prohibited and any infringement thereupon may be subject to legal action.