


POWER AND SIGNAL CONSTRUCTION NOTES:

- COORDINATE RECEPTACLE LOCATIONS AND MOUNTING HEIGHTS WITH MILLWORK AND OWNER.
- PROVIDE 2 DATA LINES AND 1" CONDUIT FOR ALL DATA DROPS UNLESS NOTED OTHERWISE.
- PROVIDE ARC FAULT INTERRUPTING TYPE CIRCUIT PROTECTION FOR ALL RECEPTACLE CIRCUITS IN SLEEPING AREAS.
- CAT6 CABLE TO WAPS SHALL BE YELLOW.
- PROVIDE LADDER RACK WITH SHELF TO WALL IN IT ROOM. COORDINATE EXACT LOCATION WITH OWNER.

POWER AND SIGNAL PLAN KEYS NOTES:


- COORDINATE EXACT LOCATION WITH OWNER.
- INTERLOCK FAN WITH LIGHTS.
- MARK RECEPTACLE STORAGE PER 2017 NEC ARTICLE 110.26.
- COVERED BY MILLWORK.
- PROVIDE 4 DATA LINES AND 1" CONDUIT.
- PROVIDE TWO SETS OF THREE (3) - 4" CONDUITS WITH 1" INNER DUCT FROM TV TO VAULTS. THREE PER VAULT FOR A TOTAL OF SIX. CAP CONDUIT AND PROVIDE NYLON PULL STRING. ALL CONDUIT SHALL BE WATER TIGHT AND FREE OF WATER. ROUTE 3 CONDUITS TO EACH PULL BOX. REFERENCE CIVIL DRAWINGS.
- PROVIDE JUNCTION BOX WITH BLANK COVER PLATE. PROVIDE 1" MINIMUM CONDUIT FROM JUNCTION BOX TO TV BOX. COORDINATE LOCATION WITH OWNER.
- PROVIDE TWO GANG JUNCTION BOX WITH BLANK COVER PLATE FOR FUTURE DOOR BELL. PROVIDE (2) TWO 1" CONDUITS FROM JUNCTION BOX TO ABOVE ACCESSIBLE CEILING. COORDINATE LOCATION WITH OWNER.
- PROVIDE QUADRUPLEX RECEPTACLE AT TOP OF RACK. COORDINATE RACK LOCATION WITH OWNER.
- STUB OUT 4" CONDUIT FROM OUTSIDE SLAB TO ABOVE ACCESSIBLE CEILING FOR TOWER TELECOMMUNICATIONS. PROVIDE SWEEPING CONNECTIONS. COORDINATE EXACT LOCATION OF TOWER WITH CIVIL DRAWINGS.
- NOT USED.
- PROVIDE SHUNT TRIP DEVICE FOR ALL CIRCUITS UNDER KITCHEN HOOD. INTERLOCK WITH HOOD SUPPRESSION SYSTEM.
- PROVIDE PLYWOOD ON THREE (3) SIDES OF THIS ROOM.




CLIENT: AUGUSTA, GA
535 TELFAIR STREET, AUGUSTA, GA 30901

PROJECT NAME: FIRE STATION #20


PROJECT LOCATION: 2820 OLD HIGHWAY 1, HEPHIZIBAH, GEORGIA 30815




1 POWER & SIGNAL PLAN
E-201 SCALE: 1/8" = 1'-0"



2 MEZZANINE POWER & SIGNAL PLAN
E-201 SCALE: 1/8" = 1'-0"



3 ENLARGED IT CLOSET
E-201 SCALE: 1/4" = 1'-0"



Order Plans

REV	DATE	BY	DESCRIPTION
0	12/21/18	FAK	ISSUED FOR BID

PROJECT NO: 3042.1604
DRAWN BY: JAP/JFP
CHECKED BY: FAK
DATE: 8/10/18

SHEET TITLE:
POWER & SIGNAL PLAN

SCALE: AS NOTED
DRAWING NO. **E-201**

REV: 0

This document is the property of Johnson, Labchober & Associates, P.C. The unauthorized reproduction, copying or otherwise use of this document is strictly prohibited and any infringement thereupon may be subject to legal action.