

ELECTRICAL SPECIFICATIONS

GENERAL NOTES

PART 1 - GENERAL
1.01 COORDINATION OF TRADES: SCHEDULE AND COORDINATE WORK WITH THAT OF OTHER DIVISIONS AND SECTIONS.
1.02 GUARANTEE IN WRITING THE ELECTRICAL INSTALLATION, AND ALL WORK UNDER THIS SECTION, FOR A PERIOD OF ONE YEAR FROM THE DATE OF FINAL ACCEPTANCE BY THE OWNER AGAINST ALL EVIDENCE OF IMPERFECT WORKMANSHIP OR FAILURE OR MALFUNCTION OF MATERIALS.

1. THE ELECTRICAL DRAWINGS, SPECIFICATIONS AND GENERAL NOTES DESCRIBE THE RECOMMENDED SCOPE OF WORK AND THE DOCUMENTS SHALL BE USED FOR THE PURPOSE OF BIDDING, BUILDING DEPARTMENT REVIEW, AND TO SECURE THE NECESSARY CONSTRUCTION PERMIT ONLY.
2. BRANCH CONTROL CIRCUITING AND WIRE COUNT MAY NOT BE INDICATED ON THESE PLANS. CONTRACTOR IS RESPONSIBLE TO COMPLETE THE BRANCH CIRCUIT WIRING IN ACCORDANCE WITH PLAN NOTES AND AS PERMITTED BY AUTHORITY. CONTRACTOR SHALL SUBMIT AS-BUILT DRAWINGS AS A PART OF RECORD DRAWING SUBMITTAL TO ARCHITECT AND AUTHORITY HAVING JURISDICTION (A.N.J.).

CONDUIT AND CONDUCTORS SCHEDULE table with columns for Mark No., OCP Device (A/P), Rating, Conductor Phase & Neutral, Raceway Size (nominal inches), etc.

TESTING FOR EMERGENCY RESPONSE RADIO COVERAGE SHALL BE CONDUCTED IN ACCORDANCE WITH IFC 510
MC CABLE SHALL NOT BE USED. PREWIRED MC CABLE WHIPS FROM LIGHTING FIXTURES ARE ACCEPTABLE WHEN SUPPLIED WITH THE FIXTURE AND NO LONGER THAN 72".
ELECTRICIAN TO PROVIDE STAINLESS STEEL COVER PLATES FOR ALL LOW VOLTAGE JUNCTION BOXES.
NO UNDER SLAB ELECTRICAL WORK ALLOWED UNLESS OTHERWISE NOTED ON PLAN.

ELECTRICAL SYMBOLS LIST table with columns for POWER DISTRIBUTION, LIGHTING & LIGHTING CONTROLS, RECEPTACLES & COMMUNICATIONS OUTLETS, and FIRE ALARM.

ELECTRICAL SPECIFICATIONS 3
NOT TO SCALE E-000

GENERAL NOTES 2
NOT TO SCALE E-000

ELECTRICAL SYMBOLS 1
NOT TO SCALE E-000



PANDA EXPRESS, INC.
1683 Walnut Grove Ave.
Rosemead, California
91770
Telephone: 626.799.9898
Facsimile: 626.372.8288

All ideas, designs, arrangement and plans indicated or represented by this drawing are the property of Panda Express Inc. and were created for use on this specific project. None of these ideas, designs, arrangements or plans may be used by or disclosed to any person, firm, or corporation without the written permission of Panda Express Inc.

REVISIONS table with columns for No., Description, and Date.

ISSUE DATE:
1st ISSUE FOR PERMIT 11-30-18
DRAWN BY: RR
PANDA PROJECT # S8-19-D6559
ARCH PROJECT # 1805
Project No. PE1805
Kurzynske & Associates CONSULTING ENGINEERS
2900 Lebanon Pike Suite 201
Nashville, Tennessee 37214



PANDA EXPRESS
ELM HILL PIKE AT DONELSON PIKE
2740 ELM HILL PIKE
NASHVILLE, TN 37214
2200 TRUE R1 (DAB 013)

E-000
ELECTRICAL SYMBOLS SPECIFICATIONS, NOTES
NOT TO SCALE E-000