


- ROOF FRAMING PLAN LEGEND:**
- ① INDICATES NOT REFERRED TO SEE CORRESPONDING PLAN NOTE.
 - INDICATES MASONRY WALL BELOW. SEE NOTE 3.
 - INDICATES PERIMETER WALLS. SEE NOTE 3.
 - M. INDICATES MASONRY LINTEL OVER WALL OPENING BELOW. SEE LINTEL SCHEDULE ON SHEET S3.1.
 - DH6 INDICATES HEADERS OVER WALL OPENINGS BELOW. SEE HEADER SCHEDULE ON SHEET S0.2.
 - INDICATES INTERIOR WALLS BELOW.

- ROOF FRAMING PLAN NOTES:**
1. ROOF CONSTRUCTION:
 - A. DECK: 3" - 22 GAGE TYPE 'N' STEEL ROOF DECK.
 - B. ATTACHMENT TO SUPPORTS: #12 SCREWS IN 24" / 4 FASTENER PATTERN.
 - C. SIDE LAP CONNECTION: (4) #10 SCREWS PER SPAN.
 - D. PERIMETER CONNECTION: #12 SCREWS @ 8" ON CENTER.
 - E. INSTALLATION CONFIGURATION: TWO SPAN MINIMUM.
 - F. NO BUILDING ELEMENTS ARE TO BE HUNG DIRECTLY FROM UNDERSIDE OF DECK BETWEEN LOAD BEARING WALLS.
 2. SEE PLAN FOR SPOT DECK BEARING ELEVATIONS. STRUCTURE SLOPES UNIFORMLY BETWEEN POINTS OF GIVEN ELEVATION.
 3. 8" MASONRY WALLS.
 - A. WALL: 8" CMU.
 - B. WALL REINFORCEMENT: #5 @ 32" ON CENTER.
 - C. REINFORCEMENT POSITION: CENTER IN MASONRY UNIT CELL IN EACH DIRECTION, UNLESS NOTED OTHERWISE ON THE DRAWINGS.
 - D. HORIZONTAL REINFORCEMENT: #9 WIRE LADDER TYPE @ 16" ON CENTER.
 - E. SEE DETAILS ON SHEET S3.1 FOR ADDITIONAL REINFORCEMENT REQUIREMENTS.
 4. SEE DETAIL 12 / S3.1 FOR TYPICAL ROOF DECK SUPPORT MEMBER CONNECTION TO MASONRY WALL. USE HALF NUMBER OF SCREWS SPECIFIED FOR DH6 HEADER.
 5. SEE DETAIL 10 / S5.1 FOR STEEL BEAM TO STEEL COLUMN CONNECTION.
 6. 600 S 200-S4 TYPICAL UNDER RTU SUPPORT RAILS. ATTACH TO HEADER MEMBERS AT EACH END WITH 3" x 3" x 14 GA. ANGLE WITH (3) #12 SCREWS INTO EACH MEMBER.
 7. SPACE TYPICAL EXTERIOR STUDS AT 16" O.C. AT NOTED LOCATIONS IN ZONE 3 OF THE COMPONENTS AND CLADDING WIND PRESSURES.

ROOF FRAMING PLAN
SCALE: 1/8" = 1'-0"
T.O.S = VARIES S1.3



Order Plans @ WWW.LDILINE.com

THESE DRAWINGS AND DESIGNS ARE THE PROPERTY OF STINARD ARCHITECTURE, INC. AND SHALL NOT BE REPRODUCED, COPIED, OR TRANSMITTED IN ANY FORM OR BY ANY MEANS, ELECTRONIC OR MECHANICAL, INCLUDING PHOTOCOPYING, RECORDING, OR BY ANY INFORMATION STORAGE AND RETRIEVAL SYSTEM, WITHOUT THE WRITTEN PERMISSION OF STINARD ARCHITECTURE, INC. THESE DRAWINGS ARE NOT TO BE USED FOR ANY OTHER PROJECT OR DATE AND ARE NOT SUITABLE FOR USE IN ANY OTHER JURISDICTION. ALL DIMENSIONS MUST BE VERIFIED BY THE CONTRACTOR AND DISCREPANCIES BEFORE PROCEEDING WITH CONSTRUCTION. DO NOT SCALE DRAWINGS.

Life Storage #354
2020 South College St
Auburn, AL 36832



ISSUE FOR CONSTRUCTION
REVISIONS:

PROJECT NUMBER: 201839
DATE: 03-15-2019

SHEET NUMBER: S1.3